

CUNNINGHAM

Security Systems

10 Princes Point Road • Yarmouth, Maine 04096
(207) 846-3350 • Fax (207) 846-6080 • (800) 210-0257

June 28, 2012

Attn: Don McPherson
Code Enforcement Officer
City of Portland
389 Congress Street
Portland, ME 04101
(207) 874-8705
Fax#: (207) 874-8716

Dear Mr. McPherson,

This letter is to inform you that on June 21, 2012, we completed the installation, programming and testing of a new fire alarm control panel at 88 Middle Street in Portland, Maine. All the horn/strobes, pull stations smoke detectors, sprinkler flow switches and sprinkler tamper switches were tied into this new fire alarm control and all these devices were programmed and test to NFPA 72 standards with test signals sent from these devices to our Central Monitoring Station. These devices were all found to be fully functional at that time.

Should you have any questions or comments regarding this matter, please feel free to contact me at (207) 846-3350.

Sincerely,



Ronald S. Sneider, Manager

cc: Acct. File

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND

BUILDING PERMIT

This is to certify that
CUNNINGHAM SECURITY
10 PRINCES POINT RD
YARMOUTH, ME 04096

For installation at
80 MIDDLE ST

Job ID: 2012-05-3926-FAFS

CBL: 029- L-004-001

has permission to install sprinkler supervisory system

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be


Fire Prevention Officer


Code Enforcement Officer / Plan Reviewer

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
PENALTY FOR REMOVING THIS CARD**