


REVISION	DESCRIPTION	DATE
0	ISSUED FOR REVIEW & APPROVAL	1/24/2014

RESERVED FOR CITY STAMP



PLAN NORTH
FIRST FLOOR FIRE ALARM PLAN
 SCALE: 1/8"=1'-0"

REVISION	DESCRIPTION	DATE
0	ISSUED FOR REVIEW & APPROVAL	1/24/2014

CUNNINGHAM
 Security Systems
 10 Princes Point Road, Yarmouth, Maine 04096
 Office: 207.846.3350 • Fax: 207.846.6080

COMMERCIAL PROPERTIES, INC.
 80-90 MIDDLE STREET
 PORTLAND, MAINE 04101
CALCS & FIRST FLOOR FIRE ALARM PLAN

DRAWN	JPB
CHECKED	WAYNE B. HANES
DATE	1/23/2014
REVISION	0
SCALE	1/8"=1'-0"

FA-2

FPS1 Battery Calculation 1/24/2014

PROJECT NAME: 80 MIDDLE STREET
 Required Standby Time: 24 Hours
 Required Alarm Time: 5 Minutes

AC Branch Current:	3.2	Amps	120V
Regulated Load in Standby	Number of Devices	Current (Amps)	Total Current (Amps)
FPS1-1	1	0.06500	0.06500
FPS1-2	1	0.06500	0.06500
TOTAL STANDBY LOAD			
Regulated Load in ALARM	Number of Devices	Current (Amps)	Total Current (Amps)
FPS1-1	1	0.14500	0.14500
FPS1-2	1	1.49700	1.49700
TOTAL ALARM LOAD			
Battery Requirements			
Standby Load	0.06500	X	24.00000
Alarm Load	2.87400	X	0.08333
Total Ampere Hours (before derating factor)			1.79950
Derating Factor			1.2
BATTERIES TO BE PROVIDED (2 - 12v)			7 AH

Existing FCP Battery Calculation 1/24/2014

PROJECT NAME: 80 MIDDLE STREET
 Required Standby Time: 24 Hours
 Required Alarm Time: 5 Minutes

Device Type	Number of Devices	Current (Amps)	Total Current (Amps)
Existing MS-9050UD System	1	0.00030	0.00030
S0355 Smoke Detector	1	0.00650	0.00650
TOTAL STANDBY LOAD			
Regulated Load in ALARM	Number of Devices	Current (Amps)	Total Current (Amps)
Existing MS-9050UD System	1	0.00030	0.00030
S0355 Smoke Detector	1	0.00650	0.00650
TOTAL ALARM LOAD			
Battery Requirements			
Standby Load	0.00030	X	24.00000
Alarm Load	0.00650	X	0.08333
Total Ampere Hours (before derating factor)			0.00774
Derating Factor			1.2
BATTERIES TO BE PROVIDED (2 - 12v)			FIELD VERIFY

NOTE: THE ABOVE BATTERY CALCULATION IS A COMBINED TOTAL OF THE ADDITIONAL LOADS THAT WILL BE ADDED FROM THE SCOPE OF THIS PROJECT. FIELD VERIFY THE SIZE OF THE EXISTING BATTERIES AND UPSIZE ACCORDINGLY.

NAC Circuit Voltage Drop Calculation 1/24/2014

Project Name: 80 MIDDLE STREET
 Circuit Number: FPS1-2

Nominal System Voltage	20.4	Volts
Minimum Device Voltage	16	Volts
Distance from source to 1st device	6.14	Per 1000
Wire Gauge for balance of circuit	14	
Max. Output Current	2.0	amps
Total Circuit Current	1.497	amps

Device	Current	Distance previous device	Voltage at Device	Drop from source	Percent Drop
Device 1	0.176		20.17	0.23	1%
Device 2	0.079	21	20.00	0.40	2%
Device 3	0.079	2	19.98	0.42	2%
Device 4	0.066	17	19.86	0.54	3%
Device 5	0.066	13	19.78	0.62	3%
Device 6	0.079	7	19.73	0.67	3%
Device 7	0.079	24	19.58	0.81	4%
Device 8	0.066	20	19.52	0.83	4%
Device 9	0.079	20	19.37	1.08	5%
Device 10	0.066	17	19.32	1.08	5%
Device 11	0.066	18	19.25	1.15	6%
Device 12	0.079	25	19.12	1.24	6%
Device 13	0.066	14	19.12	1.28	6%
Device 14	0.107	30	19.05	1.35	7%
Device 15	0.066	4	19.03	1.37	7%
Device 16	0.066	4	19.02	1.38	7%
Device 17	0.079	10	19.01	1.39	7%
Device 18	0.079	32	19.00	1.40	7%
Totals	1.497	310			

NAC Circuit Voltage Drop Calculation 1/24/2014

Project Name: 80 MIDDLE STREET
 Circuit Number: FPS1-1

Nominal System Voltage	20.4	Volts
Minimum Device Voltage	16	Volts
Distance from source to 1st device	6.14	Per 1000
Wire Gauge for balance of circuit	14	
Max. Output Current	1.5	amps
Total Circuit Current	1.232	amps

Device	Current	Distance previous device	Voltage at Device	Drop from source	Percent Drop
Device 1	0.079		20.32	0.08	0%
Device 2	0.107	17	20.20	0.20	1%
Device 3	0.176	40	19.95	0.45	2%
Device 4	0.079	23	19.86	0.54	3%
Device 5	0.079	21	19.75	0.65	3%
Device 6	0.066	5	19.73	0.67	3%
Device 7	0.066	8	19.70	0.70	3%
Device 8	0.066	20	19.58	0.82	4%
Device 9	0.066	20	19.57	0.83	4%
Device 10	0.066	6	19.57	0.83	4%
Device 11	0.066	10	19.54	0.86	4%
Device 12	0.079	22	19.50	0.90	4%
Device 13	0.079	15	19.48	0.92	5%
Device 14	0.066	17	19.47	0.93	5%
Device 15	0.079	2	19.47	0.93	5%
Totals	1.232	224			