

Freedom Fire Protection, Inc.

Over 30 Years of Fire Protection Experience
209 Quaker Ridge Rd. Casco, Maine 04015
Phone 207/627-4109 Fax 207/627-7340

May 21, 2015

Portland City Hall
Third Floor Room 315
Portland, Maine 04101

Attn: Captain Petruccelli

Ref: Hugo's Restaurant Renovation 2014
80-90 Middle Street
Portland, Maine 04101

Subj: Sprinkler System Certification Letter

This letter is certification that the renovations to the existing sprinkler system were designed, and installed at the above referenced location by Freedom Fire Protection. The installation meets the requirements of the National Fire Protection Association 13 Standard Light Hazard (NFPA 13).

Sprinkler permit # 11433 was issued by the State of Maine Fire Marshal's office.

The sprinkler system was left in service by Freedom Fire Protection on February 16, 2015.

Regards,