







OFFICE

SALES ROOM



Reviewed for Code Compliance Permitting and Inspections Department Approved with Conditions

01/30/2019

-COMMON PATH-82'

PER NFPA 101 OCCUPANCY
2,646SF/ 100 SF PER PERSON
= 27 OCCUPANTS
UNDER 50 OCCUPANTS=
SINGLE MEANS OF EGRESS ALLOWED COMMON PATH OF TRAVEL-MAXIMUM 100'



FIRST FLOOR ALTERATION PLAN