

City of Portland, Maine – Building or Use Permit Application 389 Congress Street, 04101, Tel: (207) 874-8703, FAX: 874-8716

Location of Construction: 15 Franklin St		Owner: A&M Partners		Phone: 874-6959		Permit No:
Owner Address:		Lessee/Buyer's Name:		BusinessName:		
Contractor Name: Southpaw Design		Address: 253 Gray Road, Falmouth		Phone: 878-0678		Permit Issued:
Past Use: Ofc Bldg		Proposed Use: Same w/sign		COST OF WORK: \$		
				PERMIT FEE: \$31.40		Zone: CBL: 29-N-4 73-1-10
				FIRE DEPT. <input type="checkbox"/> Approved <input type="checkbox"/> Denied		
Proposed Project Description: Erect sign (4x8) as per plans				INSPECTION: Use Group: Type:		Zoning Approval: Special Zone or Reviews: <input type="checkbox"/> Shoreland <input type="checkbox"/> Wetland <input type="checkbox"/> Flood Zone <input type="checkbox"/> Subdivision <input type="checkbox"/> Site Plan maj <input type="checkbox"/> minor <input type="checkbox"/> mm <input type="checkbox"/>
				Signature: _____ Date: _____		
Permit Taken By: Vicki Dover		Date Applied For: 2/10/98				Zoning Appeal <input type="checkbox"/> Variance <input type="checkbox"/> Miscellaneous <input type="checkbox"/> Conditional Use <input type="checkbox"/> Interpretation <input type="checkbox"/> Approved <input type="checkbox"/> Denied

1. This permit application does not preclude the Applicant(s) from meeting applicable State and Federal rules.
2. Building permits do not include plumbing, septic or electrical work.
3. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work..

Call Jenny Winslow 878-0678 for P/U

CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provisions of the code(s) applicable to such permit

Jenny Winslow 25
SIGNATURE OF APPLICANT
Jenny Winslow
Southpaw Design

ADDRESS: _____ DATE: 2/10/98 PHONE: _____

RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE _____ PHONE: _____

Historic Preservation
 Not in District or Landmark
 Does Not Require Review
 Requires Review

Action:
 Approved
 Approved with Conditions
 Denied

Date: _____

CEO DISTRICT


6" x 43" x 90"
ALUMINUM

1/2" letters

(5)
PANELS
8" x 43"

D.K. COBBEN

30" x 50"
x 72"



THIS DESIGN IS THE EXCLUSIVE PROPERTY OF SOUTHPAW DESIGN AND ALL RIGHTS TO ITS USE OR REPRODUCTION ARE RESERVED, UNTIL PURCHASED.

© COPYRIGHT

SOUTHPAW
DESIGN



207-878-0678 Fax 878-9325
253 Gray Road Falmouth, Me 04105

CUSTOMER *ADAM COBBEN*
 PHONE # *878-0678* TAX# *0788*

DATE *8-7-88*

ALL DRAWINGS ARE
ACTUAL SIZE.
PRINTED TO FIT THIS PAGE.



PRESENTATION
 CONSTRUCTION

ACCEPTED SIGNATURE

DRAWING # *Franklin.002*

1" x 4" x 8" NUM SIGN w/ PANELS

11



8

CREATIVE OFFICE
PAVILION

SIGNAGE

PLEASE ANSWER ALL QUESTIONS

ADDRESS: 15 FRANKLIN ST, PORT ZONE: B-3

OWNER: A+M PARTNERS

APPLICANT: JENNY WINSLOW, SOUTHPAW DESIGN

ASSESSOR NO.: _____

SINGLE TENANT LOT? YES _____ NO X

MULTI TENANT LOT? YES X NO _____

FREESTANDING SIGN? YES _____ NO X DIMENSIONS _____
(ex. pole sign..)

MORE THAN ONE SIGN? YES _____ NO X DIMENSIONS _____

BLDG. WALL SIGN? YES X NO _____ DIMENSIONS 4' x 8' #32
(attached to bldg)

MORE THAN ONE SIGN? YES _____ NO X DIMENSIONS _____

LIST ALL EXISTING SIGNAGE AND THEIR DIMENSIONS: NONE

LOT FRONTAGE (FEET) _____

BLDG FRONTAGE (FEET) 125' x 2 = 250'

AWNING YES _____ NO X IS AWNING BACKLIT? YES _____ NO X

HEIGHT OF AWNING: _____

IS THERE ANY COMMUNICATION, MESSAGE, TRADEMARK OR SYMBOL ON IT? NO

A SITE SKETCH AND BUILDING SKETCH SHOWING EXACTLY WHERE EXISTING AND NEW SIGNAGE IS LOCATED MUST BE PROVIDED. SKETCHES AND/OR PICTURES OF THE PROPOSED SIGNS ARE ALSO REQUIRED.

BUILDING PERMIT REPORT

DATE: 11 MAY 98 ADDRESS: 15 Franklin ST. (29-N-4)
REASON FOR PERMIT: TO erect sign
BUILDING OWNER: A & M Partners
CONTRACTOR: Southpan Design
PERMIT APPLICANT: Jenny Waslow
USE GROUP Sign BOCA 1996 CONSTRUCTION TYPE 513

CONDITION(S) OF APPROVAL

This Permit is being issued with the understanding that the following conditions are met:

Approved with the following conditions: *1, *2, *29

1. This permit does not excuse the applicant from meeting applicable State and Federal rules and laws.
2. Before concrete for foundation is placed, approvals from the Development Review Coordinator and Inspection Services must be obtained. (A 24 hour notice is required prior to inspection)
3. Precaution must be taken to protect concrete from freezing.
4. It is strongly recommended that a registered land surveyor check all foundation forms before concrete is placed. This is done to verify that the proper setbacks are maintained.
5. Private garages located beneath habitable rooms in occupancies in Use Group R-1, R-2, R-3 or I-1 shall be separated from adjacent interior spaces by fire partitions and floor/ceiling assembly which are constructed with not less than 1-hour fire resisting rating. Private garages attached side-by-side to rooms in the above occupancies shall be completely separated from the interior spaces and the attic area by means of ½ inch gypsum board or the equivalent applied to the garage means of ½ inch gypsum board or the equivalent applied to the garage side. (Chapter 4 Section 407.0 of the BOCA/1996)
6. All chimneys and vents shall be installed and maintained as per Chapter 12 of the City's Mechanical Code. (The BOCA National Mechanical Code/1993).
7. Sound transmission control in residential building shall be done in accordance with Chapter 12 section 1214.0 of the city's building code.
8. Guardrails & Handrails: A guardrail system is a system of building components located near the open sides of elevated walking surfaces for the purpose of minimizing the possibility of an accidental fall from the walking surface to the lower level. Minimum height all Use Groups 42", except Use Group R which is 36". In occupancies in Use Group A, B, H-4, I-1, I-2 M and R and public garages and open parking structures, open guards shall have balusters or be of solid material such that a sphere with a diameter of 4" cannot pass through any opening. Guards shall not have an ornamental pattern that would provide a ladder effect. (Handrails shall be a minimum of 34" but not more than 38". Use Group R-3 shall not be less than 30", but not more than 38".) Handrail grip size shall have a circular cross section with an outside diameter of at least 1 1/4" and not greater than 2".
9. Headroom in habitable space is a minimum of 7'6".
10. Stair construction in Use Group R-3 & R-4 is a minimum of 10" tread and 7 3/4" maximum rise. All other Use group minimum 11" tread. 7" maximum rise.
11. The minimum headroom in all parts of a stairway shall not be less than 80 inches. (6' 8")
12. Every sleeping room below the fourth story in buildings of use Groups R and I-1 shall have at least one operable window or exterior door approved for emergency egress or rescue. The units must be operable from the inside without the use of special knowledge or separate tools. Where windows are provided as means of egress or rescue they shall have a sill height not more than 44 inches (1118mm) above the floor. All egress or rescue windows from sleeping rooms shall have a minimum net clear opening height dimension of 24 inches (610mm). The minimum net clear opening width dimension shall be 20 inches (508mm), and a minimum net clear opening of 5.7 sq. ft.
13. Each apartment shall have access to two (2) separate, remote and approved means of egress. A single exit is acceptable when it exits directly from the apartment to the building exterior with no communications to other apartment units.
14. All vertical openings shall be enclosed with construction having a fire rating of at least one (1) hour, including fire doors with self closer's. (Over 3 stories in height requirements for fire rating is two (2) hours.)
15. The boiler shall be protected by enclosing with (1) hour fire-rated construction including fire doors and ceiling, or by providing automatic extinguishment.
16. All single and multiple station smoke detectors shall be of an approved type and shall be installed in accordance with the