

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that

SALT OF THE EARTH INC

Located at

5 COMMERCIAL ST (Space B)

PERMIT ID: 2014-01079

ISSUE DATE: 06/27/2014

CBL: 029 N024001

has permission to **Construct an enclosed deli-butcher area in existing retail space** provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Craig Messinger

/s/ Jeanie Bourke

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning

coffee shop - Crema (Space A - more than 9 seats) & retail grocery store - Rosemont Produce (Space B)

Building Inspections

Use Group: M **Type:** 5B
Mercantile - Rosemont Produce/Deli
Occupant Load - 38
NFPA 13 Sprinkler (required)
Space B
MUBEC/IBC 2009

Fire Department

Classification:
Class C Mercantile
ENTIRE

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703 (ONLY)
or email: buildinginspections@portlandmaine.gov

**Check the Status or Schedule an Inspection On-Line at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.**

REQUIRED INSPECTIONS:

Framing Only

Electrical Close-in

Final - Commercial

Final - Electric

Final - Fire

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit		Permit No: 2014-01079	Date Applied For: 05/20/2014	CBL: 029 N024001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Same - Retail grocery store		Proposed Project Description: Construct an enclosed deli-butcher area in existing retail space		
Dept: Historic		Status: Approved w/Conditions	Reviewer: Deb Andrews	Approval Date: 05/27/2014
Note:		Ok to Issue: <input checked="" type="checkbox"/>		
Conditions:		1) Approved with the understanding that project entails no exterior alterations. Any exterior alterations associated with project require review and approval.		
Dept: Zoning		Status: Approved w/Conditions	Reviewer: Ann Machado	Approval Date: 05/27/2014
Note:		Ok to Issue: <input checked="" type="checkbox"/>		
Conditions:		1) ANY exterior work requires a separate review and approval thru Historic Preservation. This property is located within an Historic District.		
Dept: Building		Status: Approved w/Conditions	Reviewer: Jeanie Bourke	Approval Date: 06/27/2014
Note:		Ok to Issue: <input checked="" type="checkbox"/>		
Conditions:		1) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems and fuel tanks. Separate plans may need to be submitted for approval as a part of this process. 2) Approval is subject to compliance with City and State Food Codes per the Portland Public Health Dept. It is strongly advised to contact the Health Inspector for approval of kitchen design compliance prior to commencing work in earnest. 3) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.		
Dept: Fire		Status: Approved w/Conditions	Reviewer: Craig Messinger	Approval Date: 06/03/2014
Note:		Ok to Issue: <input checked="" type="checkbox"/>		
Conditions:		1) All outstanding code violations shall be corrected prior to final inspection. 2) All means of egress to remain accessible at all times. 3) Emergency lights and exit signs are required. Emergency lights and exit signs are required to be labeled in relation to the panel and circuit and on the same circuit as the lighting for the area they serve 4) All construction shall comply with City Code Chapter 10. 5) Shall comply with NFPA 101, Chapter, Existing Mercantile Occupancies.		