

Benjamin Wallace - 9 Commercial St Fire Alarm Permit 2011-12-2947

From: Benjamin Wallace
To: dan@cascobayelectric.com
Date: 12/22/2011 11:09 AM
Subject: 9 Commercial St Fire Alarm Permit 2011-12-2947
CC: Chris Pirone; Gayle Guertin; Lannie Dobson; Tammy Munson; will@benne...
Attachments: Benjamin Wallace.vcf

Good morning,

I tried calling the number listed on the application but there was no answer and no answering machine. Unfortunately I can not approve this permit for a commercial fire alarm system as submitted for the following reasons:

Wrong application form (see <http://www.portlandmaine.gov/fireprevention/firealarmpermit.pdf> for the correct form),
No certificate of fitness,
No documentation provided,
No electrical permit attached to the fire alarm permit.

If you would like to provide the information required please drop of the completed submittal with the correct application form to the Building Inspections Office at City Hall. A certificate of fitness will be required and verified before the application can be accepted.

Thank you,

Lt. Benjamin Wallace Jr.
Fire Prevention Officer
Portland Fire Department
380 Congress Street
Portland, Maine 04101
(207)874-8400
wallaceb@portlandmaine.gov