


CITY OF PORTLAND
 FIRE PREVENTION BUREAU
 380 Congress Street, Portland, Maine 04101
 fireprevention@portlandmaine.gov
 (207) 874-8400



NOTICE OF VIOLATION AND ORDER TO CORRECT

July 6, 2017

| | | |
|---|---|-------------------------------------|
| Responsible Party 1: SALT OF THE EARTH INC 9 COMMERCIAL ST PORTLAND, ME 04101 | | |
| Location 5 COMMERCIAL ST | CBL 029 N024001 | Inspection Date 6/13/2017 |
| Inspector Robert Mcpartlan | Inspection Type FP Routine Inspection | Status Failed |

The City of Portland Fire Department inspected this property, and found the fire and life safety code violations listed below, which you are hereby ordered to correct. You must propose a date of completion to remedy each violation, a final date of completion, and a date of re-inspection.

You must send this form to the Fire Prevention Bureau no later than 7/30/2017.

Your failure to submit a plan of action by the date provided, or to correct any violation within the applicable time frame, may result in legal action against you, the imposition of civil penalties, and the pursuit of other legal remedies.

| Violation | Proposed Date of Completion |
|---|-----------------------------|
| NFPA 10- 6.1.3.4 FIRE EXTINGUISHER REQUIRES MOUNTING; Portable fire extinguishers other than wheeled extinguishers shall be installed using any of the following means: (1) Securely on a hanger intended for the extinguisher (2) In the bracket supplied by the extinguisher manufacturer (3) In a listed bracket approved for such purpose (4) In cabinets or wall recesses The extinguishers in both the coffee shop and the market need to be mounted on the wall. The coffee shop has 2 located by the back door. The market had one located in the kitchen at the back of the buisness | |
| FINAL DATE OF COMPLETED VIOLATION(S) | 7/13/17 |
| FIRE PREVENTION BUREAU RE-INSPECTION OF COMPLETED VIOLATION(S) | _/_/_ |

The Bureau reserves the right to reject or modify any proposed plan of action, and may require evidence of sufficient financial and technical capacity to complete the proposed plan. Please contact the Bureau with any questions.

VIOLATOR CERTIFICATION

I agree to remedy the violations listed within the timeframes provided. If I require additional time to comply, I understand that I must contact the Fire Prevention Bureau prior to the deadline to request an extension, which is entirely within the Bureau's discretion to grant or deny.

I further understand that it is my responsibility to schedule a reinspection of my property once the violations have been remedied to do so. My failure to schedule a reinspection shall be deemed an admission that the violations have not been remedied.

If I fail to comply with this agreement, I understand that I am liable for penalties pursuant to the City of Portland Code of Ordinances §§ 1-15 and 10-25, and 30-A M.R.S. § 4452 and may be subject to further legal action.

7/18/17
Date

Catherine Walsh
Responsible Party

Date

Responsible Party

SEEN AND AGREED

7/20/17
Date

Katherine Cahoon for FFB
Fire Prevention Bureau