

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that
PEAK 5 EQUITIES LLC

Located at
99 SILVER ST

PERMIT ID: 2016-00350 ISSUE DATE: 05/04/2016 CBL: 029 0001502

has permission to **Change of Use from a barber shop to an art gallery. Create openings in wall between existing gallery and former barber shop to join spaces.**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Craig Messinger

/s/ Laurie Leader

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning

retail art gallery

Building Inspections

Use Group: A-3 Type: 3B

Art gallery
Occupant load = 104
FIRST FLOOR
MUBEC/IBC 2009

Fire Department

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703 (ONLY)
or email: buildinginspections@portlandmaine.gov

**Check the Status or Schedule an Inspection On-Line at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.**

REQUIRED INSPECTIONS:

Close-in Plumbing/Framing

Electrical Close-in

Certificate of Occupancy/Final

Final - Electric

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit		Permit No: 2016-00350	Date Applied For: 02/17/2016	CBL: 029 0001502
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Art Gallery (Unit 502) ("Art Collector Maine LLC")		Proposed Project Description: Change of Use from a barber shop to an art gallery. Create opening in wall between existing gallery and former barber shop to join spaces.		
Dept: Historic	Status: Approved w/Conditions	Reviewer: Robert Wiener	Approval Date: 03/24/2016	Ok to Issue: <input checked="" type="checkbox"/>
Note:				
Conditions:				
1) Any changes to exterior signage, lighting, doors, windows, ventilation, etc. must be reviewed and approved separately, prior to construction.				
2) No exterior alterations are included with this permit approval.				
Dept: Zoning	Status: Approved w/Conditions	Reviewer: Christina Stacey	Approval Date: 03/04/2016	Ok to Issue: <input checked="" type="checkbox"/>
Note: B-3 zone, PAD Change of use in B-3 - no parking required				
Conditions:				
1) This property is located in the Pedestrian Activities District (PAD) which regulates first floor uses to retail -like and other uses as listed in section 14-217(b)(1). The front windows shall not be blocked or have curtains that block out visibility from the sidewalk. Your use shall not change without review and approval PRIOR to implementation				
2) Separate permits shall be required for any new signage.				
3) This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work.				
Dept: Building Inspecti	Status: Approved w/Conditions	Reviewer: Laurie Leader	Approval Date: 04/27/2016	Ok to Issue: <input checked="" type="checkbox"/>
Note:				
Conditions:				
1) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems, fire suppression and fuel tanks. Separate plans may need to be submitted for approval as a part of this process.				
2) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.				
Dept: Engineering DPS	Status: Not Applicable	Reviewer: Rachel Smith	Approval Date: 02/23/2016	Ok to Issue: <input checked="" type="checkbox"/>
Note:				
Conditions:				
1) This approval is non-applicable to Engineering DPS as it relates to approval for Grease Control Equipment for the Fats, Oil, and Grease Program. If approval is needed for this project by the Engineering Department of Public Services for any other reason than FOG, please contact David Margolis-Pineo at 207-874-8850 or dmp@portlandmaine.gov				
Dept: Fire	Status: Approved w/Conditions	Reviewer: Craig Messenger	Approval Date: 03/23/2016	Ok to Issue: <input checked="" type="checkbox"/>
Note:				
Conditions:				
1) Two separate means of egress shall be required per NFPA 101.				
2) Shall comply with NFPA 101, Chapter 37, Existing Mercantile Occupancies.				
3) Emergency lights and exit signs are required. Emergency lights and exit signs are required to be labeled in relation to the panel and circuit and on the same circuit as the lighting for the area they serve.				
4) Shall meet the requirements of 2009 NFPA 1 Fire Code.				

PERMIT ID: 2016-00350

Located at: 99 SILVER ST

CBL: 029 0001502

5) All construction shall comply with City Code Chapter 10.