

1 ELECTRICAL DEMOLITION PLAN — ROOF PLAN
SCALE: 1/8"=1'-0"

NOTES:

1. SEE E0.0 FOR LEGEND, ABBREVIATIONS AND GENERAL NOTES.


KEYED NOTES:

- ① REMOVE ELECTRICAL DISCONNECT, WIRING AND CONDUIT OF ROOFTOP MECHANICAL EQUIPMENT BACK TO POWER PANEL. RETAIN CONDUIT STUBS THROUGH ROOF AND ANY FIRE ALARM CONDUITS FOR FUTURE EQUIPMENT. REMOVE ANY ASSOCIATED DUCT SMOKE DETECTORS AND COORDINATE WITH FIRE ALARM PANEL SERVICE CONTACT: CUNNINGHAM SECURITY SYSTEMS, PHONE (207)-846-3350.
- ② SATELLITE DISH. DETERMINE SOURCE OF OWNERSHIP AND DEMOLISH ACCORDINGLY.
- ③ KEEP POWER FEED TO EXISTING SIGNAGE LOCATION. DISCONNECT AT POWER PANEL AND LABEL FOR RE-USE FOR NEW SIGNAGE.



PORT CITY ARCHITECTURE

65 NEWBURY STREET
PORTLAND, ME 04101
207.761.9000



Consultants:

Swiftcurrent Engineering Services, Inc.
10 Forest Falls Dr. - Unit 4B
Yarmouth, ME 04096
(207) 847-9280
contact: Timothy D. Matthews, P.E.
tim@swiftcurrenteng.com

PERMIT SET
NOT FOR CONSTRUCTION

NEWPORT DEVELOPMENT ASSOCIATES

164 Middle St
Portland, Maine

| # | DATE | DESCRIPTION |
|---|------|-------------|
| | | |
| | | |
| | | |
| | | |
| | | |

Date Issued September 9th, 2016
Project Number 16202
Drawing Scale AS NOTED

ELECTRICAL DEMOLITION PLAN - ROOF

Drawn By JMD
Checked By TDM

ED1.4