<u>LIGHTING SCHEDULE</u>							
TYPE	DESCRIPTION	MANFACTURER	LAMPS	MOUNTING	NOTES		
А	4' LED WRAP AROUND	COLUMBIA LIGHTING	48W LED 3500K 4700 LUMENS	CEILING SURFACE	MODEL #: LAW4-35ML-EU		
В	2' LED WRAPAROUND	COLUMBIA LIGHTING	25W LED 3500K 2600 LUMENS	CEILING SURFACE	MODEL #: LAW2-35LW-EU		
С	VAPOR-TIGHT ELEVATOR PIT FIXTURE 120V	HUBBELL LIGHTING	11W LED 4100K 757 LUMENS	WALL SURFACE	MODEL #: VWGL-1		
D	4" LED RECESSED DOWNLIGHT 120V	COOPER LIGHTING	22.4W LED 3500K 1300 LUMENS	CEILING RECESSED	MODEL #: LD4A-13-D010TE-ERM4A-13-835-4LM1-H-WF		
D2	4" LED RECESSED DOWNLIGHT WITH EMERGENCY MODULE AND REMOTE TEST SWITCH.	COOPER LIGHTING	22.4W LED 3500K 1300 LUMENS	CEILING RECESSED	MODEL #: LD4A-13-D010TE-EMBOD-ERM4A- 13-835-4LM1-H-WF		
E	LED SIGN LIGHT. WITH WIDE BEAM AND 24" STEM LENGTH.	COOPER LIGHTING	10W LED 3000K 245 LUMENS	WALL MOUNTED	MODEL #: 922-10LED3041-12-BK-SA24 FURNISH REMOTE 12V TRANSFORMER		
F	LED WALL PACK. BRONZE FINISH.	LUMARK LIGHTING	18W LED 3500K 1633 LUMENS	WALL SURFACE	MODEL #: XTOR2A		
⇔ c	€ELING MOUNTED DUAL TECHNOLOGY UTRASONIC AND PASSIVE INFRARED OCCUPANCY SENSOR	HUBBELL	N/A	CEILING SURFACE	MODEL #: OMNIDT500 FURNISH RELAYS/POWER PACKS AS REQUIRED FOR A COMPLETE AND OPERABLE INSTALLATION		
→w	WALL MOUNT PASSIVE INFRARED OCCUPANCY SENSOR 120V	HUBBELL	N/A	WALL	MODEL #: LHIRS11		
1	EMERGENCY BATTERY UNIT 120V	DUAL-LITE	2W LED	WALL SURFACE	MODEL #: EV4D-02L		
WP	WEATHER PROOF REMOTE HEAD. WHITE FINISH.	DUAL-LITE	(2) 1W LED	WALL SURFACE	MODEL #: EVO-D-W		
	LED EXIT SIGN EMERGENCY BATTERY UNIT COMBINATION WITH REMOTE CAPACITY 120V	DUAL-LITE	(2) 1W LED	CEILING SURFACE	MODEL #: EVCU-R-W-D4		
	LED EXIT SIGN EMERGENCY BATTERY UNIT 120V	DUAL-LITE	2W LED	CEILING SURFACE	MODEL #: EVEU-R-W		

LIGHTING SCHEDULE

NOTES:


1. SEE EO.O FOR LEGEND, ABBREVIATIONS AND GENERAL NOTES.

KEYED NOTES:

CONTRACTOR TO FURNISH AES WIRELES TRANSMITTER MODEL 7788, 12V/ 7AH STANDBY BATTERY, 1640 PLUG-IN TRANSFORMER. SENTROL TAMPER SWITCH TO ALLOW SERVICING WITHOUT SENDING SYSTEM INTO ALARM. SYSTEM COORDINATE WITH DICK ANDREWS, PORTLAND FIRE DEPARTMENT.



65 NEWBURY STREET PORTLAND, ME 04101 207.761.9000



<u>Consultants:</u>

Swiftcurrent Engineering Services, Inc.

10 Forest Falls Dr. — Unit 4B
Yarmouth, ME 04096
(207) 847—9280 contact Timothy D. Matthews, P.E. tim@swiftcurrenteng.com

PERMIT SET 11-1-16

NOT FOR CONSTRUCTION

NEWPORT DEVELOPMENT ASSOCIATES

164 Middle St Portland, Maine

# DATE	DESCRIPTION				
I					
Date Issued	October 26th, 2016				

Project Number AS NOTED

ELECTRICAL LIGHTING SCHEDULE & FIRE ALARM RISER DIAGRAM

Drawn By

E1.5 Checked By

CM FIREMAN'S HAT				
CM ALT FLOOR RECALL				
CM PRI FLOOR RECALL				
STOR. RETAIL STAIR 100 FLOOR 202 201 BELEVATOR ELEVATOR MACH. RM. SHAFT PIT				
FURNISH ALL SPRINKLER SYSTEM SWITCHES AS REQUIRED BY				
COORDINATE LOCATION OF ELECTRIC BELL AND RED LIGHT WITH FIRE DEPT. PRIOR TO PLACEMENT. SPRINKLER SYSTEM DESIGNER PS TS FS MM	15 110 110 110 110 15 110			
HVAC-1 MOTOR STOP SUPERVISORY SUPPLY STARTER RTI	FIRE 110 110 110 15 15 75 75 110 75 75			
A CO	TIRE			
HVAC-3 MOTOR STOP SUPERVISORY SUPPLY STARTER D				
HVAC-4 MOTOR STOP SUPERVISORY STARTER D				
HVAC-5 MOTOR STOP SUPERVISORY SUPPLY STARTER D				
WIRELESS FT TRANSMITTER				
FURNISH (2) PHONE LINES FOR ALARM	F S HALLWAY TENANT ABOVE 103 104 FACP			
REMOTE ANN ANNUNCIATOR ENTRY 200				
	→ 120V			

PANEL

CM SHUNT TRIP

FIRE ALARM RISER DIAGRAM

7

7

, y

0 1' 2' | Liii | Liii | Lii | SCALE

 ∞

COPYRIGHT: Reuse or reproduction of the contents of this document is not permitted without written permission of PORT CITY ARCHITECTURE PA