

**Silent Knight Addressable Fire Alarm System Addition  
West Elm  
Portland, Maine**

**System Narrative**

**In the event of an alarm from an actuated device, the following shall**

**occur:** (Devices reporting as alarm: Manual Station, Smoke Detector, Heat Detector, and Sprinkler Waterflow,)

- 1) Notify Portland Fire Department via Radio Master Box
- 2) Activate all horn circuits
- 3) Flash all strobe appliance circuits in a synchronized manner
- 4) Annunciate audibly, visually, and in plain English the active initiating device at the Fire Alarm Control Panel
- 5) If smoke detector is designated an elevator device, activate relays for elevator recall
- 6) If heat detector is designated an elevator device, activate relays for elevator shunt (existing)

**In the event of a supervisory condition from an actuated device, the following shall occur:** (Devices reporting as supervisory: Sprinkler Tamper Switches)

- 1) Annunciate audibly, visually, and in plain English the active initiating device at the Fire Alarm Control Panel

**In the event of a system trouble report, the following shall occur:**

- 1) Annunciate audibly, visually, and in plain English the active initiating device at the Fire Alarm Control Panel