

## \* W A L L T Y P E S \*



## W1 TYPICAL INTERIOR PARTITION

- 1. **Gypsum Board** -- 5/8 in. Type "X" GWB, 4 ft wide, attached to studs with Type S-12 steel screws spaced 8 in. OC. along edges of board and 12 in. OC in the field of the board. Joints oriented vertically and stagged on opposite sides of the assembly 48 in. OC.
- **Metal Studs** -- 6 in. 20 guage metal studs spaced 16 in. OC. **Insulation** -- 6 in. Fiberglass batt insulation friction fit in stud space.
- Joint Tape and Compound -- Vinyl, dry or premixed joint compound, applied in two coats to joints and screw heads; paper tape, 2 in. wide, embedded in first layer of compound over all joints. As an alternate, nominal 3/32 in. thick gypsum veneer plaster may be applied to the entire surface of Classified veneer baseboard. Joints reinforced.
- 5. Walls to go to bottom of deck



145 COMMERCIAL