

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that

FLEMING CREEK LLC ETALS

Located at

145 COMMERCIAL ST

PERMIT ID: 2016-02226

ISSUE DATE: 09/23/2016

CBL: 029 S001001

has permission to **Temporary banner 4' by 8' for People's United Bank (above Edgecomb Potters)** provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

N/A

/s/ Laurie Leader

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning

retail bank

Building Inspections

Use Group: NA **Type:**
Temporary Banner
ENTIRE
MUBEC/IBC 2009

Fire Department

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703 (ONLY)
or email: buildinginspections@portlandmaine.gov

**Check the Status or Schedule an Inspection On-Line at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the City of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that are attached to this permit! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases 6 months.**
- **If the inspection requirements are not followed as stated below, additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**

REQUIRED INSPECTIONS:

Final - Commercial

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit		Permit No: 2016-02226	Date Applied For: 08/19/2016	CBL: 029 S001001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Same: Bank & Banking Offices ("People's United Bank")		Proposed Project Description: Temporary banner 4' by 8' for People's United Bank (above Edgecomb Potters)		
Dept: Historic	Status: Approved	Reviewer: Robert Wiener	Approval Date: 09/21/2016	Ok to Issue: <input checked="" type="checkbox"/>
Note:				
Conditions:				
Dept: Zoning	Status: Approved w/Conditions	Reviewer: Christina Stacey	Approval Date: 09/20/2016	Ok to Issue: <input checked="" type="checkbox"/>
Note: 4' by 8' temp banner - OK				
Conditions:				
1) The temporary banner must be removed 30 days after installation.				
2) This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work.				
Dept: Building Inspecti	Status: Approved w/Conditions	Reviewer: Laurie Leader	Approval Date: 09/21/2016	Ok to Issue: <input checked="" type="checkbox"/>
Note:				
Conditions:				
1) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.				
2) Signage and Awning Installation to comply with Chapters 16 (Structural Loads), 31 (Materials) & 32 (ROW Height & Encroachments) of the IBC 2009 building code.				