

389 Congress St.Rm 315  
Portland, ME 04101  
Phone: (207)874-8700  
Fax: (207)874-8716

facsimile transmittal

**To:** Peter & Kathleen McAleney      **From:** Mike Nugent  
**Fax:** 874-2456      **Date:** August 6, 2002  
**Phone:** 775-1612      **Pages:** 1  
**Re:** 60 Portland Pier (030 B004)      **CC:**

Urgent     For Review     Please Comment     Please Reply     Please Recycle

I have left a message for Mike Hayes to call, I have some questions on the plans:

- 1) Floor and roof load of the Exterior Covered Deck
- 2) The 2 hr. fire separation on page 4 of 5 is "Similar to" UL L536, is it a 2 hr rating or not.
- 3) The floor plan does not show a fire separation between the office and residential use.
- 4) Are the windows specified for the sleeping room in compliance with egress standards.
- 5) Are there elevations available?

