



... Fire Protection by Computer Design

SPRINKLER SYSTEMS INC.
4 AVON STREET
P O BOX 1285
LEWISTON, ME. 04243
207-782-0104

Job Name : 100 Commercial Street Dry Systems Area 1
Building : Existing
Location : 100 Commercial Street Portland, Maine
System : 2 Dry
Contract : 15-095
Data File : 100 Commercial Street Dry System Area 1.WXF

Hydraulic Design Information Sheet

Name - 100 Commercial Street Date - 11-16-15
 Location - 100 Commercial Street Portland, Maine
 Building - Existing System No. - 2 Dry
 Contractor - Sprinkler Systems Inc. Contract No. - 15-095
 Calculated By - CDS Drawing No. - 1-3 of 3
 Construction: (X) Combustible () Non-Combustible Ceiling Height - varies
 Occupancy - Office Building

S (X) NFPA 13 () Lt. Haz. Ord.Haz.Gp. (X) 1 () 2 () 3 () Ex.Haz.
 Y () NFPA 231 () NFPA 231C () Figure Curve

S Other

T Specific Ruling Made By Date

E				
M	Area of Sprinkler Operation	- 1950	System Type	Sprinkler/Nozzle
	Density	- .15	() Wet	Make Reliable
D	Area Per Sprinkler	- 130	(X) Dry	Model F1FR56
E	Elevation at Highest Outlet	- 105.500	() Deluge	Size 1/2" x 1/2"
S	Hose Allowance - Inside	- 0	() Preaction	K-Factor 5.6
I	Rack Sprinkler Allowance	- 0	() Other	Temp.Rat.200 Deg.
G	Hose Allowance - Outside	- 250		

N Note

Calculation Flow Required - 360.26 Press Required - 65.618 AT BASE
 Summary C-Factor Used: 120 Overhead 140 Underground

W	Water Flow Test:	Pump Data:	Tank or Reservoir:
A	Date of Test - 10-06-15		Cap. -
T	Time of Test - AM	Rated Cap.-	Elev.-
E	Static Press - 110	@ Press -	
R	Residual Press - 48	Elev. -	Well
	Flow - 1162		Proof Flow
S	Elevation - 100.0'		

U Location - ON SITE

P Source of Information - OWNER AND WATER DISTRICT

C	Commodity	Class	Location
O	Storage Ht.	Area	Aisle W.
M	Storage Method:	%	Palletized % Rack
	() Single Row	() Conven. Pallet	() Auto. Storage () Encap.
S	() Double Row	() Slave Pallet	() Solid Shelf () Non
T	() Mult. Row		() Open Shelf

R K Flue Spacing Clearance:Storage to Ceiling
 A Longitudinal Transverse

E Horizontal Barriers Provided:

Fittings Used Summary

SPRINKLER SYSTEMS INC.
100 Commercial Street Dry Systems Area 1

Page 2
Date

Fitting Legend		1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
Abbrev.	Name																				
Bvcb	B Fly Vic 705W	0	0	0	0	0	0	5	5	0	12	12	8	11	12	14	0	0	0	0	0
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121

Units Summary

Diameter Units Inches
Length Units Feet
Flow Units US Gallons per Minute
Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Pressure / Flow Summary - STANDARD

SPRINKLER SYSTEMS INC.
100 Commercial Street Dry Systems Area 1

Page 3
Date

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
TYP	0.0	5.6	12.13	na	19.5	0.15	130	7.0
ARM1	105.5	5.6	22.92	na	26.81	0.15	130	7.0
119	105.5	5.6	22.08	na	26.31	0.15	130	7.0
118	105.5	5.6	21.98	na	26.26	0.15	130	7.0
116	105.5	5.6	21.82	na	26.16	0.15	130	7.0
115	105.5	5.6	21.73	na	26.1	0.15	130	7.0
117	105.5		24.71	na				
120	105.5		25.0	na				
107	105.5	K = K @ SPRG	15.37	na	19.55			
108	105.5	K = K @ SPRG	15.51	na	19.64			
109	105.5	K = K @ SPRG	16.01	na	19.95			
110	105.5	K = K @ SPRG	17.08	na	20.61			
111	105.5	K = K @ SPRG	18.93	na	21.7			
101	105.5	K = K @ SPRG	15.29	na	19.5			
102	105.5	K = K @ SPRG	15.43	na	19.59			
103	105.5	K = K @ SPRG	15.92	na	19.9			
104	105.5	K = K @ SPRG	16.99	na	20.55			
105	105.5	K = K @ SPRG	18.83	na	21.64			
106	105.5		23.0	na				
112	105.5		23.12	na				
114	105.5		25.6	na				
121	105.5		26.69	na				
122	105.5	K = K @ SPRG	27.2	na	26.0			
123	105.5		35.22	na				
124	105.5		45.63	na				
125	105.5		49.04	na				
TDR	105.5		52.63	na				
BDR	101.5		59.58	na				
BWR	101.5		59.67	na				
BKFL	101.5		59.76	na				
BASE	100.0		65.62	na				
HOSE	100.0		66.05	na	250.0			
TEST	100.0		67.18	na				

The maximum velocity is 14.65 and it occurs in the pipe between nodes 111 and 112

Final Calculations - Hazen-Williams

SPRINKLER SYSTEMS INC.
100 Commercial Street Dry Systems Area 1

Page 4
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
TYP to SPRG	19.50 19.5	1.049 120.0 0.1242	T EqL	5.0 19.0 0.0	1.500 24.000 25.500	12.125 0.0 3.167		K Factor = 5.60 Vel = 7.24	
	0.0 19.50					15.292		K Factor = 4.99	
ARM1 to 114	26.81 26.81	1.049 120.0 0.2238	E T	2.0 5.0 0.0	5.000 7.000 12.000	22.915 0.0 2.685		K Factor = 5.60 Vel = 9.95	
	0.0 26.81					25.600		K Factor = 5.30	
119 to 120	26.31 26.31	1.049 120.0 0.2161	E T	2.0 5.0 0.0	6.500 7.000 13.500	22.078 0.0 2.918		K Factor = 5.60 Vel = 9.77	
	0.0 26.31					24.996		K Factor = 5.26	
118 to 120	26.26 26.26	1.049 120.0 0.2153	E T	2.0 5.0 0.0	7.000 7.000 14.000	21.982 0.0 3.014		K Factor = 5.60 Vel = 9.75	
	0.0 26.26					24.996		K Factor = 5.25	
116 to 117	26.16 26.16	1.049 120.0 0.2138	E T	2.0 5.0 0.0	6.500 7.000 13.500	21.822 0.0 2.886		K Factor = 5.60 Vel = 9.71	
	0.0 26.16					24.708		K Factor = 5.26	
115 to 117	26.10 26.1	1.049 120.0 0.2129	E T	2.0 5.0 0.0	7.000 7.000 14.000	21.727 0.0 2.981		K Factor = 5.60 Vel = 9.69	
117 to 120	26.16 52.26	2.157 120.0 0.0230		0.0 0.0 0.0	12.500 0.0 12.500	24.708 0.0 0.288		Vel = 4.59	
120 to 121	52.57 104.83	2.157 120.0 0.0833	T	12.307 0.0 0.0	8.000 12.307 20.307	24.996 0.0 1.692		Vel = 9.20	
	0.0 104.83					26.688		K Factor = 20.29	
107 to 108	19.55 19.55	1.682 120.0 0.0125		0.0 0.0 0.0	11.000 0.0 11.000	15.372 0.0 0.138		K Factor @ node SPRG Vel = 2.82	
108 to 109	19.64 39.19	1.682 120.0 0.0453		0.0 0.0 0.0	11.000 0.0 11.000	15.510 0.0 0.498		K Factor @ node SPRG Vel = 5.66	
109 to 110	19.95 59.14	1.682 120.0 0.0971		0.0 0.0 0.0	11.000 0.0 11.000	16.008 0.0 1.068		K Factor @ node SPRG Vel = 8.54	

Final Calculations - Hazen-Williams

SPRINKLER SYSTEMS INC.
100 Commercial Street Dry Systems Area 1

Page 5
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
110 to 111	20.61 79.75	1.682 120.0 0.1686		0.0 0.0 0.0	11.000 0.0 11.000	17.076 0.0 1.855		K Factor @ node SPRG		Vel = 11.52
111 to 112	21.69 101.44	1.682 120.0 0.2633	T	9.9 0.0 0.0	6.000 9.900 15.900	18.931 0.0 4.186		K Factor @ node SPRG		Vel = 14.65
	0.0 101.44					23.117		K Factor = 21.10		
101 to 102	19.50 19.5	1.682 120.0 0.0125		0.0 0.0 0.0	11.000 0.0 11.000	15.292 0.0 0.137		K Factor @ node SPRG		Vel = 2.82
102 to 103	19.59 39.09	1.682 120.0 0.0451		0.0 0.0 0.0	11.000 0.0 11.000	15.429 0.0 0.496		K Factor @ node SPRG		Vel = 5.64
103 to 104	19.90 58.99	1.682 120.0 0.0965		0.0 0.0 0.0	11.000 0.0 11.000	15.925 0.0 1.062		K Factor @ node SPRG		Vel = 8.52
104 to 105	20.55 79.54	1.682 120.0 0.1679		0.0 0.0 0.0	11.000 0.0 11.000	16.987 0.0 1.847		K Factor @ node SPRG		Vel = 11.48
105 to 106	21.64 101.18	1.682 120.0 0.2619	T	9.9 0.0 0.0	6.000 9.900 15.900	18.834 0.0 4.165		K Factor @ node SPRG		Vel = 14.61
106 to 112	0.0 101.18	3.26 120.0 0.0105		0.0 0.0 0.0	11.250 0.0 11.250	22.999 0.0 0.118				Vel = 3.89
112 to 114	101.44 202.62	3.26 120.0 0.0377	2E	18.815 0.0 0.0	47.000 18.815 65.815	23.117 0.0 2.483				Vel = 7.79
114 to 121	26.81 229.43	3.26 120.0 0.0475	E	9.408 0.0 0.0	13.500 9.408 22.908	25.600 0.0 1.088				Vel = 8.82
121 to 122	104.83 334.26	3.26 120.0 0.0951		0.0 0.0 0.0	5.330 0.0 5.330	26.688 0.0 0.507				Vel = 12.85
122 to 123	26.00 360.26	3.26 120.0 0.1094	2T	40.319 0.0 0.0	33.000 40.319 73.319	27.195 0.0 8.021		K Factor @ node SPRG		Vel = 13.85
123 to 124	0.0 360.26	3.26 120.0 0.1094	T	20.159 0.0 0.0	75.000 20.159 95.159	35.216 0.0 10.411				Vel = 13.85
124 to 125	0.0 360.26	3.26 120.0 0.1094	T	20.159 0.0 0.0	11.000 20.159 31.159	45.627 0.0 3.409				Vel = 13.85
125 to TDR	0.0 360.26	3.26 120.0 0.1094	2E	18.815 0.0 0.0	14.000 18.815 32.815	49.036 0.0 3.590				Vel = 13.85

Final Calculations - Hazen-Williams

SPRINKLER SYSTEMS INC.
100 Commercial Street Dry Systems Area 1

Page 6
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
TDR	0.0	3.26	Bvcb	6.72	2.000	52.626			
to		120.0	T	20.159	45.694	1.732			
BDR	360.26	0.1094	Eq	18.815	47.694	5.219		Vel = 13.85	
BDR	0.0	4.26		0.0	3.000	59.577			
to		120.0		0.0	0.0	0.0			
BWR	360.26	0.0297		0.0	3.000	0.089		Vel = 8.11	
BWR	0.0	4.26		0.0	3.000	59.666			
to		120.0		0.0	0.0	0.0			
BKFL	360.26	0.0297		0.0	3.000	0.089		Vel = 8.11	
BKFL	0.0	4.026	3E	30.0	1.000	59.755			
to		120.0		0.0	30.000	4.650		** Fixed Loss = 4	
BASE	360.26	0.0391		0.0	31.000	1.213		Vel = 9.08	
BASE	0.0	6.16	G	4.304	50.000	65.618			
to		140.0	T	43.037	67.425	0.0			
HOSE	360.26	0.0037	E	20.084	117.425	0.436		Vel = 3.88	
HOSE	250.00	8.27		0.0	480.000	66.054		Qa = 250	
to		140.0		0.0	0.0	0.0			
TEST	610.26	0.0023		0.0	480.000	1.124		Vel = 3.64	
	0.0								
	610.26					67.178		K Factor = 74.46	

Water Supply Curve C

SPRINKLER SYSTEMS INC.
100 Commercial Street Dry Systems Area 1

Page 7
Date

City Water Supply:
C1 - Static Pressure : 110
C2 - Residual Pressure: 48
C2 - Residual Flow : 1162

Demand:
D1 - Elevation : 2.382
D2 - System Flow : 360.265
D2 - System Pressure : 67.178
Hose (Demand) : 250
D3 - System Demand : 610.265
Safety Margin : 23.986

