



... Fire Protection by Computer Design

SPRINKLER SYSTEMS INC.
4 AVON STREET
P O BOX 1285
LEWISTON, ME. 04243
207-782-0104

Job Name : 100 Commercial Street Wet Systems Area 1
Building : Existing
Location : 100 Commercial Street Portland, Maine
System : 1 Wet
Contract : 15-095
Data File : 100 Commercial Street Wet System Area 1.WXF

Hydraulic Design Information Sheet

Name - 100 Commercial Street Date - 11-16-15
 Location - 100 Commercial Street Portland, Maine
 Building - Existing System No. - 1 Wet
 Contractor - Sprinkler Systems Inc. Contract No. - 15-095
 Calculated By - CDS Drawing No. - 1-3 of 3
 Construction: (X) Combustible () Non-Combustible Ceiling Height - varies
 Occupancy - Office Building

S (X) NFPA 13 (X) Lt. Haz. Ord.Haz.Gp. () 1 () 2 () 3 () Ex.Haz.
 Y () NFPA 231 () NFPA 231C () Figure Curve

S Other

T Specific Ruling Made By Date

E				
M	Area of Sprinkler Operation	- 1950	System Type	Sprinkler/Nozzle
	Density	- .10	(X) Wet	Make Reliable
D	Area Per Sprinkler	- 168	() Dry	Model F1FR56
E	Elevation at Highest Outlet	- 151	() Deluge	Size 1/2" x 1/2"
S	Hose Allowance - Inside	- 0	() Preaction	K-Factor 5.6
I	Rack Sprinkler Allowance	- 0	() Other	Temp.Rat.200 Deg.
G	Hose Allowance - Outside	- 100		

N Note

Calculation Flow Required - 248.18 Press Required - 85.803 AT BASE
 Summary C-Factor Used: 120 Overhead 140 Underground

W	Water Flow Test:	Pump Data:	Tank or Reservoir:
A	Date of Test - 10-06-15		Cap. -
T	Time of Test - AM	Rated Cap.-	Elev.-
E	Static Press - 110	@ Press -	
R	Residual Press - 48	Elev. -	Well
	Flow - 1162		Proof Flow
S	Elevation - 100.0'		

U Location - ON SITE

P Source of Information - OWNER AND WATER DISTRICT

C	Commodity	Class	Location
O	Storage Ht.	Area	Aisle W.
M	Storage Method:	%	Palletized % Rack
	() Single Row	() Conven. Pallet	() Auto. Storage () Encap.
S	() Double Row	() Slave Pallet	() Solid Shelf () Non
T	() Mult. Row		() Open Shelf

R K Flue Spacing Clearance:Storage to Ceiling
 A Longitudinal Transverse

E Horizontal Barriers Provided:

Fittings Used Summary

SPRINKLER SYSTEMS INC.
100 Commercial Street Wet Systems Area 1

Page 2
Date

Fitting Legend		1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24	
Abbrev.	Name																					
Bvcb	B Fly Vic 705W	0	0	0	0	0	0	5	5	0	12	12	8	11	12	14	0	0	0	0	0	0
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61	
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																				
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13	
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65						
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121	

Units Summary

Diameter Units Inches
Length Units Feet
Flow Units US Gallons per Minute
Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Pressure / Flow Summary - STANDARD

SPRINKLER SYSTEMS INC.
100 Commercial Street Wet Systems Area 1

Page 3
Date

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
TYP	0.0	5.6	9.0	na	16.8	0.1	168	7.0
TYP1	0.0	5.6	9.0	na	16.8	0.1	168	7.0
15	151.0	K = K @ SPRG	12.37	na	17.39			
16	151.0	K = K @ SPRG	12.65	na	17.59			
17	151.0	K = K @ DROP	13.57	na	18.25			
10	151.0	K = K @ SPRG	12.15	na	17.24			
11	151.0	K = K @ SPRG	12.23	na	17.29			
12	151.0	K = K @ SPRG	12.76	na	17.67			
5	151.0	K = K @ SPRG	11.54	na	16.8			
6	151.0	K = K @ SPRG	11.6	na	16.84			
7	151.0	K = K @ DROP	11.88	na	17.08			
8	151.0	K = K @ DROP	12.54	na	17.54			
1	151.0	K = K @ DROP	13.2	na	18.0			
2	151.0	K = K @ DROP	13.41	na	18.14			
3	151.0		14.56	na				
4	151.0	K = K @ DROP	14.6	na	18.93			
9	151.0		14.61	na				
13	151.0		14.79	na				
14	151.0	K = K @ DROP	15.38	na	19.43			
18	151.0		15.46	na				
19	151.0		38.9	na				
A	151.0		51.47	na				
B	139.5		56.61	na				
C	128.5		61.94	na				
D	116.5		68.38	na				
E	116.5		69.24	na				
F	105.5		74.37	na				
TWR	105.5		75.11	na				
BWR	101.5		80.5	na				
BKFL	101.5		80.54	na				
BASE	100.0		85.8	na				
HOSE	100.0		86.02	na	100.0			
TEST	100.0		86.42	na				

The maximum velocity is 14.6 and it occurs in the pipe between nodes 18 and 19

Final Calculations - Hazen-Williams

SPRINKLER SYSTEMS INC.
100 Commercial Street Wet Systems Area 1

Page 4
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
TYP to SPRG	16.80 16.8	1.049 120.0 0.0943	E T Eq	2.0 5.0 19.0	1.000 26.000 27.000	9.000 0.0 2.545			K Factor = 5.60	
	0.0 16.80						11.545		K Factor = 4.94	
TYP1 to DROP	16.80 16.8	1.049 120.0 0.0943	E T Eq	2.0 5.0 19.0	0.500 26.000 26.500	9.000 0.0 2.498			K Factor = 5.60	
	0.0 16.80						11.498		K Factor = 4.95	
15 to 16	17.39 17.39	1.442 120.0 0.0213		0.0 0.0 0.0	13.500 0.0 13.500	12.366 0.0 0.288			K Factor @ node SPRG	
									Vel = 3.42	
16 to 17	17.59 34.98	1.442 120.0 0.0777		0.0 0.0 0.0	11.750 0.0 11.750	12.654 0.0 0.913			K Factor @ node SPRG	
									Vel = 6.87	
17 to 18	18.24 53.22	1.442 120.0 0.1689	T	7.432 0.0 0.0	3.750 7.432 11.182	13.567 0.0 1.889			K Factor @ node DROP	
	0.0 53.22						15.456		K Factor = 13.54	
10 to 11	17.24 17.24	1.442 120.0 0.0211		0.0 0.0 0.0	3.750 0.0 3.750	12.154 0.0 0.079			K Factor @ node SPRG	
									Vel = 3.39	
11 to 12	17.29 34.53	1.442 120.0 0.0759		0.0 0.0 0.0	7.000 0.0 7.000	12.233 0.0 0.531			K Factor @ node SPRG	
									Vel = 6.78	
12 to 13	17.67 52.2	1.442 120.0 0.1630	T	7.432 0.0 0.0	5.000 7.432 12.432	12.764 0.0 2.026			K Factor @ node SPRG	
	0.0 52.20						14.790		K Factor = 13.57	
5 to 6	16.80 16.8	1.682 120.0 0.0095		0.0 0.0 0.0	5.500 0.0 5.500	11.545 0.0 0.052			K Factor @ node SPRG	
									Vel = 2.43	
6 to 7	16.84 33.64	1.682 120.0 0.0342		0.0 0.0 0.0	8.250 0.0 8.250	11.597 0.0 0.282			K Factor @ node SPRG	
									Vel = 4.86	
7 to 8	17.07 50.71	1.682 120.0 0.0730		0.0 0.0 0.0	9.000 0.0 9.000	11.879 0.0 0.657			K Factor @ node DROP	
									Vel = 7.32	
8 to 9	17.55 68.26	1.682 120.0 0.1265	T	9.9 0.0 0.0	6.500 9.900 16.400	12.536 0.0 2.074			K Factor @ node DROP	
	0.0								Vel = 9.86	

Final Calculations - Hazen-Williams

SPRINKLER SYSTEMS INC.
100 Commercial Street Wet Systems Area 1

Page 5
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
	68.26				14.610			K Factor = 17.86	
1	18.00	1.442		9.000	13.202			K Factor @ node DROP	
to		120.0		0.0	0.0				
2	18.0	0.0228		9.000	0.205			Vel = 3.54	
2	18.14	1.442	T	7.432	6.500	13.407		K Factor @ node DROP	
to		120.0		0.0	7.432	0.0			
3	36.14	0.0825		0.0	13.932	1.150		Vel = 7.10	
3	0.0	2.635		0.0	8.750	14.557			
to		120.0		0.0	0.0	0.0			
4	36.14	0.0045		0.0	8.750	0.039		Vel = 2.13	
4	18.93	2.635		0.0	1.500	14.596		K Factor @ node DROP	
to		120.0		0.0	0.0	0.0			
9	55.07	0.0093		0.0	1.500	0.014		Vel = 3.24	
9	68.26	2.635		0.0	4.250	14.610			
to		120.0		0.0	0.0	0.0			
13	123.33	0.0424		0.0	4.250	0.180		Vel = 7.26	
13	52.19	2.635		0.0	7.250	14.790			
to		120.0		0.0	0.0	0.0			
14	175.52	0.0817		0.0	7.250	0.592		Vel = 10.33	
14	19.44	2.635		0.0	0.750	15.382		K Factor @ node DROP	
to		120.0		0.0	0.0	0.0			
18	194.96	0.0987		0.0	0.750	0.074		Vel = 11.47	
18	53.22	2.635	T	16.474	135.000	15.456			
to		120.0		0.0	16.474	0.0			
19	248.18	0.1548		0.0	151.474	23.448		Vel = 14.60	
19	0.0	2.635	E	8.237	11.000	38.904			
to		120.0	T	16.474	50.795	3.000		** Fixed Loss = 3	
A	248.18	0.1548	S	19.22	61.795	9.566		Vel = 14.60	
			Bvcb	6.864					
			Fsp	0.0					
A	0.0	4.26		0.0	11.000	51.470			
to		120.0		0.0	0.0	4.981			
B	248.18	0.0149		0.0	11.000	0.164		Vel = 5.59	
B	0.0	4.26	T	26.334	11.000	56.615			
to		120.0		0.0	26.334	4.764			
C	248.18	0.0149		0.0	37.334	0.557		Vel = 5.59	
C	0.0	4.26	2E	26.334	31.000	61.936			
to		120.0	T	26.334	52.668	5.197			
D	248.18	0.0149		0.0	83.668	1.249		Vel = 5.59	
D	0.0	4.26	2E	26.334	31.500	68.382			
to		120.0		0.0	26.334	0.0			
E	248.18	0.0149		0.0	57.834	0.862		Vel = 5.59	
E	0.0	4.26	E	13.167	11.250	69.244			
to		120.0		0.0	13.167	4.764			
F	248.18	0.0149		0.0	24.417	0.365		Vel = 5.59	

Final Calculations - Hazen-Williams

SPRINKLER SYSTEMS INC.
100 Commercial Street Wet Systems Area 1

Page 6
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
F	0.0	4.26	2E	26.334	23.000	74.373			
to		120.0		0.0	26.334	0.0			
TWR	248.18	0.0149		0.0	49.334	0.736		Vel = 5.59	
TWR	0.0	4.26	Bvcb	15.8	2.000	75.109			
to		120.0	T	26.334	42.134	4.732		** Fixed Loss = 3	
BWR	248.18	0.0149	Fsp	0.0	44.134	0.659		Vel = 5.59	
BWR	0.0	4.26		0.0	3.000	80.500			
to		120.0		0.0	0.0	0.0			
BKFL	248.18	0.0147		0.0	3.000	0.044		Vel = 5.59	
BKFL	0.0	4.026	3E	30.0	1.000	80.544			
to		120.0		0.0	30.000	4.650		** Fixed Loss = 4	
BASE	248.18	0.0196		0.0	31.000	0.609		Vel = 6.25	
BASE	0.0	6.16	G	4.304	50.000	85.803			
to		140.0	T	43.037	67.425	0.0			
HOSE	248.18	0.0019	E	20.084	117.425	0.219		Vel = 2.67	
HOSE	100.00	8.27		0.0	480.000	86.022		Qa = 100	
to		140.0		0.0	0.0	0.0			
TEST	348.18	0.0008		0.0	480.000	0.398		Vel = 2.08	
	0.0								
	348.18					86.420		K Factor = 37.45	

Water Supply Curve C

SPRINKLER SYSTEMS INC.
100 Commercial Street Wet Systems Area 1

Page 7
Date

City Water Supply:
C1 - Static Pressure : 110
C2 - Residual Pressure: 48
C2 - Residual Flow : 1162

Demand:
D1 - Elevation : 22.088
D2 - System Flow : 248.18
D2 - System Pressure : 86.420
Hose (Demand) : 100
D3 - System Demand : 348.18
Safety Margin : 16.911

