Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 12/04/13

FIRST FLOOR SLAB PLAN

1/4"=1'-0"

TOPPING SLAB THICKNESS VARIES.
TOP OF TOPPING SLAB EL = 0'-0" (EQUAL TO SITE ELEV 9.80')

MATERIAL PROPERTIES:

CONCRETE	4000 PSI AT 28 DAYS
AGGREFATE	3/4" ASTM C33
ENTRAINED AIR	7% ± 1%
SLUMP	3" ± 1"
CORROSION INHIBITOR	3 1/2 GAL/CY ADDED AT BATCH PLANT GRACE DCI-S OR MASTER BUILDERS RHEOCRETE CNI
REINFORCING	ASTM A-615 EPOXY COATED

Key Plan

Prepared For:
MAINE WHARF, LLC
P.O. Box 535
BUXTON, ME 04093

Consulting Engineer:
STRUCTURAL DESIGN CONSULTING
22 Quaynant Drive
Old Orchard Beach ME
04064-4121
Tel 207.934.8038
Fax 207.934.8039

Architect:
ARCHETYPE architects
48 Union Wharf Portland, Maine 04101
(207) 772-6022 Fax (207) 772-4056

Project:
Maine Wharf
Building 1
Section A
68 Commercial Street
Portland, ME

Revisions:
Phase 1 Permit & Const. 11/22/13

Scale: As Noted

Date: 22 Nov 2013

FIRST FLOOR
SLAB PLAN

S1.01