Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 12/04/13

* W I N D O W S C H E D U L E *

TYPE A
ALUM. FIXED OVER AND UNDER AWNING WINDOW
(FIRST FLOOR)

TYPE A1
ALUM. FIXED BETWEEN CASEMENT WINDOWS WITH MULLIONS
(FIRST FLOOR)

TYPE F
PVC FIXED OVER AND UNDER AWNING WINDOW

TYPE T
ALUM. CASEMENT OVER AWNING WINDOW
(FIRST FLOOR)

TYPE Z
PVC FIXED CENTER BETWEEN CASEMENT WINDOWS
TWO MULLIONS

NOTE:
ALL WINDOW OPENINGS MEASUREMENTS TO BE FIELD VERIFIED.

DOOR SCHEDULE

DOOR SCHEDULE ABBREVIATIONS

CLO.	CLOSER	HM	HOLLOW METAL	S.C.	SOLID CORE HARDBOARD
DSI	DOOR SILENCERS	INS	INSULATED	S.H.	SPRING HINGE
D.S.	DOOR SWEEP (SOUNDPROOFING)	K	KICKPLATE (PUSH SIDE)	S.J.	SPLIT JAMB (WOOD)
DST	DOOR STOP	KL	KEY LOCK	TEMP	TEMPERED SAFETY GLAZING
EHO	ELECTRO. HOLD OPENER	MTL.	METAL	TL	THUMB LATCH
ES	ELECTRIC STRIKE	NO	NUMBER	THK	THICKNESS
F.J.P.	FINGER JOINTED PRIMED	PS	PASSAGE SET	UC	UNDERCUT
FR	FIRE RATED	P.H.	FIRE EXIT PANIC HARDWARE (NOTE 3)	WD	WOOD (SOLID)
HA	HANDICAP ACCESSIBLE	P.P.	PUSH PADDLE	WG	WIRE GLASS
HC	HOLLOW CORE HARDBOARD	PVS	PRIVACY SET	WS	WEATHERSTRIPPING
HDWE	HARDWARE	S.	STEEL	VIF	VERIFY IN FIELD

DOORS										FRAME TYPES					THRESHOLD			
MARK	TYPE	SIZE	THK.	F.R.	HDWE SET	MAT.	GLASS SIZE	GLASS TYPE	REMARKS	TYPE	MAT.	F.R.	DETAILS HEAD	DETAILS JAMB	MAT.	DETAIL SILL	DETAIL HT.	REMARKS
109	G	3'–0" x 7'–0"	–	–	FIRE EXIT PANIC HDWRE	ALUM	FULL	INS GLASS	HA, CLO, PH, DSI, DS, TEMP, WS	CC	ALUM	–	–	–	ALUM	–	1/2" MAX	NOTE 3, TWO EQ FULL GLASS SIDELIGHTS
209	J	3'–0" x 7'–0"	1 3/4"	–	–	PVC	FULL	INS GLASS	DSI, WS, PVS, DS	BB	METAL				–	–	–	

NOTES

1. SPECIFIC SELECTION OF DOOR TYPES, THICKNESS, VENEER, HINGES, LEVER HANDLES, FIRE EXIT PANIC BARS, PUSH PADS, WOOD TRIM AND OTHER RELATED DOOR HARDWARE BY OWNER/G.C. (MAINTAIN FIRE RATINGS REQUIRED FOR DOORS, FRAMES AND HARDWARE DEVICES INDICATED IN THIS SCHEDULE, TYP)
2. ALL NON–FIRE RATED DOORS SHALL BE EQUIPPED WITH LEVER TYPE HANDLES (UON) AND SHALL BE ADA COMPLIANT. OPERABLE PARTS SHALL BE 34" MIN. TO 48" MAX. ABOVE FINISHED FLOOR AND OPERATE WITH ONE HAND AND SHALL NOT REQUIRE TIGHT GRASPING, PINCHING, OR TWISTING OF THE WRIST. THE FORCE REQUIRED TO ACTIVATE OPERABLE PARTS SHALL BE 5 POUNDS (22.2N) MAXIMUM.
   a) DOOR CLOSERS SHALL BE ADJUSTED SO THAT FROM AN OPEN POSITION OF 90 DEGREES, THE TIME REQUIRED TO MOVE THE DOOR TO A POSITION OF 12 DEGREES FROM THE LATCH IS SECONDS, MINIMUM
3. LABELED FIRE DOORS OR EGRESS EXIT DOORS SHALL BE EQUIPPED WITH FIRE EXIT PANIC HARDWARE CONSISTING OF LISTED FIRE LABEL (IF APPLICABLE) WITH LATCHING MECHANISM. REQUIRED FIRE EXIT PANIC HARDWARE SHALL NOT BE EQUIPPED WITH ANY LOCKING DEVICE, SET SCREW, OR OTHER ARRANGEMENT THAT PREVENTS THE RELEASE OF THE LATCH WHEN PRESSURE IS APPLIED TO THE RELEASING DEVICE.

DOOR TYPES

FRAME TYPES

HEAD & JAMB TYPES

NOTES

1. DESIGN OF HEADS, JAMBS ETC. – SEE STRUCTURAL DRAWINGS
2. G.C. VERIFY ACTUAL THICKNESS OF EXISTING WALLS IN FIELD PRIOR TO ORDERING OR FABRICATION.
3. WALL TYPES–SHEET A

5' 4' 3' 2' 1' 0 5' 10'
GRAPHIC SCALE ¼" = 1'–0"

REGISTERED ARCHITECT
WILLIAM KENNETH HOPKINS
NO. 1090
STATE OF MAINE

Prepared For:
MAINE WHARF LLC
72 COMMERCIAL STREET
PORTLAND, ME 04101

Consulting Engineer:

Architect:
ARCHETYPE architects
48 Union Wharf Portland, Maine 04101
(207) 772-6022 Fax (207) 772-4056

Project:
MAINE WHARF
68 COMMERCIAL STREET
PORTLAND, MAINE

Revisions:
06 FEB 2013 : ISSUED FOR PERMIT
22 NOV 2013 : PHASE 1 : ISSUED FOR PERMIT AND CONSTRUCTION

Scale: AS INDICATED

Date: 27 Feb. 2013

PHASE 1 DOOR AND WINDOW SCHEDULE

A4.01