

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



# CITY OF PORTLAND BUILDING PERMIT



**This is to certify that**  
MAINE WHARF LLC

**Located at**  
68 COMMERCIAL ST

**PERMIT ID:** 2016-00956    **ISSUE DATE:** 08/11/2016    **CBL:** 030 D001001

has permission to **Demo of existing tenant fit up, new slab, new exterior fenestration and siding.**  
provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

*/s/ Michael White*

*/s/ Laurie Leader*

**Fire Official**

**Building Official**

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY  
THERE IS A PENALTY FOR REMOVING THIS CARD**

***Approved Property Use - Zoning***

Fish wholesale and retail

***Building Inspections***

**Use Group:** F-2/M    **Type:** 5A

Fish Wholesale/Mercantile  
Occupant load = 26 (fish retail)  
Building is not sprinkled  
BLDG B - END UNIT (RIGHT)  
MUBEC/IBC 2009

***Fire Department***

BUILDING PERMIT INSPECTION PROCEDURES  
Please call 874-8703 (ONLY)  
or email: [buildinginspections@portlandmaine.gov](mailto:buildinginspections@portlandmaine.gov)

**Check the Status or Schedule an Inspection On-Line at  
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the City of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that are attached to this permit! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases 6 months.**
- **If the inspection requirements are not followed as stated below, additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**

### **REQUIRED INSPECTIONS:**

Close-in Plumbing/Framing w/Fire & Draft Stopping

Above Ceiling Inspection

Electrical Close-in w/Fire & Draftstopping

Final - Commercial

Final - Fire

Final - Electric

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

<b>City of Portland, Maine - Building or Use Permit</b>		<b>Permit No:</b> 2016-00956	<b>Date Applied For:</b> 04/21/2016	<b>CBL:</b> 030 D001001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
<b>Proposed Use:</b> Fish wholesale and retail		<b>Proposed Project Description:</b> Demo of existing tenant fit up, new slab, new exterior fenestration and siding.		
<b>Dept:</b> Zoning <b>Status:</b> Approved w/Conditions <b>Reviewer:</b> Christina Stacey <b>Approval Date:</b> 06/08/2016		<b>Ok to Issue:</b> <input checked="" type="checkbox"/>		
<b>Note:</b> WCZ, Flood zone A2, EI 10. Wholesale and retail sales of fish - OK as marine use Minor improvement per FEMA requirements				
<b>Conditions:</b>				
1) Separate permits shall be required for any new signage.				
2) The use of the unit shall remain wholesale and retail sales of fish. Any change of use or addition of new uses shall require a separate permit application for review and approval.				
3) The use shall comply with the performance standards of the waterfront central zone, Section 14-311(d).				
4) This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work.				
<b>Dept:</b> Building Inspecti <b>Status:</b> Approved w/Conditions <b>Reviewer:</b> Laurie Leader <b>Approval Date:</b> 08/09/2016		<b>Ok to Issue:</b> <input checked="" type="checkbox"/>		
<b>Note:</b>				
<b>Conditions:</b>				
1) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.				
2) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems, fire suppression and fuel tanks. Separate plans may need to be submitted for approval as a part of this process.				
<b>Dept:</b> Engineering DPS <b>Status:</b> Not Applicable <b>Reviewer:</b> Rachel Smith <b>Approval Date:</b> 05/09/2016		<b>Ok to Issue:</b> <input checked="" type="checkbox"/>		
<b>Note:</b>				
<b>Conditions:</b>				
1) This approval is non-applicable to Engineering DPS as it relates to approval for Grease Control Equipment for the Fats, Oil, and Grease Program. If approval is needed for this project by the Engineering Department of Public Services for any other reason than FOG, please contact David Margolis-Pineo at 207-874-8850 or dmp@portlandmaine.gov				
<b>Dept:</b> Fire <b>Status:</b> Approved w/Conditions <b>Reviewer:</b> Michael White <b>Approval Date:</b> 06/08/2016		<b>Ok to Issue:</b> <input checked="" type="checkbox"/>		
<b>Note:</b>				
<b>Conditions:</b>				
1) If applicable, all outstanding code violations shall be corrected prior to final inspection.				
2) All means of egress to remain accessible at all times.				
3) All construction shall comply with 2009 NFPA 101, Chapter 37 Existing Mercantile Occupancies.				
4) All construction shall comply with 2009 NFPA 101, Chapter 43 Building Rehabilitation.				
5) All construction shall comply with 2009 NFPA 1, Fire Code. Review and approval by the AHJ shall not relieve the applicant of the responsibility of compliance with this Code (Chapter 1.14.4).				
6) All construction shall comply with City Code, Chapter 10.				