

**... Fire Protection by Computer Design**

High Tech Fire Protection  
PO Box 156  
Minot, ME 04258  
(207) 998-2551

Job Name : Third Floor Calc.  
Building : Maine Wharf  
Location : 68 Commercial Street  
System : NFPA 13  
Contract : 021414-1  
Data File : Third Floor Calc.wxf

Hydraulic Design Information Sheet

Name - Third Floor Calc. Date - 03/26/2014  
 Location - 68 Commercial Street  
 Building - Maine Wharf System No. - NFPA 13  
 Contractor - High Tech Fire Protection Contract No. - 021414-1  
 Calculated By - Jeremy A Foss Drawing No. - FP-1.2  
 Construction: ( ) Combustible (X) Non-Combustible Ceiling Height - Varies  
 Occupancy - TBD - Future Tenant

S (X) NFPA 13 ( ) Lt. Haz. Ord.Haz.Gp. ( ) 1 (X) 2 ( ) 3 ( ) Ex.Haz.  
 Y ( ) NFPA 231 ( ) NFPA 231C ( ) Figure Curve

S Other

T Specific Ruling Made By Date

	Area of Sprinkler Operation - 1950	System Type	Sprinkler/Nozzle
M	Density - .2	(X) Wet	Make Globe
D	Area Per Sprinkler - 120	( ) Dry	Model GL5615
E	Elevation at Highest Outlet - 47.500	( ) Deluge	Size 1/2"
S	Hose Allowance - Inside -	( ) Preaction	K-Factor 5.6
I	Rack Sprinkler Allowance -	( ) Other	Temp.Rat.155
G	Hose Allowance - Outside - 250		

N Note

Calculation Flow Required - 809 Press Required - 92  
 Summary C-Factor Used: 120 Overhead 140 Underground

W	Water Flow Test:	Pump Data:	Tank or Reservoir:
A	Date of Test - 05/11/2013		Cap. -
T	Time of Test -	Rated Cap.-	Elev.-
E	Static Press - 108	@ Press -	
R	Residual Press - 102	Elev. -	Well
S	Flow - 1537		Proof Flow
U	Elevation - -3		

P Location - Test Hydrant Located at Corner of Commercial and Maple Streets

P Source of Information - Brian Johnson of the Portland Water District

C	Commodity	Class	Location
O	Storage Ht.	Area	Aisle W.
M	Storage Method:	%	Palletized % Rack
M	( ) Single Row	( ) Conven. Pallet	( ) Auto. Storage ( ) Encap.
S	( ) Double Row	( ) Slave Pallet	( ) Solid Shelf ( ) Non
T	( ) Mult. Row		( ) Open Shelf

R K Flue Spacing Clearance:Storage to Ceiling  
 A Longitudinal Transverse

E Horizontal Barriers Provided:


# Water Supply Curve (C)

High Tech Fire Protection  
Third Floor Calc.

Page 2  
Date 03/26/2014

City Water Supply:  
C1 - Static Pressure : 108  
C2 - Residual Pressure: 102  
C2 - Residual Flow : 1537

Demand:  
D1 - Elevation : 21.872  
D2 - System Flow : 558.623  
D2 - System Pressure : 91.996  
Hose ( Demand ) : 250  
D3 - System Demand : 808.623  
Safety Margin : 14.175



# Fittings Used Summary

High Tech Fire Protection  
Third Floor Calc.

Page 3  
Date 03/26/2014

Fitting Legend		½	¾	1	1¼	1½	2	2½	3	3½	4	5	6	8	10	12	14	16	18	20	24	
Abbrev.	Name																					
B	NFPA 13 Butterfly Valve	0	0	0	0	5	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0	0
E	NFPA 13 90° Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61	
F	NFPA 13 45° Elbow	1	1	1	1	2	2	3	3	3	4	5	7	9	11	13	17	19	21	24	28	
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																				
G	NFPA 13 Gate Valve	0	0	1	1	1	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13	
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65						
T	NFPA 13 90° Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121	
V	90° Ell Firelock #001	0	0	0	0	0	3.5	4.3	5	0	6.8	8.5	10	13	0	0	0	0	0	0	0	0
X	90° Tee-Branch Firelock 002	0	0	0	0	0	8.5	10.8	13	0	16	21	25	33	0	0	0	0	0	0	0	0

## Units Summary

Diameter Units           Inches  
 Length Units             Feet  
 Flow Units                US Gallons per Minute  
 Pressure Units           Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with \*. The fittings marked with a \* show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a \* will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

# Pressure / Flow Summary - STANDARD

High Tech Fire Protection  
Third Floor Calc.

Page 4  
Date 03/26/2014

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
DP1	0.5	5.6	18.37	na	24.0	0.2	120	7.0
DP2	0.5	5.6	18.37	na	24.0	0.2	120	7.0
201	44.0	K = K @ EQ01	25.34	na	27.3			
202	44.0	K = K @ EQ01	25.4	na	27.33			
203	44.0	K = K @ EQ01	25.65	na	27.46			
204	44.0	K = K @ EQ01	26.18	na	27.75			
205	44.0	K = K @ EQ01	27.24	na	28.3			
A1	44.0		27.35	na				
206	47.5	K = K @ EQ02	19.04	na	24.0			
A3	47.5		21.87	na				
207	47.5	K = K @ EQ01	21.88	na	25.37			
208	47.5	K = K @ EQ01	22.07	na	25.47			
209	47.5	K = K @ EQ01	22.51	na	25.73			
210	47.5	K = K @ EQ01	23.28	na	26.17			
211	47.5	K = K @ EQ01	24.71	na	26.96			
A4	47.5		24.82	na				
212	47.5	K = K @ EQ02	19.11	na	24.04			
A6	47.5		22.02	na				
213	47.5	K = K @ EQ01	22.03	na	25.45			
214	47.5	K = K @ EQ01	22.22	na	25.56			
215	47.5	K = K @ EQ01	22.67	na	25.82			
216	47.5	K = K @ EQ01	23.44	na	26.26			
217	47.5	K = K @ EQ01	24.88	na	27.05			
A7	47.5		24.99	na				
218	44.0	K = K @ EQ01	26.63	na	27.99			
219	44.0	K = K @ EQ01	26.7	na	28.02			
220	44.0	K = K @ EQ01	26.96	na	28.16			
221	44.0	K = K @ EQ01	27.51	na	28.45			
A9	44.0		28.75	na				
A2	40.5		31.06	na				
A5	40.5		31.11	na				
A8	40.5		31.3	na				
A10	40.5		31.77	na				
A11	40.5		32.49	na				
A12	39.5		34.4	na				
A13	39.5		43.57	na				
A14	27.0		50.42	na				
A15	27.0		62.98	na				
BF1	27.0		63.91	na				
BF2	18.0		78.41	na				
BF3	-2.0		87.41	na				
BF4	-2.0		89.47	na				
BF5	-3.0		91.31	na				
TEST	-3.0		92.0	na	250.0			

The maximum velocity is 13.54 and it occurs in the pipe between nodes A7 and A8

# Final Calculations - Hazen-Williams

High Tech Fire Protection  
Third Floor Calc.

Page 5  
Date 03/26/2014

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftnng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
DP1 to EQ01	24.00 24.0	1.049 120.0 0.1824	1T	5.0 0.0 0.0	0.500 5.000 5.500	18.367 0.217 1.003			K Factor = 5.60 Vel = 8.91	
	0.0 24.00						19.587		K Factor = 5.42	
DP2 to EQ02	24.00 24.0	1.049 120.0 0.1824	1E	2.0 0.0 0.0	0.500 2.000 2.500	18.367 0.217 0.456			K Factor = 5.60 Vel = 8.91	
	0.0 24.00						19.040		K Factor = 5.50	
201 to 202	27.30 27.3	2.157 120.0 0.0070		0.0 0.0 0.0	9.000 0.0 9.000	25.335 0.0 0.063			K Factor @ node EQ01 Vel = 2.40	
202 to 203	27.32 54.62	2.157 120.0 0.0249		0.0 0.0 0.0	10.000 0.0 10.000	25.398 0.0 0.249			K Factor @ node EQ01 Vel = 4.80	
203 to 204	27.47 82.09	2.157 120.0 0.0530		0.0 0.0 0.0	10.000 0.0 10.000	25.647 0.0 0.530			K Factor @ node EQ01 Vel = 7.21	
204 to A1	27.74 109.83	2.157 120.0 0.0908	1X	10.461 0.0 0.0	2.500 10.461 12.961	26.177 0.0 1.177			K Factor @ node EQ01 Vel = 9.64	
	0.0 109.83						27.354		K Factor = 21.00	
205 to A1	28.30 28.3	2.157 120.0 0.0074	1X	10.461 0.0 0.0	5.500 10.461 15.961	27.236 0.0 0.118			K Factor @ node EQ01 Vel = 2.48	
A1 to A2	109.83 138.13	2.157 120.0 0.1388	1T	12.307 0.0 0.0	3.500 12.307 15.807	27.354 1.516 2.194			Vel = 12.13	
	0.0 138.13						31.064		K Factor = 24.78	
206 to A3	24.00 24.0	1.049 120.0 0.1823	1E 1T	2.0 5.0 0.0	8.500 7.000 15.500	19.040 0.0 2.826			K Factor @ node EQ02 Vel = 8.91	
A3 to 207	0.0 24.0	2.157 120.0 0.0056		0.0 0.0 0.0	2.500 0.0 2.500	21.866 0.0 0.014			Vel = 2.11	
207 to 208	25.37 49.37	2.157 120.0 0.0207		0.0 0.0 0.0	9.000 0.0 9.000	21.880 0.0 0.186			K Factor @ node EQ01 Vel = 4.33	
208 to 209	25.47 74.84	2.157 120.0 0.0446		0.0 0.0 0.0	10.000 0.0 10.000	22.066 0.0 0.446			K Factor @ node EQ01 Vel = 6.57	
209 to 210	25.73 100.57	2.157 120.0 0.0772		0.0 0.0 0.0	10.000 0.0 10.000	22.512 0.0 0.772			K Factor @ node EQ01 Vel = 8.83	

# Final Calculations - Hazen-Williams

High Tech Fire Protection  
Third Floor Calc.

Page 6  
Date 03/26/2014

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
210 to A4	26.17 126.74	2.157 120.0 0.1184	1X 0.0 0.0	10.461 0.0 12.961	2.500 10.461 12.961	23.284 0.0 1.534		K Factor @ node EQ01 Vel = 11.13	
	0.0 126.74					24.818		K Factor = 25.44	
211 to A4	26.96 26.96	2.157 120.0 0.0068	1X 0.0 0.0	10.461 0.0 15.961	5.500 10.461 15.961	24.710 0.0 0.108		K Factor @ node EQ01 Vel = 2.37	
A4 to A5	126.73 153.69	2.157 120.0 0.1691	1T 0.0 0.0	12.307 0.0 19.307	7.000 12.307 19.307	24.818 3.032 3.264		Vel = 13.49	
	0.0 153.69					31.114		K Factor = 27.55	
212 to A6	24.04 24.04	1.049 120.0 0.1830	1E 1T 0.0	2.0 5.0 0.0	8.900 7.000 15.900	19.110 0.0 2.909		K Factor @ node EQ02 Vel = 8.92	
A6 to 213	0.0 24.04	2.157 120.0 0.0056	0.0 0.0 0.0	0.0 0.0 0.0	2.500 0.0 2.500	22.019 0.0 0.014		Vel = 2.11	
213 to 214	25.46 49.5	2.157 120.0 0.0208	0.0 0.0 0.0	0.0 0.0 9.000	9.000 0.0 9.000	22.033 0.0 0.187		K Factor @ node EQ01 Vel = 4.35	
214 to 215	25.56 75.06	2.157 120.0 0.0449	0.0 0.0 0.0	0.0 0.0 10.000	10.000 0.0 10.000	22.220 0.0 0.449		K Factor @ node EQ01 Vel = 6.59	
215 to 216	25.82 100.88	2.157 120.0 0.0776	0.0 0.0 0.0	0.0 0.0 10.000	10.000 0.0 10.000	22.669 0.0 0.776		K Factor @ node EQ01 Vel = 8.86	
216 to A7	26.26 127.14	2.157 120.0 0.1190	1X 0.0 0.0	10.461 0.0 12.961	2.500 10.461 12.961	23.445 0.0 1.543		K Factor @ node EQ01 Vel = 11.16	
	0.0 127.14					24.988		K Factor = 25.43	
217 to A7	27.05 27.05	2.157 120.0 0.0068	1X 0.0 0.0	10.461 0.0 15.961	5.500 10.461 15.961	24.879 0.0 0.109		K Factor @ node EQ01 Vel = 2.37	
A7 to A8	127.14 154.19	2.157 120.0 0.1700	1T 0.0 0.0	12.307 0.0 19.307	7.000 12.307 19.307	24.988 3.032 3.283		Vel = 13.54	
	0.0 154.19					31.303		K Factor = 27.56	
218 to 219	27.99 27.99	2.157 120.0 0.0073	0.0 0.0 0.0	0.0 0.0 9.000	9.000 0.0 9.000	26.633 0.0 0.066		K Factor @ node EQ01 Vel = 2.46	
219 to 220	28.02 56.01	2.157 120.0 0.0261	0.0 0.0 0.0	0.0 0.0 10.000	10.000 0.0 10.000	26.699 0.0 0.261		K Factor @ node EQ01 Vel = 4.92	

# Final Calculations - Hazen-Williams

High Tech Fire Protection  
Third Floor Calc.

Page 7  
Date 03/26/2014

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
220 to 221	28.15 84.16	2.157 120.0 0.0555		0.0 0.0 0.0	10.000 0.0 10.000	26.960 0.0 0.555		K Factor @ node EQ01 Vel = 7.39		
221 to A9	28.45 112.61	2.157 120.0 0.0951	1X	10.461 0.0 0.0	2.500 10.461 12.961	27.515 0.0 1.233		K Factor @ node EQ01 Vel = 9.89		
A9 to A10	0.0 112.61	2.157 120.0 0.0951	1T	12.307 0.0 0.0	3.500 12.307 15.807	28.748 1.516 1.503		Vel = 9.89		
	0.0 112.61					31.767		K Factor = 19.98		
A2 to A5	138.13 138.13	4.26 120.0 0.0050		0.0 0.0 0.0	10.000 0.0 10.000	31.064 0.0 0.050		Vel = 3.11		
A5 to A8	153.70 291.83	4.26 120.0 0.0201		0.0 0.0 0.0	9.400 0.0 9.400	31.114 0.0 0.189		Vel = 6.57		
A8 to A10	154.18 446.01	4.26 120.0 0.0442		0.0 0.0 0.0	10.500 0.0 10.500	31.303 0.0 0.464		Vel = 10.04		
A10 to A11	112.61 558.62	4.26 120.0 0.0669	1V	8.954 0.0 0.0	1.900 8.954 10.854	31.767 0.0 0.726		Vel = 12.57		
A11 to A12	0.0 558.62	4.26 120.0 0.0669	1X	21.067 0.0 0.0	1.000 21.067 22.067	32.493 0.433 1.477		Vel = 12.57		
A12 to A13	0.0 558.62	4.26 120.0 0.0669	2V	17.907 0.0 0.0	119.000 17.907 136.907	34.403 0.0 9.163		Vel = 12.57		
A13 to A14	0.0 558.62	4.26 120.0 0.0669	1V	8.954 0.0 0.0	12.500 8.954 21.454	43.566 5.414 1.435		Vel = 12.57		
A14 to A15	0.0 558.62	4.26 120.0 0.0669	3V 1T 1S	26.861 26.334 28.968	44.900 97.963 142.863	50.415 3.000 9.562		* Fixed loss = 3 Vel = 12.57		
			1Fsp 1B	0.0 15.8						
A15 to BF1	0.0 558.62	4.26 120.0 0.0669	1V	8.954 0.0 0.0	5.000 8.954 13.954	62.977 0.0 0.934		Vel = 12.57		
BF1 to BF2	0.0 558.62	4.26 120.0 0.0669	1Fsp	0.0 0.0 0.0	9.000 0.0 9.000	63.911 13.898 0.602		* Fixed loss = 10 Vel = 12.57		
BF2 to BF3	0.0 558.62	6.16 140.0 0.0084	1E	20.084 0.0 0.0	20.000 20.084 40.084	78.411 8.662 0.335		Vel = 6.01		



# Final Calculations - Hazen-Williams

High Tech Fire Protection  
Third Floor Calc.

Page 8  
Date 03/26/2014

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
BF3 to BF4	0.0 558.62	6.16 140.0 0.0083	1G 4.304 1T 43.037	200.000 47.341	87.408 0.0				
			0.0	247.341	2.065		Vel = 6.01		
BF4 to BF5	0.0 558.62	12.24 100.0 0.0005	5F 52.392	2500.000 52.392	89.473 0.433				
			0.0	2552.392	1.402		Vel = 1.52		
BF5 to TEST	0.0 558.62	6.16 140.0 0.0083	1E 20.084 1G 4.304 1T 43.037	15.000 67.425 82.425	91.308 0.0 0.688				
	250.00 808.62						Qa = 250.00 K Factor = 84.31		
					91.996				