General Mechanical Notes

1. Locate plumbing vents a minimum of 30'-0" from outside air intake openings.
2. Locate exhaust fan vents a minimum of 10'-0" from outside air intake openings.
3. The Electrical Contractor shall provide duct smoke detectors for each air handling system, connected to the Building Fire Alarm system.

ROOF PLAN

3rd FLOOR PLAN

THIRD FLOOR PLAN
SCALE: 1/8" = 1'-0"

Atlantic Comfort Systems, Inc.
Mechanical Contractor • 207-284-6380
392 Hill Street Biddeford, ME 04005
www.atlanticcomfort.com

Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 05/23/14

STATE OF ME
STEPHEN P. DOEL
No. 3807
PROFESSIONAL ENGINEER

Revisions
1. Added minisplit AC unit to the EMR and electric heat to the Sprinkler and Electrical Rooms. Changed 1-1/4"G. (H.P.) to 1-1/2"G. (H.P.).

Maine Wharf

Portland, ME

BENNETT ENGINEERING
MECHANICAL • ELECTRICAL
(207) 865-9475

Job No.:	3540
Date:	1/15/14
Scale:	1/8" = 1'-0" or A.N.
Drawn by:	SP Doel
Checked by:	SP Doel

Drawing Title:
HVAC 3rd Floor Plan and Roof Plan

M.2