



P.O. Box 1005, North Conway, NH 03860 • 1-800-717-6454

P.O. Box 187, Gardiner, ME 04345 • 1-800-649-9881

August 15, 2019

Fire Prevention Office, City of Portland, ME
Attn: Mike Clinton
Portland, ME 04101

RE: Ri-Ra's
72 Commercial Street
Portland, ME 04101

Please be advised that Interstate Fire Protection has completed the installation of an ANSUL R 102 Fire Suppression System for the protection of the Vent Hood and Appliances at the above mentioned location.

The System installation is in compliance with the State, Local and Federal Fire Codes as well as the manufacturers (ANSUL) specifications. It also complies with NFPA 17A Standard for Wet Chemical Extinguishing Systems.

The System has means of automatic detection (Fusible Links) as well as a Remote Manual Pull Station Actuation. In the event of a System Actuation the electric power to appliances beneath the Vent Hood will shut down, and means to notify the Fire Department through a 24 hour Monitoring Company will occur through snap action micro-switches located in the Fire Suppression System Control Box.

The System was Tested and witnessed by your office on Wednesday, August 15, 2019.

I respectfully submit this letter and should you require any more information, please do not hesitate to contact me.

Sincerely,

Steven D Cram

Office: 800-717-6454

Cell: 603-455-2380

Fax: 603-356-2763

E-mail: scram@interstatefire.com