




Reviewed for Code Compliance
Inspections Division
Approved with Conditions

10/31/16

Date:



3-5/8" MTL STUD &
TYPE "X" GYP BD PARTITION
(1 HOUR RATED - UL U419)

1A