






GENERAL NOTES:

- IT IS THE BUILDING OWNERS RESPONSIBILITY TO PROVIDE ADEQUATE HEAT FOR ALL AREAS IN THE BUILDING PROTECTED BY WET SPRINKLER SYSTEMS AND FOR ALL WATER FILLED SUPPLY PIPES, VALVES AND SYSTEM RISERS IN ALL DRY PIPE SPRINKLER SYSTEMS.
- ALL NEW PIPING IS TO BE HYDROSTATICALLY TESTED AT NOT LESS THAN 200 PSI FOR 2 HOURS, OR AT 50 PSI IN EXCESS OF THE MAXIMUM PRESSURE, WHEN THE MAXIMUM PRESSURE TO BE MAINTAINED IS IN EXCESS OF 150 PSI. (PER NFPA 13)
- WHETHER OR NOT INDICATED ON DRAWINGS, THE FOLLOWING ITEMS ARE TO BE PROVIDED:
 - SPARE HEAD CABINET WITH WRENCH (NFPA 13)
 - PROVISIONS FOR FLUSHING CONNECTIONS AND DRAINING OF ALL PIPE.
 - INSPECTORS TEST CONNECTION SHALL BE PROVIDED FOR EACH SYSTEM
 - A) FOR WET PIPE SYSTEMS SEE NFPA 13)
 - B) FOR DRY PIPE SYSTEMS SEE NFPA 13)
 - AIR PRESSURE SHALL BE MAINTAINED ON ALL DRY PIPE SYSTEMS BY AN APPROVED AUTOMATIC AIR COMPRESSOR OR PLANT AIR SYSTEM SPECIFICALLY APPROVED FOR AND CAPABLE OF AUTOMATICALLY MAINTAINING THE REQUIRED AIR PRESSURE.
 - WET PIPE SYSTEMS SHALL BE PROVIDED WITH A RELIEF VALVE NOT LESS THAN 1/2" IN SIZE. (NFPA 13).
- ALL PIPE 1" SHALL BE SCHEDULE 40 STEEL WITH MALLEABLE IRON FITTINGS.
- ALL PIPE 1 1/2" AND LARGER, SHALL BE SCHEDULE 10 STEEL, WITH GROOVED COUPLINGS AND VICTAULIC MECHANICAL FITTINGS OR EQUIVALENT.
- ALL MECHANICAL TRADES ARE TO COORDINATE THEIR WORK WITH SPRINKLER WORK AS SHOWN ON THESE PLANS.
- ALL HANGERS AND LOCATIONS ARE TO BE IN ACCORDANCE WITH N.F.P.A. 13.
- ALL SPRINKLER HEADS LOCATED IN SUSPENDED CEILING TILES ARE TO BE LOCATED IN AN AESTHETIC PLEASING PATTERN NO CLOSER THAN 3" TO ANY CEILING T-BAR.
- ALL PIPING IS TO BE PITCHED IN ACCORDANCE WITH N.F.P.A. 13.
- HYDRAULIC DATA REFERENCE POINTS: (25) (4)
- CENTER LINE OF PIPE ABOVE FINISH FLOOR (12'-0") BELOW DECK (12")
- PROTECTIVE CAPS ARE TO REMAIN ON THE SPRINKLER HEADS UNTIL AFTER CEILINGS ARE INSTALLED.
- WORK IS LIMITED TO THE WORK SHOWN ON THESE DOCUMENTS.
- PHASE 1 OF THIS PROJECT IS TO COVER VACANT SUITES OF THE BUILDING ON THE LOWER LEVELS UP TO THE SECOND FLOOR, RIGHT HAND SIDE OF BUILDING.

WATER DATA
 STATIC 110 PSI
 RESIDUAL 102 PSI
 FLOW 1162 GPM
 BY PORTLAND WATER DISTRICT
 DATE 10/06/15 @ 6:35 AM
 HYDRANT ELEV: 100.00' +/-



1. Type of Hazard LIGHT/ORDINARY 2. Deflector Distance PER SPEC
 3. Pipe Type Used BLK_SCH_10/40 4. Sprinkler Area PER SPEC
 5. Type of Construction COMBUSTIBLE
 6. Maximum Spacing Allowed PER NFPA 13
 7. PIPE SIZING METHOD: PIPE SCHEDULE HYDRAULICALLY CALCULATED
 8. ALL HANGERS AND LOCATIONS TO BE IN ACCORDANCE WITH N.F.P.A. PAMPHLET NO. 13
 9. HIGH DEGREE TEMPERATURE SPRINKLER HEADS TO BE INSTALLED IN ACCORDANCE WITH N.F.P.A. PAMPHLET NO. 13



HANGERS
AS SHOWN IN DETAIL

ABBREVIATIONS
 B Bottom of Beam
 D Bottom of Deck
 P Bottom of Pipe
 H.V. Hanger Valve
 N.C. Not in Contact
 NTS Not to Scale
 OBU Open Box Joints
 PRV Pressure Red Valve
 RM Roof Membrane
 SP Standpipe
 TSB Top of Beam
 TOS Top of Slab
 UNL Unless Otherwise Noted
 CL Centerline
 NED No Automatic Sprinklers
 OTA Open to Above

CONTRACT RESPONSIBILITIES


ITEM	FFC	OTHERS
STREET CONN		
LOG MAN		
EXCAVATION		
FLUSHING		
WIRING		
PAINTING		
TAMPER SWITCHES		
FLOW SWITCHES		
STREET CONN		

SPRINKLER HEAD LEGEND

SYMBOL	MAKE	MODEL	SIN	FINISH	TYPE	TEMP	NPT	ORIFICE	K-FACTOR	TOTAL
○	RELIABLE	F1FR 56	RA1414	WHITE	SEMI-REC PENDENT	155° F	1/2"	1/2"	5.6	7
○	RELIABLE	F1FR 56	RA1414	BRONZE	PENDENT	155° F	1/2"	1/2"	5.6	38
○	RELIABLE	F1FR 56	RA1425	BRONZE	UPRIGHT	155° F	1/2"	1/2"	5.6	1
○	RELIABLE	F1FR 56	RA1425	BRONZE	UPRIGHT	200° F	1/2"	1/2"	5.6	12
○	RELIABLE	F1FR 56	RA1435	WHITE	HORIZ SIDE WALL	155° F	1/2"	1/2"	5.6	11
TOTAL										69

SUBMITTALS

SENT TO	DATE SENT	DATE RECEIVED
1'S D		
F.M		
L.M		
I.R.1		
L.A		
STATE FIRE		
LOCAL FIRE		
LOCAL WATER		
OWNER		




JOHN D. CARROLL BLOCK
 136 COMMERCIAL STREET
 PORTLAND, MAINE 04101

CONTRACT WITH SCOTT LINDSEY

SCALE AS NOTED
 DRAWN BY JJP
 CHECKED BY CDS
 DATE 12/15/2015
 TOTAL SPKRS ON JOB 69
 SHEET# 1 of 3
 JOB# 15142

SUBMITTAL COPY



... Fire Protection by Computer Design

SPRINKLER SYSTEMS INC.
4 AVON STREET
P O BOX 1285
LEWISTON, ME. 04243
207-782-0104

Job Name : 136 Commercial Street Area 1
Building : Existing
Location : 136 Commercial Street Portland, Maine
System : 1 WET
Contract : 15-142
Data File : 136 Commercial Street Area 1.WXF

Hydraulic Design Information Sheet

Name - 136 Commercial Street Area 1 Date - 4-26-16
 Location - 136 Commercial Street Portland, Maine
 Building - Existing System No. - 1 WET
 Contractor - Sprinkler Systems Inc Contract No. - 15-142
 Calculated By - CDS Drawing No. - 1-3 of TBD
 Construction: (X) Combustible () Non-Combustible Ceiling Height - VARIES
 Occupancy - OFFICES

S (X) NFPA 13 (X) Lt. Haz. Ord.Haz.Gp. () 1 () 2 () 3 () Ex.Haz.
 Y () NFPA 231 () NFPA 231C () Figure Curve

S Other

T Specific Ruling Made By Date

		Made By	Date
M	Area of Sprinkler Operation - 945	System Type	Sprinkler/Nozzle
	Density - .10	(X) Wet	Make RELIABLE
D	Area Per Sprinkler - 196	() Dry	Model F1FR56
E	Elevation at Highest Outlet - 130	() Deluge	Size 1/2" X 1/2"
S	Hose Allowance - Inside - 0	() Preaction	K-Factor 5.6
I	Rack Sprinkler Allowance - 0	() Other	Temp.Rat.155 DEG.
G	Hose Allowance - Outside - 100		

N Note

Calculation Flow Required - 347.99 Press Required - 63.901 AT BASE
 Summary C-Factor Used: 120 Overhead 140 Underground

W	Water Flow Test:	Pump Data:	Tank or Reservoir:
A	Date of Test - 10/06/15		Cap. -
T	Time of Test - AM	Rated Cap.-	Elev.-
E	Static Press - 110	@ Press -	
R	Residual Press - 102	Elev. -	Well
	Flow - 1162		Proof Flow
S	Elevation - 100.0'		

U Location - ON SITE

P Source of Information - OWNER AND WATER DISTRICT

Y

C	Commodity	Class	Location
O	Storage Ht.	Area	Aisle W.
M	Storage Method:	%	Palletized % Rack
	() Single Row	() Conven. Pallet	() Auto. Storage () Encap.
S	() Double Row	() Slave Pallet	() Solid Shelf () Non
T	() Mult. Row		() Open Shelf

O C
 R K Flue Spacing Clearance:Storage to Ceiling
 A Longitudinal Transverse

G
 E Horizontal Barriers Provided:

Fittings Used Summary

SPRINKLER SYSTEMS INC.
136 Commercial Street Area 1

Page 2
Date

Fitting Legend		1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
E	NFPA 13 90° Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
F	NFPA 13 45° Elbow	1	1	1	1	2	2	3	3	3	4	5	7	9	11	13	17	19	21	24	28
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																			
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
T	NFPA 13 90° Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Zac	Ames 2000SS	Fitting generates a Fixed Loss Based on Flow																			

Units Summary

Diameter Units Inches
 Length Units Feet
 Flow Units US Gallons per Minute
 Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Pressure / Flow Summary - STANDARD

SPRINKLER SYSTEMS INC.
136 Commercial Street Area 1

Page 3
Date

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
TYP	0.0	5.6	12.25	na	19.6	0.1	196	7.0
ARM1	128.5	5.6	29.85	na	30.59	0.15	120	7.0
20	128.5	5.6	31.33	na	31.34	0.1	196	7.0
23	128.5	5.6	31.58	na	31.47	0.15	120	7.0
24	128.5	K = K @ DROP	31.8	na	30.65			
25	128.5		32.27	na				
26	128.5		34.93	na				
17	130.0	5.6	22.84	na	26.77	0.1	196	7.0
15	130.0	5.6	22.56	na	26.6	0.1	196	7.0
13	130.0	5.6	18.07	na	23.8	0.1	196	7.0
10	130.0	5.6	12.25	na	19.6	0.1	196	7.0
11	130.0	K = K @ DROP	14.0	na	20.34			
7	130.0	5.6	13.68	na	20.71	0.1	196	7.0
8	130.0	K = K @ DROP	14.93	na	21.0			
5	130.0	5.6	16.36	na	22.65	0.1	196	7.0
2	130.0	5.6	14.5	na	21.32	0.1	196	7.0
1	130.0	5.6	14.24	na	21.13	0.1	196	7.0
3	130.0		16.4	na				
4	129.25		20.13	na				
6	129.25		20.2	na				
9	129.25		20.32	na				
12	129.25		20.65	na				
14	129.25		21.27	na				
16	128.5		25.86	na				
18	128.5		27.06	na				
19	128.5		33.87	na				
21	128.5		34.32	na				
22	128.5		34.97	na				
27	128.5		35.0	na				
A	118.25		40.09	na				
B	118.25		41.29	na				
C	118.25		42.53	na				
D	104.0		49.47	na				
TOR	106.0		54.74	na				
BKFL	104.0		58.66	na				
BASE	100.0		63.9	na				
HOSE	100.0		64.31	na	100.0			
1000	100.0		64.48	na				
2000	100.0		64.55	na				
TEST	100.0		65.19	na				

The maximum velocity is 19.66 and it occurs in the pipe between nodes 18 and 19

Final Calculations - Hazen-Williams

SPRINKLER SYSTEMS INC.
136 Commercial Street Area 1

Page 4
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
TYP to DROP	19.60 19.6	1.049 120.0 0.1253	T 5.0 0.0 0.0	1.000 5.000 6.000	12.250 0.0 0.752		K Factor = 5.60 Vel = 7.28		
	0.0 19.60					13.002	K Factor = 5.44		
ARM1 to 25	30.59 30.59	1.049 120.0 0.2856	T 5.0 0.0 0.0	3.500 5.000 8.500	29.846 0.0 2.428		K Factor = 5.60 Vel = 11.36		
	0.0 30.59					32.274	K Factor = 5.38		
20 to 21	31.34 31.34	1.049 120.0 0.2988	E 2.0 T 5.0 0.0	3.000 7.000 10.000	31.328 0.0 2.988		K Factor = 5.60 Vel = 11.63		
	0.0 31.34					34.316	K Factor = 5.35		
23 to 24	31.47 31.47	1.682 120.0 0.0303		7.000 0.0 7.000	31.584 0.0 0.212		K Factor = 5.60 Vel = 4.54		
24 to 25	30.65 62.12	1.682 120.0 0.1062		4.500 0.0 4.500	31.796 0.0 0.478		K Factor @ node DROP Vel = 8.97		
25 to 26	30.60 92.72	1.682 120.0 0.2229	T 9.9 0.0 0.0	2.000 9.900 11.900	32.274 0.0 2.653		Vel = 13.39		
26 to 27	0.0 92.72	2.635 120.0 0.0251		2.750 0.0 2.750	34.927 0.0 0.069		Vel = 5.46		
	0.0 92.72					34.996	K Factor = 15.67		
17 to 18	26.77 26.77	1.049 120.0 0.2231	2E 4.0 T 5.0 0.0	7.000 9.000 16.000	22.844 0.650 3.570		K Factor = 5.60 Vel = 9.94		
	0.0 26.77					27.064	K Factor = 5.15		
15 to 16	26.60 26.6	1.049 120.0 0.2206	2E 4.0 T 5.0 0.0	3.000 9.000 12.000	22.561 0.650 2.647		K Factor = 5.60 Vel = 9.87		
	0.0 26.60					25.858	K Factor = 5.23		
13 to 14	23.80 23.8	1.049 120.0 0.1796	2E 4.0 T 5.0 0.0	7.000 9.000 16.000	18.069 0.325 2.873		K Factor = 5.60 Vel = 8.84		
	0.0 23.80					21.267	K Factor = 5.16		
10 to 11	19.60 19.6	1.049 120.0 0.1254	4E 8.0 0.0 0.0	6.000 8.000 14.000	12.250 0.0 1.755		K Factor = 5.60 Vel = 7.28		

Final Calculations - Hazen-Williams

SPRINKLER SYSTEMS INC.
136 Commercial Street Area 1

Page 5
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
11 to 12	20.34 39.94	1.049 120.0 0.4679	E T	2.0 5.0 0.0	6.500 7.000 13.500	14.005 0.325 6.316			K Factor @ node DROP	
	0.0 39.94						20.646		K Factor = 8.79	
7 to 8	20.71 20.71	1.049 120.0 0.1388	E	2.0 0.0 0.0	7.000 2.000 9.000	13.679 0.0 1.249			K Factor = 5.60	Vel = 7.69
8 to 9	21.00 41.71	1.049 120.0 0.5069	E T	2.0 5.0 0.0	3.000 7.000 10.000	14.928 0.325 5.069			K Factor @ node DROP	Vel = 15.48
	0.0 41.71						20.322		K Factor = 9.25	
5 to 6	22.65 22.65	1.049 120.0 0.1638	3E T	6.0 5.0 0.0	10.500 11.000 21.500	16.356 0.325 3.521			K Factor = 5.60	Vel = 8.41
	0.0 22.65						20.202		K Factor = 5.04	
2 to 3	21.32 21.32	1.049 120.0 0.1465	E T	2.0 5.0 0.0	6.000 7.000 13.000	14.498 0.0 1.904			K Factor = 5.60	Vel = 7.91
	0.0 21.32						16.402		K Factor = 5.26	
1 to 3	21.13 21.13	1.049 120.0 0.1441	E T	2.0 5.0 0.0	8.000 7.000 15.000	14.241 0.0 2.161			K Factor = 5.60	Vel = 7.84
3 to 4	21.32 42.45	1.049 120.0 0.5237	T	5.0 0.0 0.0	1.500 5.000 6.500	16.402 0.325 3.404				Vel = 15.76
4 to 6	0.0 42.45	2.157 120.0 0.0158		0.0 0.0 0.0	4.500 0.0 4.500	20.131 0.0 0.071				Vel = 3.73
6 to 9	22.65 65.1	2.157 120.0 0.0343		0.0 0.0 0.0	3.500 0.0 3.500	20.202 0.0 0.120				Vel = 5.72
9 to 12	41.72 106.82	2.157 120.0 0.0864		0.0 0.0 0.0	3.750 0.0 3.750	20.322 0.0 0.324				Vel = 9.38
12 to 14	39.94 146.76	2.157 120.0 0.1552		0.0 0.0 0.0	4.000 0.0 4.000	20.646 0.0 0.621				Vel = 12.89
14 to 16	23.80 170.56	2.157 120.0 0.2050	2E	12.307 0.0 0.0	8.500 12.307 20.807	21.267 0.325 4.266				Vel = 14.97
16 to 18	26.60 197.16	2.157 120.0 0.2680		0.0 0.0 0.0	4.500 0.0 4.500	25.858 0.0 1.206				Vel = 17.31

Final Calculations - Hazen-Williams

SPRINKLER SYSTEMS INC.
136 Commercial Street Area 1

Page 6
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
18	26.77	2.157	T	12.307	7.750	27.064			
to		120.0		0.0	12.307	0.0			
19	223.93	0.3392		0.0	20.057	6.804		Vel = 19.66	
19	0.0	2.635		0.0	3.500	33.868			
to		120.0		0.0	0.0	0.0			
21	223.93	0.1280		0.0	3.500	0.448		Vel = 13.17	
21	31.34	2.635		0.0	4.000	34.316			
to		120.0		0.0	0.0	0.0			
22	255.27	0.1630		0.0	4.000	0.652		Vel = 15.02	
22	0.0	4.26		0.0	1.750	34.968			
to		120.0		0.0	0.0	0.0			
27	255.27	0.0160		0.0	1.750	0.028		Vel = 5.75	
27	92.72	4.26	E	13.167	10.500	34.996			
to		120.0		0.0	13.167	4.439			
A	347.99	0.0279		0.0	23.667	0.660		Vel = 7.83	
A	0.0	4.26	E	13.167	3.500	40.095			
to		120.0	T	26.334	39.501	0.0			
B	347.99	0.0279		0.0	43.001	1.199		Vel = 7.83	
B	0.0	4.26	2E	26.334	18.000	41.294			
to		120.0		0.0	26.334	0.0			
C	347.99	0.0279		0.0	44.334	1.236		Vel = 7.83	
C	0.0	4.26	E	13.167	14.500	42.530			
to		120.0		0.0	13.167	6.172			
D	347.99	0.0279		0.0	27.667	0.771		Vel = 7.83	
D	0.0	4.26	10E	131.671	62.000	49.473			
to		120.0	T	26.334	158.005	-0.866			
TOR	347.99	0.0279		0.0	220.005	6.134		Vel = 7.83	
TOR	0.0	4.26	Fsp	0.0	2.000	54.741			
to		120.0		0.0	0.0	3.866		* * Fixed Loss = 3	
BKFL	347.99	0.0280		0.0	2.000	0.056		Vel = 7.83	
BKFL	0.0	4.026	Zac	0.0	0.500	58.663			
to		120.0		0.0	0.0	5.220		* * Fixed Loss = 3.488	
BASE	347.99	0.0360		0.0	0.500	0.018		Vel = 8.77	
BASE	0.0	6.16	E	20.084	50.000	63.901			
to		140.0	T	43.037	67.425	0.0			
HOSE	347.99	0.0035	G	4.304	117.425	0.409		Vel = 3.75	
HOSE	100.00	8.27	T	55.354	75.000	64.310		Qa = 100	
to		140.0		0.0	55.354	0.0			
1000	447.99	0.0013		0.0	130.354	0.172		Vel = 2.68	
1000	0.0	12.34	F	20.316	270.000	64.482			
to		140.0	T	93.767	114.083	0.0			
2000	447.99	0.0002		0.0	384.083	0.073		Vel = 1.20	
2000	0.0	8.27		0.0	480.000	64.555			
to		140.0		0.0	0.0	0.0			
TEST	447.99	0.0013		0.0	480.000	0.634		Vel = 2.68	

Final Calculations - Hazen-Williams

SPRINKLER SYSTEMS INC.
136 Commercial Street Area 1

Page 7
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
	0.0 447.99					65.189		K Factor = 55.49	


Water Supply Curve C

SPRINKLER SYSTEMS INC.
136 Commercial Street Area 1

Page 8
Date

City Water Supply:
C1 - Static Pressure : 110
C2 - Residual Pressure: 102
C2 - Residual Flow : 1162

Demand:
D1 - Elevation : 12.993
D2 - System Flow : 347.986
D2 - System Pressure : 65.189
Hose (Demand) : 100
D3 - System Demand : 447.986
Safety Margin : 43.439



Hydraulic Design Information Sheet

Name - 136 Commercial Street Area 2 Date - 4-26-16
 Location - 136 Commercial Street Portland, Maine
 Building - Existing System No. - 1 WET
 Contractor - Sprinkler Systems Inc Contract No. - 15-142
 Calculated By - CDS Drawing No. - 1-3 of TBD
 Construction: (X) Combustible () Non-Combustible Ceiling Height - VARIES
 Occupancy - RETAIL

S (X) NFPA 13 () Lt. Haz. Ord.Haz.Gp. () 1 (X) 2 () 3 () Ex.Haz.
 Y () NFPA 231 () NFPA 231C () Figure Curve

S Other

T Specific Ruling Made By Date

E			
M	Area of Sprinkler Operation - 945	System Type	Sprinkler/Nozzle
	Density - .20	(X) Wet	Make RELIABLE
D	Area Per Sprinkler - 130	() Dry	Model F1FR56
E	Elevation at Highest Outlet - 119	() Deluge	Size 1/2" X 1/2"
S	Hose Allowance - Inside - 0	() Preaction	K-Factor 5.6
I	Rack Sprinkler Allowance - 0	() Other	Temp.Rat.155 DEG.
G	Hose Allowance - Outside - 250		

N Note

Calculation Flow Required - 352.18 Press Required - 50.747 AT BASE
 Summary C-Factor Used: 120 Overhead 140 Underground

W	Water Flow Test:	Pump Data:	Tank or Reservoir:
A	Date of Test - 10/06/15		Cap. -
T	Time of Test - AM	Rated Cap.-	Elev.-
E	Static Press - 110	@ Press -	
R	Residual Press - 102	Elev. -	Well
	Flow - 1162		Proof Flow
S	Elevation - 100.0'		

U Location - ON SITE

P Source of Information - OWNER AND WATER DISTRICT

Y

C	Commodity	Class	Location
O	Storage Ht.	Area	Aisle W.
M	Storage Method:	%	Palletized % Rack
	() Single Row	() Conven. Pallet	() Auto. Storage () Encap.
S	() Double Row	() Slave Pallet	() Solid Shelf () Non
T	() Mult. Row		() Open Shelf

O C
 R K Flue Spacing Clearance:Storage to Ceiling
 A Longitudinal Transverse

G
 E Horizontal Barriers Provided:

Pressure / Flow Summary - STANDARD

SPRINKLER SYSTEMS INC.
136 Commercial Street Area 2

Page 10
Date

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
TYP	0.0	5.6	21.56	na	26.0	0.2	130	7.0
40	118.25	5.6	24.16	na	27.52	0.1	196	7.0
37	119.0	K = K @ DROP	24.06	na	26.7			
38	119.0	K = K @ DROP	24.27	na	26.81			
35	118.25	5.6	23.57	na	27.19	0.1	196	7.0
33	119.0	5.6	22.83	na	26.76	0.1	196	7.0
31	119.0	K = K @ DROP	22.82	na	26.0			
32	119.0	K = K @ DROP	23.02	na	26.11			
34	118.25		26.17	na				
36	118.25		26.21	na				
39	118.25		26.38	na				
41	118.25		26.86	na				
43	118.25	5.6	25.32	na	28.18	0.1	196	7.0
45	118.25	K = K @ DROP	25.87	na	27.68			
46	118.25	K = K @ DROP	26.09	na	27.8			
48	118.25	K = K @ DROP	24.52	na	26.95			
49	118.25	K = K @ DROP	24.71	na	27.05			
50	118.25	K = K @ DROP	25.4	na	27.42			
51	118.25		28.7	na				
47	118.25		28.75	na				
44	118.25		28.76	na				
42	118.25		28.76	na				
C	118.25		29.2	na				
D	104.0		36.16	na				
TOR	106.0		41.56	na				
BKFL	104.0		45.48	na				
BASE	100.0		50.75	na				
HOSE	100.0		51.16	na	250.0			
1000	100.0		51.46	na				
2000	100.0		51.59	na				
TEST	100.0		52.68	na				

The maximum velocity is 11.76 and it occurs in the pipe between nodes 50 and 51

Final Calculations - Hazen-Williams

SPRINKLER SYSTEMS INC.
136 Commercial Street Area 2

Page 11
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
TYP to DROP	26.00 26.0	1.049 120.0 0.2115	T	5.0 0.0 0.0	1.000 5.000 6.000	21.556 0.0 1.269			K Factor = 5.60	
	0.0 26.00									
							22.825		K Factor = 5.44	
40 to 41	27.52 27.52	1.049 120.0 0.2350	2T	10.0 0.0 0.0	1.500 10.000 11.500	24.159 0.0 2.702			K Factor = 5.60	
	0.0 27.52									
							26.861		K Factor = 5.31	
37 to 38	26.70 26.7	1.682 120.0 0.0223		0.0 0.0 0.0	9.250 0.0 9.250	24.063 0.0 0.206			K Factor @ node DROP	
									Vel = 3.86	
38 to 39	26.81 53.51	1.682 120.0 0.0806	E T	4.95 9.9 0.0	7.330 14.850 22.180	24.269 0.325 1.788			K Factor @ node DROP	
	0.0 53.51									
							26.382		K Factor = 10.42	
35 to 36	27.19 27.19	1.049 120.0 0.2297	2T	10.0 0.0 0.0	1.500 10.000 11.500	23.572 0.0 2.642			K Factor = 5.60	
	0.0 27.19									
							26.214		K Factor = 5.31	
33 to 34	26.76 26.76	1.049 120.0 0.2230	2E T	4.0 5.0 0.0	4.500 9.000 13.500	22.832 0.325 3.010			K Factor = 5.60	
	0.0 26.76									
							26.167		K Factor = 5.23	
31 to 32	26.00 26.0	1.682 120.0 0.0212		0.0 0.0 0.0	9.250 0.0 9.250	22.825 0.0 0.196			K Factor @ node DROP	
									Vel = 3.75	
32 to 34	26.11 52.11	1.682 120.0 0.0768	3E T	14.849 9.9 0.0	12.000 24.749 36.749	23.021 0.325 2.821			K Factor @ node DROP	
									Vel = 7.52	
34 to 36	26.76 78.87	2.635 120.0 0.0188		0.0 0.0 0.0	2.500 0.0 2.500	26.167 0.0 0.047				Vel = 4.64
36 to 39	27.19 106.06	2.635 120.0 0.0320		0.0 0.0 0.0	5.250 0.0 5.250	26.214 0.0 0.168				Vel = 6.24
39 to 41	53.50 159.56	2.635 120.0 0.0684		0.0 0.0 0.0	7.000 0.0 7.000	26.382 0.0 0.479				Vel = 9.39
41 to 42	27.53 187.09	2.635 120.0 0.0918	T	16.474 0.0 0.0	4.250 16.474 20.724	26.861 0.0 1.902				Vel = 11.01

Final Calculations - Hazen-Williams

SPRINKLER SYSTEMS INC.
136 Commercial Street Area 2

Page 12
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
	0.0 187.09					28.763		K Factor = 34.88	
43 to 44	28.18	1.049 120.0 0.2454	2T 10.0 0.0 0.0	4.000 10.000 14.000	25.322 0.0 3.436			K Factor = 5.60 Vel = 10.46	
	0.0 28.18					28.758		K Factor = 5.25	
45 to 46	27.68	1.682 120.0 0.0238	0.0 0.0 0.0	9.250 0.0 9.250	25.872 0.0 0.220			K Factor @ node DROP Vel = 4.00	
46 to 47	27.80	1.682 120.0 0.0862	2E 9.9 T 9.9 0.0	11.000 19.800 30.800	26.092 0.0 2.656			K Factor @ node DROP Vel = 8.01	
	0.0 55.48					28.748		K Factor = 10.35	
48 to 49	26.95	1.682 120.0 0.0227	0.0 0.0 0.0	8.330 0.0 8.330	24.523 0.0 0.189			K Factor @ node DROP Vel = 3.89	
49 to 50	27.05	1.682 120.0 0.0820	0.0 0.0 0.0	8.330 0.0 8.330	24.712 0.0 0.683			K Factor @ node DROP Vel = 7.80	
50 to 51	27.43	1.682 120.0 0.1753	E 4.95 T 9.9 0.0	4.000 14.850 18.850	25.395 0.0 3.305			K Factor @ node DROP Vel = 11.76	
51 to 47	0.0	4.26 120.0 0.0019	E 13.167 0.0 0.0	12.000 13.167 25.167	28.700 0.0 0.048			Vel = 1.83	
47 to 44	55.48	4.26 120.0 0.0050	0.0 0.0 0.0	2.000 0.0 2.000	28.748 0.0 0.010			Vel = 3.08	
44 to 42	28.18	4.26 120.0 0.0067	0.0 0.0 0.0	0.750 0.0 0.750	28.758 0.0 0.005			Vel = 3.72	
42 to C	187.09	4.26 120.0 0.0285	E 13.167 0.0 0.0	2.000 13.167 15.167	28.763 0.0 0.432			Vel = 7.93	
C to D	0.0	4.26 120.0 0.0285	E 13.167 0.0 0.0	14.500 13.167 27.667	29.195 6.172 0.789			Vel = 7.93	
D to TOR	0.0	4.26 120.0 0.0285	10E 131.671 T 26.334 0.0	62.000 158.005 220.005	36.156 -0.866 6.271			Vel = 7.93	
TOR to BKFL	0.0	4.26 120.0 0.0285	Fsp 0.0 0.0 0.0	2.000 0.0 2.000	41.561 3.866 0.057			** Fixed Loss = 3 Vel = 7.93	

Final Calculations - Hazen-Williams

SPRINKLER SYSTEMS INC.
136 Commercial Street Area 2

Page 13
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
BKFL to BASE	0.0 352.18	4.026 120.0 0.0380	Zac	0.0 0.0 0.500	0.500 0.0 0.500	45.484 5.244 0.019		* * Fixed Loss = 3.512 Vel = 8.88	
BASE to HOSE	0.0 352.18	6.16 140.0 0.0036	E T G	20.084 43.037 4.304	50.000 67.425 117.425	50.747 0.0 0.418		Vel = 3.79	
HOSE to 1000	250.00 602.18	8.27 140.0 0.0023	T	55.354 0.0 0.0	75.000 55.354 130.354	51.165 0.0 0.298		Qa = 250 Vel = 3.60	
1000 to 2000	0.0 602.18	12.34 140.0 0.0003	F T	20.316 93.767 0.0	270.000 114.083 384.083	51.463 0.0 0.125		Vel = 1.62	
2000 to TEST	0.0 602.18	8.27 140.0 0.0023		0.0 0.0 0.0	480.000 0.0 480.000	51.588 0.0 1.097		Vel = 3.60	
	0.0 602.18					52.685		K Factor = 82.96	


Water Supply Curve C



SPRINKLER SYSTEMS INC.
136 Commercial Street Area 2

Page 14
Date

City Water Supply:
C1 - Static Pressure : 110
C2 - Residual Pressure: 102
C2 - Residual Flow : 1162

Demand:
D1 - Elevation : 8.229
D2 - System Flow : 352.178
D2 - System Pressure : 52.685
Hose (Demand) : 250
D3 - System Demand : 602.178
Safety Margin : 54.944





HYDRAULIC DATA NAMEPLATE

This Building is protected by a hydraulically designed Automatic Sprinkler System

Location AREA-2

No. of Sprinkler 13

Basis of design

- Density .20 GPM/FT²
- Design area of discharge 945 FT²

System Demand

- Water Flow Rate
- Residual Pressure


① Base/Pump 352.18 GPM

② Base/Pump 50.747 PSI

CUSHION = 54.94 psi

NOT MOST REMOTE


- CEILING TYPE**
- EWJ EXPOSED WOOD JOIST
 - TNG TONGUE AND GROOVE WOOD DECK
 - MSC METAL SLAT CEILING
 - ACT ACOUSTICAL TILE CEILING
 - GWB GYPSUM WALL BOARD



● ABOVE AND BELOW COVERAGE, ONE BRONZE UPRIGHT 200' HEAD AND ONE WHITE SEMI-RECESSED PENDENT 155'. SEE SPRINKLER HEAD DETAILS.

SPRINKLER HEAD LEGEND

SYMBOL	MAKE	MODEL	SIN	FINISH	TYPE	TEMP	NPT	ORIFICE	K-FACTOR	TOTAL
○	RELIABLE	F1FR 56	RA1414	WHITE	SEMI-REC PENDENT	155° F	1/2"	1/2"	5.6	7
●	RELIABLE	F1FR 56	RA1414	BRONZE	PENDENT	155° F	1/2"	1/2"	5.6	38
○	RELIABLE	F1FR 56	RA1425	BRONZE	UPRIGHT	155° F	1/2"	1/2"	5.6	1
○	RELIABLE	F1FR 56	RA1425	BRONZE	UPRIGHT	200° F	1/2"	1/2"	5.6	12
○	RELIABLE	F1FR 56	RA1435	WHITE	HORIZ. SIDE WALL	155° F	1/2"	1/2"	5.6	11
TOTAL										69




JOHN D. CARROLL BLOCK
 136 COMMERCIAL STREET
 PORTLAND, MAINE 04101

CONTRACT WITH SCOTT LINDSEY

SYSTEM TYPE	NO.	DATE	REVISIONS	DESCRIPTION
WET				
DRY				
DELUGE				
PREACTION				
ME. LIFE				
HYDRO-PRO				

DATE: 12/15/2015
 TOTAL SPKRS ON JOB: 69
 SHEET# 2 of 3
 JOB# 15142

SUBMITTAL COPY



SECOND FLOOR SPRINKLER PLAN
 SCALE: 1/4" = 1'-0"
 FINISH FLOOR ELEV. 119.83'

HYDRAULIC DATA NAMEPLATE

This Building is protected by a hydraulically designed Automatic Sprinkler System

Location AREA-1

No. of Sprinkler 14

Basis of design


- Density .10 GPM/FT²
- Design area of discharge 945 FT²

System Demand

- Water Flow Rate
 @ Base/Pump 347.99 GPM
- Residual Pressure
 @ Base/Pump 63.901 PSI
 CUSHION = 43.44 psi

AREA 1
 .10/945
 +100


MOST REMOTE



THIRD FLOOR SPRINKLER PLAN
 SCALE: 1/4" = 1'-0"
 FINISH FLOOR ELEV. 131.38'

NO WORK ON THIS FLOOR AT THIS TIME.


- CEILING TYPE**
- EWJ EXPOSED WOOD JOIST
 - TNG TONGUE AND GROOVE WOOD DECK
 - MSC METAL SLAT CEILING
 - ACT ACOUSTICAL TILE CEILING



ABOVE AND BELOW COVERAGE, ONE BRONZE UPRIGHT 200' HEAD AND ONE WHITE SEMI-RECESSED PENDENT 155'. SEE SPRINKLER HEAD DETAILS.

SPRINKLER HEAD LEGEND

SYMBOL	MAKE	MODEL	SIN	FINISH	TYPE	TEMP	NPT	ORIFICE	K-FACTOR	TOTAL
○	RELIABLE	F1FR 56	RA1414	WHITE	SEMI-RECESSED PENDENT	155° F	1/2"	1/2"	5.6	7
●	RELIABLE	F1FR 56	RA1414	BRONZE	UPRIGHT	155° F	1/2"	1/2"	5.6	38
○	RELIABLE	F1FR 56	RA1425	BRONZE	UPRIGHT	155° F	1/2"	1/2"	5.6	1
○	RELIABLE	F1FR 56	RA1425	BRONZE	UPRIGHT	200° F	1/2"	1/2"	5.6	12
◀	RELIABLE	F1FR 56	RA1435	WHITE	HORIZ. SIDE WALL	155° F	1/2"	1/2"	5.6	11
TOTAL										69



JOHN D. CARROLL BLOCK
 136 COMMERCIAL STREET
 PORTLAND, MAINE 04101

CONTRACT WITH SCOTT LINDSEY

SYSTEM TYPE WET DRY DELUGE PREACTION ME. LIFE HYDRO-PRO

NO. DATE DESCRIPTION

REVISIONS

DATE: 12/15/2015

TOTAL SPKRS ON JOB: 69

SHEET# 3 of 3

JOB# 15142

SCALE AS NOTED

DRAWN BY JJP

CHECKED BY CDS

PERMIT # ?????

LICENSE# 093 R.M.S.# 442

SUBMITTAL COPY