## DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



This is to certify that

314 CHANDLERS WHARF LLC

Located at

314 CHANDLERS WHARF

**PERMIT ID:** 2014-02952

**ISSUE DATE:** 01/08/2015

**CBL:** 031 J002314

has permission to For the installation of an HVAC System (Prestige Excellence Water Boiler) for Unit 314 (Second Floor).

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Benjamin Wallace Jr.

/s/ Tammy Munson

Fire Official

**Building Official** 

THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY THERE IS A PENALTY FOR REMOVING THIS CARD

Approved Property Use - Zoning

**Building Inspections** 

Fire Department

## BUILDING PERMIT INSPECTION PROCEDURES Please call 874-8703 (ONLY)

or email: buildinginspections@portlandmaine.gov

## Check the Status or Schedule an Inspection On-Line at http://www.portlandmaine.gov/planning/permitstatus.asp

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.
- Permits expire in 6 months. If the project is not started or ceases for 6 months.
- If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.
- Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.

## **REQUIRED INSPECTIONS:**

Final Inspection

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

Permit No: Date Applied For: CBL: City of Portland, Maine - Building or Use Permit 2014-02952 12/26/2014 031 J002314 389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716 Proposed Use: **Proposed Project Description:** Same: Residential Condo (Unit 314) For the installation of an HVAC System (Prestige Excellence Wate Boiler) for Unit 314 (Second Floor). 01/02/2015 Reviewer: Tammy Munson **Dept:** Zoning Status: Approved **Approval Date:** Ok to Issue: Note: **Conditions: Status:** Approved w/Conditions **Reviewer:** Tammy Munson 01/02/2015 Dept: Building **Approval Date:** Note: Ok to Issue: ✓ **Conditions:** 1) Equipment shall be installed in compliance with the manufacturer's specifications and the UL listing. 2) The installation must comply with the State of Maine Gas Regulations. **Reviewer:** Benjamin Wallace Jr. 01/08/2015 **Dept:** Fire **Status:** Approved w/Conditions **Approval Date:** Ok to Issue: Note: **Conditions:** 1) Installation shall comply with NFPA 211, Standard for Chimneys, Fireplaces, Vents, and Solid Fuel-Burning Appliances; NFPA 54, National Fuel Gas Code; NFPA 70, National Electrical Code; and the manufacturer's published instructions.

2) Installation shall comply with City Code Chapter 10.