

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that

CM WATERFRONT PROPERTIES LLC /Dan Michaud

Located at

250 COMMERCIAL ST

PERMIT ID: 2013-00967

ISSUE DATE: 05/29/2013

CBL: 031 L034001

has permission to **install one 8' diameter wall sign**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

| | |
|---|--|
| Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED. | A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy. |
|---|--|

N/A

/s/ Ann Machado

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning

1st floor -left side restaurant & right side Spa,
2nd floor - left side - front office, left side rear - photo studio & right side -spa

Building Inspections

Fire Department

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703 (ONLY)
or email: buildinginspections@portlandmaine.gov

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.**

REQUIRED INSPECTIONS:

Final Inspection

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

| | | | | |
|---|---|--|--|----------------------------|
| City of Portland, Maine - Building or Use Permit | | Permit No: 2013-00967 | Date Applied For: 05/14/2013 | CBL: 031 L034001 |
| 389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716 | | | | |
| Proposed Use: same - restaurant w/ brewery & distillery, spa and office | Proposed Project Description: install one 8' diameter wall sign | | | |
| Dept: Zoning Status: Approved Reviewer: Ann Machado Approval Date: 05/20/2013 | | Note: Doesn't need certificate of insurance because it is located back from the street. Ok to Issue: <input checked="" type="checkbox"/> | | |
| Conditions: | | | | |
| Dept: Building Status: Approved w/Conditions Reviewer: Ann Machado Approval Date: 05/20/2013 | | Note: Ok to Issue: <input checked="" type="checkbox"/> | | |
| Conditions: | | | | |
| 1) Signage and Awning Installation to comply with Chapters 16 (Structural Loads), 31 (Materials) & 32 (ROW Height & Encroachments) of the IBC 2009 building code. | | | | |