
Sign Permit #00601 - 250 Commercial St

Jonni Peace <jonni@signarama-saco.com>

Thu, Apr 27, 2017 at 1:31 PM

To: Christina Stacey <cstacey@portlandmaine.gov>, info@mainespantry.com

Sign bracket will be attached with (4) 3/8 x 2" lag Screws set in with 3/8 x 1-3/4 anchor sleeve set into the bricks. Additional epoxy may be added to the holes at the time of installation depending on the condition and density of the bricks

Please let us know if you need any other information.

Thank you!

Jonni Peace

Owner

Signarama
The way to grow your business.

Signarama of Saco

872 Portland Rd

Saco, ME 04072

How did we do?



Click to rate your experience with Signarama: Saco

207-494-8085

www.signarama-saco.com

E Mail: jonni@signarama-saco.com