


CITY OF PORTLAND  
 FIRE PREVENTION BUREAU  
 380 Congress Street, Portland, Maine 04101  
 fireprevention@portlandmaine.gov  
 (207) 874-8400



**NOTICE OF VIOLATION AND ORDER TO CORRECT**

August 1, 2017

<b>Responsible Party 1:</b> CM WATERFRONT PROPERTIES LLC PO BOX 7467 PORTLAND, ME 04112		
<b>Location</b> 250 COMMERCIAL ST	<b>CBL</b> 031 L034001	<b>Inspection Date</b> 7/12/2017
<b>Inspector</b> Phillip Larou	<b>Inspection Type</b> FP Tier II	<b>Status</b> Failed

The City of Portland Fire Department inspected this property, and found the fire and life safety code violations listed below, which you are hereby ordered to correct. You must propose a date of completion to remedy each violation, a final date of completion, and a date of re-inspection.

**You must send this form to the Fire Prevention Bureau no later than 8/30/2017.**

Your failure to submit a plan of action by the date provided, or to correct any violation within the applicable time frame, may result in legal action against you, the imposition of civil penalties, and the pursuit of other legal remedies.

Violation	Proposed Date of Completion
NFPA 70- ARTICLE 590.6 EXT. CORD USED FOR PERMENANT WIRING; Ground-fault protection for personnel for all TEMPORARY wiring installations shall be provided to comply with 590.6 (A) and (B). This section shall apply only to temporary wiring installations used to supply temporary power to equipment used by personnel during construction, remodeling, maintenance, repair, or demolition of buildings, structures, equipment or similar activities. Extension cord in kitchen. Left hand side by hand sink when entering the kitchen from dinning room.	Wiring issue addressed 8/1/17 and ready for re-inspection
FINAL DATE OF COMPLETED VIOLATION(S)	___/___/___
FIRE PREVENTION BUREAU RE-INSPECTION OF COMPLETED VIOLATION(S)	___/___/___

APPROVED 8/9/17  
 CAPT. *[Signature]* # 17

