

City of Portland, Maine - Building or Use Permit Application

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

DEPT. OF BUILDING INSPECTION
CITY OF PORTLAND, ME

Permit No: 05-1684 Issue Date: NOV 29 CBL: 032 C001001

Location of Construction: 390 CONGRESS ST	Owner Name: MEDIA PROPERTIES OF MAINE	Owner Address: ONE CITY CENTER	Phone:
Business Name:	Contractor Name: Northeast Mechanical Corp	Contractor Address: 139 Cash Street South Portland	Phone: 2077998533
Lessee/Buyer's Name	Phone:	Permit Type: HVAC	Zone:

RECEIVED

Past Use: Commercial	Proposed Use: Commercial/ install a Cleaver Brooks CB 200-80 Boiler in basement	Permit Fee: \$1,641.00	Cost of Work: \$180,000.00	CEO District: 1
-------------------------	--	---------------------------	-------------------------------	--------------------

FIRE DEPT: <input checked="" type="checkbox"/> Approved <input type="checkbox"/> Denied	INSPECTION: Use Group: <i>Boiler</i> Type: <i>Boiler</i> <i>11/27/05</i> <i>[Signature]</i>
---	---

PERMIT ISSUED with conditions
NOV 29 2005
CITY OF PORTLAND

Proposed Project Description:
install a Cleaver Brooks CB 200-80 Boiler in basement

Signature: *[Signature]* Signature: *[Signature]*
PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.)
Action: Approved Approved w/Conditions Denied
Date:

Permit Taken By: Idobson	Date Applied For: 11/17/2005	Zoning Approval
-----------------------------	---------------------------------	------------------------

<ol style="list-style-type: none"> This permit application does not preclude the Applicant(s) from meeting applicable State and Federal Rules. Building permits do not include plumbing, septic or electricat work. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work.. 	Special Zone or Reviews <input type="checkbox"/> Shoreland <input type="checkbox"/> Wetland <input type="checkbox"/> Flood Zone <input type="checkbox"/> Subdivision <input type="checkbox"/> Site Plan Maj <input type="checkbox"/> Minor <input type="checkbox"/> MM <input type="checkbox"/> Date:	Zoning Appeal <input type="checkbox"/> Variance <input type="checkbox"/> Miscellaneous <input type="checkbox"/> Conditional Use <input type="checkbox"/> Interpretation <input type="checkbox"/> Approved <input type="checkbox"/> Denied Date:	Historic Preservation <input type="checkbox"/> Not in District or Landmark <input type="checkbox"/> Does Not Require Review <input type="checkbox"/> Requires Review <input type="checkbox"/> Approved <input type="checkbox"/> Approved w/Conditions <input type="checkbox"/> Denied Date:
---	---	---	---

CERTIFICATION


I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provision of the code(s) applicable to such permit.

SIGNATURE OF APPLICANT	ADDRESS	DATE	PHONE
RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE		DATE	PHONE



FILL IN AND SIGN WITH INK

APPLICATION FOR PERMIT HEATING OR POWER EQUIPMENT



The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location / CBL 390 CONGRESS STREET Use of Building OFFICE Date 11/17/05
 Name and address of owner of appliance PORTLAND PRESS HERALD
390 CONGRESS STREET PORTLAND, MAINE 04101
 Installer's name and address NORTHEAST MECHANICAL CORPORATION
139 CASH ST. SOUTH PORTLAND, ME Telephone 799-8533

Location of appliance:

- Basement
- Attic
- Floor
- Roof

Type of Fuel:

- Gas
- Oil
- Solid

Appliance Name: CLEAVER-BROOKS CB260-80

U.L. Approved Yes No

Will appliance be installed in accordance with the manufacture's installation instructions? Yes No

IF NO Explain: _____

The Type of License of Installer:

- Master Plumber # _____
- Solid Fuel # _____
- Oil # MS 30004466
- Gas # _____
- Other 1-6 OIL/SOLID FUELS UNLIMITED

Type of Chimney:

- Masonry Lined EXISTING CHIMNEY
- Factory built SEE ATTACHED CHIMNEY INSPECTION REPORT
- Metal BREECHING
- Factory Built U.L. Listing # MH 6673
- SEE ATTACHED m-3 DRAWING
- Direct Vent
- Type _____ UL# _____

Type of Fuel Tank

- Oil
- Gas

Size of Tank 20,000

Number of Tanks 1 UNDERGROUND

Distance from Tank to Center of Flame 20 feet.

Cost of Work: \$ 180,000.00

Permit Fee: \$ _____

Approved

Fire: _____
 Ele.: _____
 Bldg.: [Signature]

Approved with Conditions

- See attached letter or requirement

Inspector's Signature _____

Date Approved _____

Signature of Installer [Signature]

City of Portland, Maine - Building or Use Permit

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

Permit No: 05-1684	Date Applied For: 11/17/2005	CBL: 032 C001001
------------------------------	--	----------------------------

Location of Construction: 390 CONGRESS ST	Owner Name: MEDIA PROPERTIES OF MAINE	Owner Address: ONE CITY CENTER	Phone:
Business Name:	Contractor Name: Northeast Mechanical Corp	Contractor Address: 139 Cash Street South Portland	Phone (207) 799-8533
Lessee/Buyer's Name	Phone:	Permit Type: HVAC	

Proposed Use: Commercial/ install a Cleaver Brooks CB 200-80 Boiler in basement	Proposed Project Description: install a Cleaver Brooks CB 200-80 Boiler in basement
---	---

Dept: Building	Status: Approved with Conditions	Reviewer: Mike Nugent	Approval Date: 11/23/2005
Note:			Ok to Issue: <input type="checkbox"/>
1) Installation shall comply with 2003 International Mechanical Code and State of Maine Oil and Solid Fuel Board Laws and Rules			
Dept: Fire	Status: Approved with Conditions	Reviewer: Cptn Greg Cass	Approval Date: 11/17/2005
Note:			Ok to Issue: <input checked="" type="checkbox"/>
1) All penetrations to be sealed { 1 hour }			
2) Fire alarm certification required			
3) Sprinkler system certification required			