LEGEND

DESCRIPTION

FACP	FIRE ALARM CONTROL PANEL
FAA	FIRE ALARM ANNUNCIATOR PANEL
BDA	BI-DIRECTIONAL AMP FOR FIREMAN PHONE COMM
XPP	TRANSPONDER CABINET FOR FIRE PUMP MONITORING
XPA	TRANSPONDER CABINET FOR FIREMAN PHONE COMM REPEATER SYSTEM
XPE	TRANSPONDER CABINET FOR ELEVATOR CONTROL – RELAY BOARD
F	MANUAL PULL STATION
K	MONITOR MODULE/FUTURE KITCHEN HOOD
N	INTELLIGENT CONTROL MODULE FOR NAC CRKTS
S	SMOKE DETECTOR
S_{SB}	SMOKE DETECTOR w/SOUNDER BASE
S_C	SMOKE/CARBON MONOXIDE COMBINATION DETECTOR
D	DUCT SMOKE DETECTOR
Q	CO2 GAS DETECTOR
H	HEAT DETECTOR
V	STROBE UNIT
H	HORN/STROBE UNIT
R	INTELLIGENT RELAY MODULE
RTS	REMOTE TEST STATION FOR DUCT DETECTORS

1 | FIRST FLOOR PLAN
SCALE: 1/8"=1'-0"

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 01/22/14

Prepared For:
119 Development, LLC
P.O. Box 7468
Portland, ME 04112

Consultant:
CHS ENGINEERING
CONSTANCE HICKEY SCOTT, PE
7846 WOOD OAK COVE
CORDOVA, TN 38016
TEL: (901) 830-5300
EMAIL:chsscott@chsengineering.com

Architect:
ARCHETYPE architects
48 Union Wharf Portland, Maine 04101
(207) 772-6022 Fax (207) 772-4056

Project:
PRESS HOTEL
390 CONGRESS STREET
PORTLAND, ME 04101

Revisions:

1	13_10-14	Issue for Bid & Marriott Revw
2	13_10-21	Addendum #2
3	13_10-31	Addendum #3

Scale: As indicated

Date: 23 OCT 13

FIRST FLOOR
FIRE ALARM PLAN

FA1.03