## LEGEND

### DESCRIPTION

| | |
|---|---|
| FACP | FIRE ALARM CONTROL PANEL |
| FAA | FIRE ALARM ANNUNCIATOR PANEL |
| BDA | BI-DIRECTIONAL AMP FOR FIREMAN PHONE COMM |
| XPP | TRANSPONDER CABINET FOR FIRE PUMP MONITORING |
| XPA | TRANSPONDER CABINET FOR FIREMAN PHONE COMM REPEATER SYSTEM |
| XPE | TRANSPONDER CABINET FOR ELEVATOR CONTROL – RELAY BOARD |
| F | MANUAL PULL STATION |
| K | MONITOR MODULE/FUTURE KITCHEN HOOD |
| N | INTELLIGENT CONTROL MODULE FOR NAC CRKTS |
| S | SMOKE DETECTOR |
| $S_{SB}$ | SMOKE DETECTOR w/SOUNDER BASE |
| $S_C$ | SMOKE/CARBON MONOXIDE COMBINATION DETECTOR |
| D | DUCT SMOKE DETECTOR |
| G | CO2 GAS DETECTOR |
| H | HEAT DETECTOR |
| V | STROBE UNIT |
| H | HORN/STROBE UNIT |
| R | INTELLIGENT RELAY MODULE |
| RTS | REMOTE TEST STATION FOR DUCT DETECTORS |

1 | BASEMENT PLAN
SCALE: 1/8"=1'-0"

Project North
W E
S

Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 01/22/14

Prepared For:
119 Development, LLC
P.O. Box 7468
Portland, ME 04112

Consultant:
CHS ENGINEERING
CONSTANCE HICKEY SCOTT, PE
7846 WOOD OAK COVE
CORDOVA, TN 38016
TEL: (901) 830-5300
EMAIL:chscott@chsengineering.com

Architect:
ARCHETYPE architects
48 Union Wharf Portland, Maine 04101
(207) 772-6022 Fax (207) 772-4056

Project:
PRESS HOTEL
390 CONGRESS STREET
PORTLAND, ME 04101

Revisions:

| | | |
|---|---|---|
| 1 | 13_10-14 | Issue for Bid & Marriott Revw |
| 2 | 13_10-21 | Addendum #2 |
| 3 | 13_10-31 | Addendum #3 |

Scale: As indicated

Date: 23 OCT 13

BASEMENT PLAN

FA1.02