REFER TO DRAWINGS AND SCHEDULES BY KNLD AND STONEHILL TAYLOR FOR ADDITIONAL LIGHTING INFORMATION

REFER TO SHEET E4.02 AND E4.03 FOR LIGHTING CONTROL PANEL SCHEDULES AND DIAGRAMS

ALL EXIT LIGHTS SHALL BE CONNECTED TO UNSWITCHED HOT LEG OF NEAREST EMERGENCY POWER CIRCUIT.
ALL STORAGE AREA STRIPS SHALL BE TYPE 'BO1' AND SHALL BE CONTROLLED VIA CEILING MOUNTED OCC SENSOR IN SPACE.

1 | LOWER LEVEL LIGHTING PLAN
SCALE: 1/8"=1'-0"

Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 01/22/14

Prepared For:
119 Development, LLC
P.O. Box 7468
Portland, ME 04112

Consultant:
CHS ENGINEERING
CONSTANCE HICKEY SCOTT, PE
7846 WOOD OAK COVE
CORDOVA, TN 38016
TEL: (901) 830-5300
EMAIL:chsscott@chsengineering.com

Architect:
ARCHETYPE architects
48 Union Wharf Portland, Maine 04101
(207) 772-6022 Fax (207) 772-4056

Project:
PRESS HOTEL
390 CONGRESS STREET
PORTLAND, ME 04101

Revisions:

| | | |
|---|---|---|
| 1 | 13_10-14 | Issue for Bid & Marriott Revw |
| 2 | 13_10-21 | Addendum #2 |
| 3 | 13_10-31 | Addendum #3 |

Scale: As indicated

Date: 23 OCT 13

LOWER LEVEL LIGHTING PLAN

E1.02A