CELING LEGEND

CEILINGS TYPES

PAINTED EXPOSED STRUCTURE

RESTORED CONCRETE STRUCTURE TREATED WITH STAIN /SEALANT AS NOTED/APPROVED BY ARCHITECT

INSULATED CEILING

GYP BD. CEILING

2X4 ACOUSTIC TILE CEILING

WOOD SLAT CEILING

LIGHTING

RECESSED LIGHT

WALL SCONCE LIGHT

2X4 FL. LIGHT

1X4 FLUORESCENT TROFFER

TRACK LIGHTING

BATHROOM COVE FOR LIGHTING AND MECHANICAL

SEE ELECTRICAL DRAWINGS AND SPECIFICATIONS FOR LIGHTING TYPES

MECHANICAL

RETURN

SUPPLY

LINEAR SUPPLY

LINEAR RETURN

HEAT PUMP — HP

SEE MECHANICAL DRAWINGS AND SPECIFICATIONS FOR MECHANICAL UNITS AND DIFFUSER TYPES

LIFE SAFETY

EXIT LIGHT

LIFE SAFTY DEVICES, SEE ELEC. & FA DRAWINGS — H H V; S SSB F

SMOKE SCREEN — SMOKE SCREEN

SEE ELECTRICAL DRAWINGS AND SPECIFICATIONS FOR LIGHTING TYPES

A/V

GENERAL CEILING NOTES

1. FULL BUILDING; EXISTING BUILDING STRUCTURE IS COMPRISED OF A MIXTURE OF CONDITIONS INCLUDING; FIRE RATED STEEL & CONCRETE AND UNTREATED STRUCTURE. WORK IS TO COMPLY WITH CONSTRUCTION RATING REQUIREMENTS SHOW IN LIFESAFETY DOCUMENTS, COLUMN, WALL AND FLOOR UL ASSEMBILIES, TO PROVIDE FOR A FULL AND COMPLETE RATED BUILDING ASSEMBILIES AS NOTED GOVERNING CODES, REGULATIONS AND RATED ASSEMBILIES; INCLUDING BUT NOT LIMITED TO THE IBC, NFPA, AND BY THE AHJ. SEE A4.00-A4.03 FOR GENERAL CONSTRUCTION CONDITIONS.
2. SUBBASEMENT - TREAT PARTIALLY EXPOSED BEAMS WITH INTUMESCENT FIRE RATED PAINT.
3. LEVEL 1 RESTAURANT - REMOVE PLASTER & LATH BEAM WRAP TO CONCRETE BEAM WRAP. PLUG, PATCH AND RESTORE EXG CONCRETE TO LEVEL SPECIFIED BY RESTAURANT DESIGNER. RESTORATION TO INCLUDE CASTING OF CAPITALS AT COLUMNS TREATED WITH INTUMESCENT PAINT (5B & 5C).
4. LEVELS 2-7 GUESTROOMS ARE COMPRISED OF 3 GENERAL CEILING AREAS; ENTRY AREAS, BATHROOM BLOCK (BATHROOM, CLOSET, MISC), AND LOFTED GENERAL AREAS. CEILINGS IN ENTRY AND BATHROOM AREAS ARE TYPICALLY NOTED ON RCP.
5. LEVELS 2-7 GUESTROOMS; WHERE CLOSETS OCCUR AWAY FROM THE BATHROOM BLOCK PROVIDE GYPSUM CEILING AT THE HEIGHT OF THE BATHROOM WHETHER SHOWN OR NOT.
6. LEVELS 2-7 GUESTROOMS; IN LOFTED GENERAL AREAS APPLY 5/8" GYPSUM BD ON 1/2" HAT CHANNEL CEILINGS APPLIED TO DECK, TYPICALLY.
7. LEVELS 2-7 GUESTROOMS; IN ADDITION OR IN CONCERT WITH STRUCTURE RATING WORK WRAP ALL EXISTING BEAMS WITH GYPSUM AS SHOWN IN TYPICAL INTERIOR DETAILS , SEE TYPICAL GUEST ROOM BEAM WRAP IN A-400 SERIES.

1 | 7TH FLOOR - REFLECTED CEILING PLAN
1/8" = 1'-0"

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 01/22/14

Prepared For:
119 Development, LLC
P. O. Box 7486
Portland, ME 04112

Consultant:

Architect:
ARCHETYPE architects
48 Union Wharf Portland, Maine 04101
(207) 772-6022 Fax (207) 772-4056

Project:
PRESS HOTEL
390 CONGRESS STREET
PORTLAND, ME 04101

Revisions:
1 13_10-14 Issue for Bid & Marriott Revw

Date: 23 OCT 13
Scale: 1/8" = 1'-0"

SEVENTH FLOOR RCP

SK-03 & 04 REF. SH. NO : FULL SHEET ADD. NO : 2

ADDENDUM
A7.05