REFER TO SHEET E4.01 FOR MECHANICAL EQUIPMENT SCHEDULES AND MECHANICAL DRAWINGS FOR LOCATIONS OF ALL EQUIPMENT
REFER TO SHEET E1.01 FOR ADDITIONAL EQUIPMENT SCHEDULES

LAUNDRY EQUIPMENT SCHEDULE

CALLOUT	SYMBOL	VOLTS	KVA	CIRCUIT	WIRE CALLOUT
CHEM DISPENSER		120V 1P 2W	1.2	LDY-20	1/2"C,1#12,#12N,#12G
CHEM DISPENSER		120V 1P 2W	1.2	LDY-22	1/2"C,1#12,#12N,#12G
DRYER		208V 3P 3W	2.77	LDY-2,4,6	1/2"C,3#12,#12G
DRYER		208V 3P 3W	2.77	LDY-8,10,12	1/2"C,3#12,#12G
DRYER		208V 3P 3W	2.77	LDY-14,16,18	1/2"C,3#12,#12G
LINT COLLECTOR		208V 3P 3W	3.99	LDY-13,15,17	1/2"C,3#12,#12G
WASHER		208V 3P 3W	9.15	LDY-1,3,5	3/4"C,3#8,#10G
WASHER		208V 3P 3W	9.15	LDY-7,9,11	3/4"C,3#8,#10G

EQUIPMENT APPROXIMATED CONFIRM WITH LAUNDRY EQUIP SUPPLIER

1 | LOWER LEVEL POWER PLAN
SCALE: 1/8"=1'-0"

Project North
W E S

Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 01/22/14

Prepared For:
119 Development, LLC
P.O. Box 7468
Portland, ME 04112

Consultant:
CHS ENGINEERING
CONSTANCE HICKEY SCOTT, PE
7846 WOOD OAK COVE
CORDOVA, TN 38016
TEL: (901) 830-5300
EMAIL:chscott@chsengineering.com

Architect:
ARCHETYPE architects
48 Union Wharf Portland, Maine 04101
(207) 772-6022 Fax (207) 772-4056

Project:
PRESS HOTEL
390 CONGRESS STREET
PORTLAND, ME 04101

Revisions:

1	13_10-14	Issue for Bid & Marriott Revw
2	13_10-21	Addendum #2
3	13_10-31	Addendum #3

Scale: As indicated

Date: 23 OCT 13

LOWER LEVEL POWER PLAN

E1.02