



... Fire Protection by Computer Design

HIGH TECH FIRE PROTECTION
84 HACKETT MILLS ROAD
P.O. BOX 156
POLAND, ME 04274
207-998-2551

Job Name : Press Hotel 6th floor room 601 #6A
Drawing : FP-04
Location : 119 Exchange Street Portland
Remote Area : 6A
Contract : 110713-1
Data File : Calc #6A 6th floor Unit 601 (new h2o).WXF

HYDRAULIC CALCULATIONS
for

Project name: Press Hotel 6th floor room 601 #6A
Location: 119 Exchange Street Portland
Drawing no: FP-04
Date: 3/20/14

Design

Remote area number: 6A
Remote area location: 6th floor Unit 601
Occupancy classification: Residential / light hazard
Density: .1 - Gpm/SqFt
Area of application: 483 - SqFt
Coverage per sprinkler: 224 - SqFt
Type of sprinklers calculated: Residential Pendants
No. of sprinklers calculated: 4
In-rack demand: n/a - GPM
Hose streams: 100 - GPM
Total water required (including hose streams): 192 - GPM @ 75 - Psi
Type of system: Wet NFPA 13
Volume of dry or preaction system: n/a - Gal

Water supply information

Date: 5-12-2014
Location: Corner of Exchange Street and Federal St.
Source: Portland Water District

Name of contractor: High Tech Fire Protection
Address: 84 Hackett Mills Road Poland / P.O. Box 154 Minot, ME / Pola
Phone number: 207-998-2551
Name of designer: Ed Poulin
Authority having jurisdiction: State of Maine / City of Portland
Notes: (Include peaking information or gridded systems here.)


Water Supply Curve (C)

HIGH TECH FIRE PROTECTION
Press Hotel 6th floor room 601 #6A

Page 2
Date 3/20/14

City Water Supply:
C1 - Static Pressure : 84
C2 - Residual Pressure: 80
C2 - Residual Flow : 1209

Demand:
D1 - Elevation : 27.935
D2 - System Flow : 91.677
D2 - System Pressure : 74.947
Hose (Demand) : 100
D3 - System Demand : 191.677
Safety Margin : 8.921



Fittings Used Summary

HIGH TECH FIRE PROTECTION
 Press Hotel 6th floor room 601 #6A

Page 3
 Date 3/20/14

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
F	NFPA 13 45' Elbow	1	1	1	1	2	2	3	3	3	4	5	7	9	11	13	17	19	21	24	28
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																			
G	NFPA 13 Gate Valve	0	0	0	0	1	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
N *	CPVC 90'EI Harvel-Spears		7	7	8	9	11	12	13	0	0	0	0	0	0	0	0	0	0	0	0
O *	CPVC Tee - Branch	3	3	5	6	8	10	12	15	0	0	0	0	0	0	0	0	0	0	0	0
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65					
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
V	90' EI Firelock #001	0	0	0	0	0	3.5	4.3	5	0	6.8	8.5	10	13	0	0	0	0	0	0	0
X	90'Tee-BranchFirelock002	0	0	0	0	0	8.5	10.8	13	0	16	21	25	33	0	0	0	0	0	0	0
Zia	Wilkins 350	Fitting generates a Fixed Loss Based on Flow																			

Units Summary

Diameter Units	Inches
Length Units	Feet
Flow Units	US Gallons per Minute
Pressure Units	Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Pressure / Flow Summary - STANDARD

HIGH TECH FIRE PROTECTION
 Press Hotel 6th floor room 601 #6A

Page 4
 Date 3/20/14

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
DP1	-1.0	5.8	14.92	na	22.4	0.1	224	7.5
600	67.5	5.8	14.92	na	22.4	0.1	224	13.2
601	67.5	K = K @ EQ01	15.17	na	22.54			
602	67.5		16.11	na				
603	67.5	5.8	16.1	na	23.27	0.1	224	13.2
604	67.5	K = K @ EQ01	16.45	na	23.47			
605	67.5		17.25	na				
606	67.5		21.66	na				
615	67.5		26.72	na				
616	67.5		28.8	na				
617	67.5		30.38	na				
SR6	57.0		41.65	na				
SR51	57.0		41.69	na				
SR5	14.0		60.5	na				
SR1	14.0		60.76	na				
SR11	14.0		60.9	na				
SR0	0.0		67.01	na				
SR01	0.0		67.37	na				
SR02	0.0		68.37	na				
SR03	0.0		68.42	na				
TOR	-4.0		70.44	na				
BOR	-6.0		74.32	na				
BASE	-6.0		78.67	na				
HS1	-4.0		77.83	na				
HS2	-4.0		77.85	na				
HS3	-4.0		77.93	na	100.0			
TEST	3.0		74.95	na				

The maximum velocity is 14.67 and it occurs in the pipe between nodes 605 and 606

Final Calculations - Hazen-Williams

HIGH TECH FIRE PROTECTION
 Press Hotel 6th floor room 601 #6A

Page 5
 Date 3/20/14

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
DP1 to EQ01	22.40 22.4	1.101 150.0 0.0838	1O	5.0 0.0 0.0	1.000 5.000 6.000	14.916 -0.433 0.503			K Factor = 5.80 Vel = 7.55	
	0.0 22.40						14.986		K Factor = 5.79	
600 to 601	22.40 22.4	1.101 150.0 0.0837		0.0 0.0 0.0	3.000 0.0 3.000	14.916 0.0 0.251			K Factor = 5.80 Vel = 7.55	
601 to 602	22.54 44.94	1.394 150.0 0.0964	1N	8.0 0.0 0.0	1.750 8.000 9.750	15.167 0.0 0.940			K Factor @ node EQ01 Vel = 9.45	
602 to 605	0.0 44.94	1.394 150.0 0.0964		0.0 0.0 0.0	11.900 0.0 11.900	16.107 0.0 1.147			Vel = 9.45	
	0.0 44.94						17.254		K Factor = 10.82	
603 to 604	23.27 23.27	1.101 150.0 0.0900		0.0 0.0 0.0	3.900 0.0 3.900	16.100 0.0 0.351			K Factor = 5.80 Vel = 7.84	
604 to 605	23.47 46.74	1.394 150.0 0.1036	1O	6.0 0.0 0.0	1.750 6.000 7.750	16.451 0.0 0.803			K Factor @ node EQ01 Vel = 9.83	
605 to 606	44.94 91.68	1.598 150.0 0.1854	1N	9.0 0.0 0.0	14.750 9.000 23.750	17.254 0.0 4.404			Vel = 14.67	
606 to 615	0.0 91.68	2.003 150.0 0.0617		0.0 0.0 0.0	82.000 0.0 82.000	21.658 0.0 5.060			Vel = 9.33	
615 to 616	0.0 91.68	2.067 120.0 0.0800		0.0 0.0 0.0	1.000 0.0 1.000	26.718 2.000 0.080			* Fixed loss = 2 Vel = 8.77	
616 to 617	0.0 91.68	2.003 120.0 0.0932		0.0 0.0 0.0	17.000 0.0 17.000	28.798 0.0 1.585			Vel = 9.33	
617 to SR6	0.0 91.68	2.157 120.0 0.0650	1B 1Fsp 1S 2X 1V	7.384 0.0 13.537 20.921 4.307	11.000 46.149 57.149	30.383 7.548 3.715			* Fixed loss = 3 Vel = 8.05	
SR6 to SR51	0.0 91.68	4.26 120.0 0.0024	1V	8.954 0.0 0.0	10.500 8.954 19.454	41.646 0.0 0.046			Vel = 2.06	
SR51 to SR5	0.0 91.68	4.26 120.0 0.0024	4V	35.814 0.0 0.0	41.000 35.814 76.814	41.692 18.623 0.182			Vel = 2.06	
SR5 to SR1	0.0 91.68	4.26 120.0 0.0024	7V	62.675 0.0 0.0	50.000 62.675 112.675	60.497 0.0 0.266			Vel = 2.06	

Final Calculations - Hazen-Williams

HIGH TECH FIRE PROTECTION
 Press Hotel 6th floor room 601 #6A

Page 6
 Date 3/20/14

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
SR1 to SR11	0.0 91.68	4.26 120.0 0.0024	3V	26.861 0.0 0.0	32.000 26.861 58.861	60.763 0.0 0.139		Vel = 2.06		
SR11 to SR0	0.0 91.68	4.26 120.0 0.0024	1V	8.954 0.0 0.0	10.000 8.954 18.954	60.902 6.063 0.046		Vel = 2.06		
SR0 to SR01	0.0 91.68	4.26 120.0 0.0024	3V 1B 1X 1F	26.861 15.8 21.067 5.267	81.500 68.995 150.495	67.011 0.0 0.355		Vel = 2.06		
SR01 to SR02	0.0 91.68	4.26 120.0 0.0030		0.0 0.0 0.0	1.000 0.0 1.000	67.366 1.000 0.003		* Fixed loss = 1 Vel = 2.06		
SR02 to SR03	0.0 91.68	4.26 120.0 0.0023	1X	21.067 0.0 0.0	2.000 21.067 23.067	68.369 0.0 0.054		Vel = 2.06		
SR03 to TOR	0.0 91.68	4.26 120.0 0.0024	2V 1X	17.907 21.067 0.0	81.000 38.974 119.974	68.423 1.732 0.284		Vel = 2.06		
TOR to BOR	0.0 91.68	4.26 120.0 0.0025	1Fsp	0.0 0.0 0.0	4.000 0.0 4.000	70.439 3.866 0.010		* Fixed loss = 3 Vel = 2.06		
BOR to BASE	0.0 91.68	4.26 120.0 0.0020	1Zia	0.0 0.0 0.0	1.000 0.0 1.000	74.315 4.348 0.002		* Fixed loss = 4.348 Vel = 2.06		
BASE to HS1	0.0 91.68	6.14 100.0 0.0006	1G 1E 1T	2.273 10.608 22.732	25.000 35.613 60.613	78.665 -0.866 0.034		Vel = 0.99		
HS1 to HS2	0.0 91.68	8.23 100.0 0.0001	1T	29.011 0.0 0.0	90.000 29.010 119.010	77.833 0.0 0.016		Vel = 0.55		
HS2 to HS3	0.0 91.68	6.14 100.0 0.0006	1T	22.732 0.0 0.0	120.000 22.732 142.732	77.849 0.0 0.079		Vel = 0.99		
HS3 to TEST	100.00 191.68	6.14 100.0 0.0022	1G 1E	2.273 10.608 0.0	10.000 12.881 22.881	77.928 -3.032 0.051		Qa = 100 Vel = 2.08		
	0.0 191.68					74.947		K Factor = 22.14		