



... Fire Protection by Computer Design

HIGH TECH FIRE PROTECTION
84 HACKETT MILLS ROAD
P.O. BOX 156
POLAND, ME 04274
207-998-2551

Job Name : Press Hotel 7th floor room 701 #7A
Drawing : FP-05
Location : 119 Exchange Street Portland
Remote Area : 7A
Contract : 110713-1
Data File : Calc #7A 7th floor Unit 701 (new h2o).W XF

HYDRAULIC CALCULATIONS
for

Project name: Press Hotel 7th floor room 701 #7A
Location: 119 Exchange Street Portland
Drawing no: FP-05
Date: 3/20/14

Design

Remote area number: 7A
Remote area location: 7th floor Unit 701
Occupancy classification: Residential / lighthazard
Density: .1 - Gpm/SqFt
Area of application: 483 - SqFt
Coverage per sprinkler: 224 - SqFt
Type of sprinklers calculated: Residential Pendants
No. of sprinklers calculated: 4
In-rack demand: n/a - GPM
Hose streams: 100 - GPM
Total water required (including hose streams): 193 - GPM @ 76 - Psi
Type of system: Wet NFPA 13
Volume of dry or preaction system: n/a - Gal

Water supply information

Date: 5-12-2014
Location: Corner of Exchange Street and Federal St.
Source: Portland Water District

Name of contractor: High Tech Fire Protection
Address: 84 Hackett Mills Road Poland / P.O. Box 154 Minot, ME / Poland
Phone number: 207-998-2551
Name of designer: Ed Poulin
Authority having jurisdiction: State of Maine / City of Portland
Notes: (Include peaking information or gridded systems here.)


Water Supply Curve (C)

HIGH TECH FIRE PROTECTION
Press Hotel 7th floor room 701 #7A

Page 2
Date 3/20/14

City Water Supply:
C1 - Static Pressure : 84
C2 - Residual Pressure: 80
C2 - Residual Flow : 1209

Demand:
D1 - Elevation : 32.482
D2 - System Flow : 92.484
D2 - System Pressure : 75.910
Hose (Demand) : 100
D3 - System Demand : 192.484
Safety Margin : 7.957



Fittings Used Summary

HIGH TECH FIRE PROTECTION
 Press Hotel 7th floor room 701 #7A

Page 3
 Date 3/20/14

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
F	NFPA 13 45' Elbow	1	1	1	1	2	2	3	3	3	4	5	7	9	11	13	17	19	21	24	28
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																			
G	NFPA 13 Gate Valve	0	0	0	0	1	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
N *	CPVC 90'EI Harvel-Spears		7	7	8	9	11	12	13	0	0	0	0	0	0	0	0	0	0	0	0
O *	CPVC Tee - Branch	3	3	5	6	8	10	12	15	0	0	0	0	0	0	0	0	0	0	0	0
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65					
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
V	90' EI Firelock #001	0	0	0	0	0	3.5	4.3	5	0	6.8	8.5	10	13	0	0	0	0	0	0	0
X	90'Tee-BranchFirelock002	0	0	0	0	0	8.5	10.8	13	0	16	21	25	33	0	0	0	0	0	0	0
Zia	Wilkins 350	Fitting generates a Fixed Loss Based on Flow																			

Units Summary

Diameter Units	Inches
Length Units	Feet
Flow Units	US Gallons per Minute
Pressure Units	Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Pressure / Flow Summary - STANDARD

HIGH TECH FIRE PROTECTION
 Press Hotel 7th floor room 701 #7A

Page 4
 Date 3/20/14

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
DP1	-1.0	5.8	14.92	na	22.4	0.1	224	7.5
DP2	-1.0	5.8	14.92	na	22.4	0.1	224	7.5
700	78.0	K = K @ EQ01	15.39	na	22.57			
701	78.0	5.8	14.92	na	22.4	0.1	224	13.2
702	78.0		15.59	na				
703	78.0	K = K @ EQ02	16.53	na	23.52			
704	78.0	5.8	17.1	na	23.98	0.1	224	13.2
705	78.0		17.95	na				
706	78.0		19.66	na				
715	78.0		24.91	na				
716	78.0		26.99	na				
717	78.0		28.66	na				
SR7	78.0		33.39	na				
SR61	67.5		37.98	na				
SR6	57.0		42.56	na				
SR51	57.0		42.61	na				
SR5	14.0		61.42	na				
SR1	14.0		61.69	na				
SR11	14.0		61.83	na				
SR0	0.0		67.94	na				
SR01	0.0		68.3	na				
SR02	0.0		69.3	na				
SR03	0.0		69.38	na				
TOR	-4.0		71.4	na				
BOR	-6.0		75.28	na				
BASE	-6.0		79.63	na				
HS1	-4.0		78.79	na				
HS2	-4.0		78.81	na				
HS3	-4.0		78.89	na	100.0			
TEST	3.0		75.91	na				

The maximum velocity is 14.4 and it occurs in the pipe between nodes 703 and 705

Final Calculations - Hazen-Williams

HIGH TECH FIRE PROTECTION
 Press Hotel 7th floor room 701 #7A

Page 5
 Date 3/20/14

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
DP1 to EQ01	22.40 22.4	1.101 150.0 0.0839	1N	7.0 0.0 0.0	1.000 7.000 8.000	14.916 -0.433 0.671			K Factor = 5.80 Vel = 7.55	
	0.0 22.40						15.154		K Factor = 5.75	
DP2 to EQ02	22.40 22.4	1.101 150.0 0.0838	1O	5.0 0.0 0.0	1.000 5.000 6.000	14.916 -0.433 0.503			K Factor = 5.80 Vel = 7.55	
	0.0 22.40						14.986		K Factor = 5.79	
700 to 702	22.57 22.57	1.101 150.0 0.0852		0.0 0.0 0.0	2.300 0.0 2.300	15.391 0.0 0.196			K Factor @ node EQ01 Vel = 7.61	
	0.0 22.57						15.587		K Factor = 5.72	
701 to 702	22.40 22.4	1.101 150.0 0.0839	1O	5.0 0.0 0.0	3.000 5.000 8.000	14.916 0.0 0.671			K Factor = 5.80 Vel = 7.55	
702 to 703	22.57 44.97	1.394 150.0 0.0965		0.0 0.0 0.0	9.750 0.0 9.750	15.587 0.0 0.941			Vel = 9.45	
703 to 705	23.53 68.5	1.394 150.0 0.2104	1O	6.0 0.0 0.0	0.750 6.000 6.750	16.528 0.0 1.420			K Factor @ node EQ02 Vel = 14.40	
	0.0 68.50						17.948		K Factor = 16.17	
704 to 705	23.98 23.98	1.101 150.0 0.0953	1O	5.0 0.0 0.0	3.900 5.000 8.900	17.100 0.0 0.848			K Factor = 5.80 Vel = 8.08	
705 to 706	68.50 92.48	2.003 150.0 0.0627	1N	11.0 0.0 0.0	16.300 11.000 27.300	17.948 0.0 1.712			Vel = 9.42	
706 to 715	0.0 92.48	2.003 150.0 0.0627		0.0 0.0 0.0	83.750 0.0 83.750	19.660 0.0 5.253			Vel = 9.42	
715 to 716	0.0 92.48	2.067 120.0 0.0810		0.0 0.0 0.0	1.000 0.0 1.000	24.913 2.000 0.081			* Fixed loss = 2 Vel = 8.84	
716 to 717	0.0 92.48	2.157 150.0 0.0437	1V	6.509 0.0 0.0	31.500 6.509 38.009	26.994 0.0 1.662			Vel = 8.12	
717 to SR7	0.0 92.48	2.157 120.0 0.0661	1B 1Fsp 1S 1V	7.384 0.0 13.537 4.307	1.000 25.228 26.228	28.656 3.000 1.733			* Fixed loss = 3 Vel = 8.12	
SR7 to SR61	0.0 92.48	4.26 120.0 0.0024	1V	8.954 0.0 0.0	10.500 8.954 19.454	33.389 4.548 0.046			Vel = 2.08	

Final Calculations - Hazen-Williams

HIGH TECH FIRE PROTECTION
 Press Hotel 7th floor room 701 #7A

Page 6
 Date 3/20/14

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
SR61 to SR6	0.0 92.48	4.26 120.0 0.0024	1V	8.954 0.0	5.100 8.954	37.983 4.548		Vel = 2.08		
SR6 to SR51	0.0 92.48	4.26 120.0 0.0024	1V	8.954 0.0	10.500 8.954	42.565 0.0		Vel = 2.08		
SR51 to SR5	0.0 92.48	4.26 120.0 0.0024	4V	35.814 0.0	41.000 35.814	42.612 18.623		Vel = 2.08		
SR5 to SR1	0.0 92.48	4.26 120.0 0.0024	7V	62.675 0.0	50.000 62.675	61.419 0.0		Vel = 2.08		
SR1 to SR11	0.0 92.48	4.26 120.0 0.0024	3V	26.861 0.0	32.000 26.861	61.690 0.0		Vel = 2.08		
SR11 to SR0	0.0 92.48	4.26 120.0 0.0024	1V	8.954 0.0	10.000 8.954	61.831 6.063		Vel = 2.08		
SR0 to SR01	0.0 92.48	4.26 120.0 0.0024	3V 1B 1X 1F	26.861 15.8 21.067 5.267	81.500 68.995 150.495	67.940 0.0 0.362		Vel = 2.08		
SR01 to SR02	0.0 92.48	4.26 120.0 0.0020		0.0 0.0	1.000 0.0	68.302 1.000		* Fixed loss = 1 Vel = 2.08		
SR02 to SR03	0.0 92.48	4.26 120.0 0.0024	1S	28.968 0.0	2.000 28.968	69.304 0.0		Vel = 2.08		
SR03 to TOR	0.0 92.48	4.26 120.0 0.0024	2V 1X	17.907 21.067	81.000 38.974	69.379 1.732		Vel = 2.08		
TOR to BOR	0.0 92.48	4.26 120.0 0.0025	1Fsp	0.0 0.0	4.000 0.0	71.399 3.866		* Fixed loss = 3 Vel = 2.08		
BOR to BASE	0.0 92.48	4.26 120.0 0.0020	1Zia	0.0 0.0	1.000 0.0	75.275 4.348		* Fixed loss = 4.348 Vel = 2.08		
BASE to HS1	0.0 92.48	6.14 100.0 0.0006	1G 1E 1T	2.273 10.608 22.732	25.000 35.613 60.613	79.625 -0.866 0.035		Vel = 1.00		
HS1 to HS2	0.0 92.48	8.23 100.0 0.0001	1T	29.011 0.0	90.000 29.010	78.794 0.0		Vel = 0.56		
HS2 to HS3	0.0 92.48	6.14 100.0 0.0006	1T	22.732 0.0	120.000 22.732	78.810 0.0		Vel = 1.00		
HS3 to TEST	100.00 192.48	6.14 100.0 0.0022	1G 1E	2.273 10.608	10.000 12.881	78.891 -3.032		Qa = 100 Vel = 2.09		

Final Calculations - Hazen-Williams

HIGH TECH FIRE PROTECTION
 Press Hotel 7th floor room 701 #7A

Page 7
 Date 3/20/14

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
	0.0 192.48				75.910				K Factor = 22.09