FIRE ALARM CONTROL PANEL

CABINET # 1 – BASEMENT
ELECTRICAL ROOM 007

FIRE ALARM CONTROL PANEL

CABINET # 2 – BASEMENT
ELECTRICAL ROOM 007

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 04/03/15

tyco Simplexgrinnell
Safer. Smarter. Tyco.™

DISTRICT - 147
20 THOMAS DRIVE
WESTBROOK, ME 04092
SERVICE: 207-842-6440
PHONE: 20
FAX: 20

PRESS HOTEL

PRESS HOTEL
119 EXCHANGE ST
PORTLAND, ME

ISSUE LOG:				
MARK	DATE	CAD	CHK	DESCRIPTION
1	5-28-14	JD	KG	REVISED PER ENGINEERS COMMENTS & ADDED FOR SYSTEM

Revisions shown with 1 cloud

DRAWN BY:	JD
CHECKED BY:	KG
ISSUE DATE:	4/24/14
JOB #:	977465501
PROJECT #:	147:PRE-BOOKED

SIMPLEXGRINNELL © 2013

SYSTEM:
FIRE ALARM SYSTEM

SHEET:
PANEL DETAIL

FA-501

IMPORTANT NOTICE TO USER: By accepting or using this drawing, you are agreed to the following terms and conditions. The electronic information in the drawing may not be altered or transferred to any third party, used for other projects or additions to this project for which it was prepared, or used for completion of this project by any third party. SimplexGrinnell disclaims all liability by the user or any third party and such use will be a user's sole risk. User shall, to the fullest extent permitted by law, defend, indemnify, and hold SimplexGrinnell harmless from any and all claims for loss, damage or injury arising directly or indirectly therefrom.

LAST SAVED BY: JUDELACRUZ
LAST PRINTED: 5/29/2014 3:08:36 PM
24" x 36" - Arch D Size