A1: ENHANCED POWER SUPPLY - CHANNEL 1					SWITCH SETTINGS							
IDNac Number	Device Type	PID	Candela	Custom Label (Max 40 Characters)								
A1:1-1	FA_HornStrobe	49AV-WRF	30cd	SUB-BASEMENT-MECHANICAL B21	X							ON
A1:1-2	FA_HornStrobe	49AV-WRF	30cd	SUB-BASEMENT-UNFINISHED B22		X						ON
A1:1-3	FA_HornStrobe	49AV-WRF	15cd	SUB-BASEMENT-UNFINISHED B22	X	X						ON
A1:1-4	FA_HornStrobe	49AV-WRF	15cd	SUB-BASEMENT-UNFINISHED B22			X					ON
A1:1-5	FA_HornStrobe	49AV-WRF	30cd	SUB-BASEMENT-UNFINISHED B22	X		X					ON
A1:1-6	FA_HornStrobe	49AV-WRF	30cd	SUB-BASEMENT-HALL B20		X	X					ON
A1:1-7	FA_HornStrobe	49AV-WRF	30cd	SUB-BASEMENT-HALL B20	X	X	X					ON
A1:1-8	FA_HornStrobe	49AV-WRF	15cd	SUB-BASEMENT-HALL B20				X				ON
A1:1-9	FA_HornStrobe	49AV-WRF	15cd	SUB-BASEMENT-HALL B20	X			X				ON
A1:1-10	FA_HornStrobe	49AV-WRF	15cd	SUB-BASEMENT-CORRIDOR B00		X		X				ON
A1:1-11	FA_HornStrobe	49AV-WRF	15cd	SUB-BASEMENT-ELEV. VEST.	X	X		X				ON
A1:1-12	FA_HornStrobe	49AV-WRF	30cd	SUB-BASEMENT-ELEV. VEST.			X	X				ON
A1:1-13	FA_HornStrobe	49AV-WRF	30cd	SUB-BASEMENT-DRY STORAGE B10	X		X	X				ON
A1:1-14	FA_HornStrobe	49AV-WRF	15cd	SUB-BASEMET-UNFINISHED B04		X	X	X				ON
A1:1-15	FA_HornStrobe	49AV-WRF	15cd	SUB-BASEMET-UNFINISHED B04	X	X	X	X				ON
A1:1-16	FA_HornStrobe	49AV-WRF	15cd	SUB-BASEMET-UNFINISHED B04				X				ON
A1:1-17	FA_HornStrobe	49AV-WRF	15cd	SUB-BASEMET-UNFINISHED B04	X			X				ON
A1:1-18	FA_HornStrobe	49AV-WRF	15cd	SUB-BASEMET-UNFINISHED B04		X		X				ON
A1:1-19	FA_HornStrobe	49AV-WRF	15cd	SUB-BASEMET-UNFINISHED B04	X	X		X				ON
A1:1-20	FA_HornStrobe	49AV-WRF	15cd	SUB-BASEMET-UNFINISHED B04			X	X				ON

A1: ENHANCED POWER SUPPLY - CHANNEL 2					SWITCH SETTINGS							
IDNac Number	Device Type			Custom Label (Max 40 Characters)								
A1:2-1	FA_HornStrobe	49AV-WRF	15cd	BASEMENT-ELEC. ROON 007	X							ON
A1:2-2	FA_HornStrobe	49AV-WRF	15cd	BASEMENT-MAINT. SHOP 008A		X						ON
A1:2-3	FA_HornStrobe	49AV-WRF	15cd	BASEMENT-MAINT. SHOP 008A	X	X						ON
A1:2-4	FA_HornStrobe	49AV-WRF	15cd	BASEMENT-ELEV. VEST. 020			X					ON
A1:2-5	FA_HornStrobe	49AV-WRF	75cd	BASEMENT-LAUNDRY 021	X		X					ON
A1:2-6	FA_HornStrobe	49AV-WRF	15cd	BASEMENT-ADMIN 022		X	X					ON
A1:2-7	FA_HornStrobe	49AV-WRF	15cd	BASEMENT-STAIR A 00A	X	X	X					ON
A1:2-8	FA_HornStrobe	49AV-WRF	15cd	BASEMENT-STAIR A 00A				X				ON
A1:2-9	FA_HornStrobe	49AV-WRF	15cd	BASEMENT-CORRIDOR 000C	X			X				ON
A1:2-10	FA_HornStrobe	49AV-WRF	15cd	BASEMENT-EMPLOYEE BREAK ROOM 023		X		X				ON
A1:2-11	FA_Strobe	49VO-WRF	15cd	BASEMENT-MENS 024	X	X		X				ON
A1:2-12	FA_Strobe	49VO-WRF	15cd	BASEMENT-WOMENTS 025			X	X				ON
A1:2-13	FA_HornStrobe	49AV-WRF	15cd	BASEMENT-FITNESS 026	X		X	X				ON
A1:2-14	FA_HornStrobe	49AV-WRF	15cd	BASEMENT-FITNESS 026		X	X	X				ON
A1:2-15	FA_Strobe	49VO-WRF	15cd	BASEMENT- CORRIDOR 000B	X	X	X	X				ON
A1:2-16	FA_HornStrobe	49AV-WRF	15cd	BASEMENT- CORRIDOR 000B					X			ON
A1:2-17	FA_HornStrobe	49AV-WRF	15cd	BASEMENT- CORRIDOR 000B	X				X			ON
A1:2-18	FA_HornStrobe	49AV-WRF	15cd	BASEMENT- CORRIDOR 000C		X			X			ON
A1:2-19	FA_HornStrobe	49AV-WRF	30cd	BASEMENT-PANTRY 021B	X	X			X			ON

A1: ENHANCED POWER SUPPLY - CHANNEL 3					SWITCH SETTINGS							
IDNac Number	Device Type			Custom Label (Max 40 Characters)								
A1:3-1	FA_HornStrobe	49AV-WRF	15cd	BASEMENT-ELEC. 006	X							ON
A1:3-2	FA_HornStrobe	49AV-WRF	30cd	BASEMENT-PREFUNCTION/GALLERY 000		X						ON
A1:3-3	FA_HornStrobe	49AV-WRF	15cd	BASEMENT-MEETING ROOM #2 005	X	X						ON
A1:3-4	FA_HornStrobe	49AV-WRF	15cd	BASEMENT-MEETING ROOM #2 005			X					ON
A1:3-5	FA_HornStrobe	49AV-WRF	15cd	BASEMENT-MEETING ROOM #2 005	X		X					ON
A1:3-6	FA_HornStrobe	49AV-WRF	15cd	BASEMENT-PREFUNCTION/GALLERY 000		X	X					ON
A1:3-7	FA_HornStrobe	49AV-WRF	15cd	BASEMENT-WOMENS 004	X	X	X					ON
A1:3-8	FA_HornStrobe	49AV-WRF	15cd	BASEMENT-MEN 003				X				ON
A1:3-9	FA_HornStrobe	49AV-WRF	15cd	BASEMENT-STORAGE VESTIBULE 012	X			X				ON
A1:3-10	FA_HornStrobe	49AV-WRF	15cd	BASEMENT-STAIR B 00B		X		X				ON
A1:3-11	FA_HornStrobe	49AV-WRF	30cd	BASEMENT-MEETING ROOM #1B 001B	X	X		X				ON
A1:3-12	FA_HornStrobe	49AV-WRF	30cd	BASEMENT-MEETING ROOM #1B 001B			X	X				ON
A1:3-13	FA_HornStrobe	49AV-WRF	15cd	BASEMENT-MEETING ROOM #1B 001B	X		X	X				ON
A1:3-14	FA_HornStrobe	49AV-WRF	30cd	BASEMENT-MEETING ROOM #1B 001B		X	X	X				ON
A1:3-15	FA_HornStrobe	49AV-WRF	15cd	BASEMENT-BOH 001C	X	X	X	X				ON
A1:3-16	FA_HornStrobe	49AV-WRF	15cd	BASEMENT-BOH 001C					X			ON
A1:3-17	FA_HornStrobe	49AV-WRF	15cd	BASEMENT-BOH ACCESS 011	X				X			ON
A1:3-18	FA_HornStrobe	49AV-WRF	15cd	BASEMENT-BOH ACCESS 011		X			X			ON
A1:3-19	FA_HornStrobe	49AV-WRF	15cd	BASEMENT-BOARD ROOM 010	X	X			X			ON
A1:3-20	FA_HornStrobe	49AV-WRF	30cd	BASEMENT-PREFUNCTION/GALLERY 000			X		X			ON

A2: ENHANCED POWER SUPPLY - CHANNEL 1					SWITCH SETTINGS							
IDNac Number	Device Type	PID	Candela	Custom Label (Max 40 Characters)								
A2:1-1	FA_HornStrobe	49AV-WRF	15cd	1ST FL-MARKET ENTRY 121	X							ON
A2:1-2	FA_HornStrobe	49AV-WRF	15cd	1ST FL-MARKET ENTRY 121		X						ON
A2:1-3	FA_Strobe	49VO-WRF	15cd	1ST FL-SERVICE ELEV.	X	X						ON
A2:1-4	FA_HornStrobe	49AV-WRF	30cd	1ST FL- RESTAURANT 131			X					ON
A2:1-5	FA_HornStrobe	49AV-WRF	30cd	1ST FL- RESTAURANT 131	X		X					ON
A2:1-6	FA_HornStrobe	49AV-WRF	15cd	1ST FL- RESTAURANT 131		X	X					ON
A2:1-7	FA_HornStrobe	49AV-WRF	15cd	1ST FL- RESTAURANT 131	X	X	X					ON
A2:1-8	FA_HornStrobe	49AV-WRF	15cd	1ST FL- RESTAURANT 131				X				ON
A2:1-9	FA_HornStrobe	49AV-WRF	15cd	1ST FL- RESTAURANT 131	X			X				ON
A2:1-10	FA_HornStrobe	49AV-WRF	15cd	1ST FL- CONGRESS ENTRY 120		X		X				ON
A2:1-11	FA_HornStrobe	49AV-WRF	15cd	1ST FL- RESTAURANT 131	X	X		X				ON
A2:1-12	FA_HornStrobe	49AV-WRF	15cd	1ST FL- RESTAURANT 131		X	X					ON
A2:1-13	FA_HornStrobe	49AV-WRF	15cd	1ST FL- RESTAURANT 131	X		X	X				ON
A2:1-14	FA_HornStrobe	49AV-WRF	15cd	1ST FL- RESTAURANT 131		X	X	X				ON
A2:1-15	FA_HornStrobe	49AV-WRF	15cd	1ST FL- RESTAURANT 131	X	X	X	X				ON
A2:1-16	FA_HornStrobe	49AV-WRF	15cd	1ST FL- RESTAURANT 131					X			ON
A2:1-17	FA_HornStrobe	49AV-WRF	15cd	1ST FL- RESTAURANT 131	X				X			ON
A2:1-18	FA_Strobe	49VO-WRF	15cd	1ST FL- ELEV. LOBBY 124		X			X			ON
A2:1-19	FA_HornStrobe	49AV-WRF	15cd	1ST FL- EXCHANGE ENTRY 123	X	X			X			ON
A2:1-20	FA_StrobeWP	49AV-WRFO	75cd	1ST FL- EXCHANGE ENTRY 123			X		X			ON
A2:1-21	FA_StrobeWP	49AC-WRFO	75cd	1ST FL-MARKET ENTRY 121	X		X		X			ON

A2: ENHANCED POWER SUPPLY - CHANNEL 2					SWITCH SETTINGS							
IDNac Number	Device Type			Custom Label (Max 40 Characters)								
A2:2-1	FA_HornStrobe	49AV-WRF	30cd	1ST FL-RECEPTION 110	X							ON
A2:2-2	FA_HornStrobe	49AV-WRF	15cd	1ST FL-OFFICE 112		X						ON
A2:2-3	FA_HornStrobe	49AV-WRF	15cd	1ST FL-FLEX SPACE 103	X	X						ON
A2:2-4	FA_HornStrobe	49AV-WRF	15cd	1ST FL-FLEX SPACE 103			X					ON
A2:2-5	FA_HornStrobe	49AV-WRF	15cd	1ST FL-LOBBY 100	X		X					ON
A2:2-6	FA_Strobe	49VO-WRF	15cd	1ST FL-WOMENS 102		X	X					ON
A2:2-7	FA_Strobe	49VO-WRF	15cd	1ST FL-MENS 101	X	X	X					ON
A2:2-8	FA_Strobe	49VO-WRF	15cd	1ST FL-WOMENS 102				X				ON
A2:2-9	FA_HornStrobe	49AV-WRF	15cd	1ST FL-STAIR B	X			X				ON
A2:2-10	FA_HornStrobe	49AV-WRF	15cd	1ST FL-FEDERAL ENTRY 122		X		X				ON
A2:2-11	FA_HornStrobe	49AV-WRF	15cd	1ST FL-FEDERAL ENTRY 122	X	X		X				ON
A2:2-12	FA_HornStrobe	49AV-WRF	15cd	1ST FL-LOBBY 100			X	X				ON
A2:2-13	FA_HornStrobe	49AV-WRF	30cd	1ST FL-LOBBY 100	X		X	X				ON
A2:2-14	FA_HornStrobe	49AV-WRF	15cd	1ST FL-LOBBY 100		X	X	X				ON
A2:2-15	FA_HornStrobe	49AV-WRF	15cd	1ST FL-LOBBY 100	X	X	X	X				ON
A2:2-16	FA_HornStrobe	49AV-WRF	15cd	1ST FL-LOBBY 100					X			ON

A2: ENHANCED POWER SUPPLY - CHANNEL 3					SWITCH SETTINGS							
IDNac Number	Device Type			Custom Label (Max 40 Characters)								
A2:3-1	FA_HornStrobe	49AV-WRF	15cd	2ND FL-STAIR A 20A	X							ON
A2:3-2	FA_HornStrobe	49AV-WRF	15cd	2ND FL-CORRIDOR 200		X						ON
A2:3-3	FA_HornStrobe	49AV-WRF	15cd	2ND FL-CORRIDOR 200	X	X						ON
A2:3-4	FA_HornStrobe	49AV-WRF	15cd	2ND FL-CORRIDOR 200			X					ON
A2:3-5	FA_Strobe	49VO-WRF	15cd	2ND FL-CORRIDOR 200	X		X					ON
A2:3-6	FA_Strobe	49VO-WRF	15cd	2ND FL-DOUBLE DOUBLE 207		X	X					ON
A2:3-7	FA_Strobe	49VO-WRF	110cd	2ND FL-DOUBLE DOUBLE 207	X	X	X					ON
A2:3-8	FA_HornStrobe	49AV-WRF	15cd	2ND FL-CORRIDOR 200				X				ON
A2:3-9	FA_Strobe	49VO-WRF	15cd	2ND FL-KING SINGLE BEDROOM	X			X				ON
A2:3-10	FA_Strobe	49VO-WRF	110cd	2ND FL-KING SINGLE BEDROOM		X		X				ON
A2:3-11	FA_Strobe	49VO-WRF	110cd	2ND FL-KING SINGLE BEDROOM	X	X		X				ON
A2:3-12	FA_HornStrobe	49AV-WRF	15cd	2ND FL-STAIR B 20B			X	X				ON

A3: ENHANCED POWER SUPPLY - CHANNEL 1					SWITCH SETTINGS							
IDNac Number	Device Type	PID	Candela	Custom Label (Max 40 Characters)								
A3:1-1	FA_Strobe	49VO-WRF	110cd	3RD FL- JUNIOR SUITE 322	X							ON
A3:1-2	FA_Strobe	49VO-WRF	15cd	3RD FL- JUNIOR SUITE 322		X						ON
A3:1-3	FA_HornStrobe	49AV-WRF	15cd	3RD FL- CORRIDOR 300	X	X						ON
A3:1-4	FA_HornStrobe	49AV-WRF	15cd	3RD FL- CORRIDOR 300			X					ON
A3:1-5	FA_HornStrobe	49AV-WRF	15cd	3RD FL- CORRIDOR 300	X		X					ON
A3:1-6	FA_Strobe	49VO-WRF	15cd	3RD FL- CORRIDOR 300		X	X					ON
A3:1-7	FA_HornStrobe	49AV-WRF	15cd	3RD FL- CORRIDOR 300	X	X	X					ON
A3:1-8	FA_Strobe	49VO-WRF	110cd	3RD FL- DOUBLE DOUBLE 307				X				ON
A3:1-9	FA_Strobe	49VO-WRF	15cd	3RD FL- DOUBLE DOUBLE 307	X			X				ON
A3:1-10	FA_Strobe	49VO-WRF	110cd	4TH FL- JUNIOR SUITE 422		X		X				ON
A3:1-11	FA_Strobe	49VO-WRF	15cd	4TH FL- JUNIOR SUITE 422	X	X		X				ON
A3:1-12	FA_HornStrobe	49AV-WRF	15cd	4TH FL- CORRIDOR 400			X	X				ON
A3:1-13	FA_HornStrobe	49AV-WRF	15cd	4TH FL- CORRIDOR 400	X		X	X				ON
A3:1-14	FA_HornStrobe	49AV-WRF	15cd	4TH FL- CORRIDOR 400		X	X	X				ON
A3:1-15	FA_Strobe	49VO-WRF	15cd	4TH FL- CORRIDOR 400	X	X	X	X				ON
A3:1-16	FA_HornStrobe	49AV-WRF	15cd	4TH FL- CORRIDOR 400				X				ON
A3:1-17	FA_Strobe	49VO-WRF	110cd	4TH FL- DOUBLE DOUBLE 407	X			X				ON
A3:1-18	FA_Strobe	49VO-WRF	15cd	4TH FL- DOUBLE DOUBLE 407		X		X				ON
A3:1-19	FA_Strobe	49VO-WRF	15cd	3RD FL- KING ADA 323	X	X		X				ON
A3:1-20	FA_HornStrobe	49AV-WRF	15cd	4TH FL- KING 401		X		X				ON

A3: ENHANCED POWER SUPPLY - CHANNEL 2					SWITCH SETTINGS							
IDNac Number	Device Type			Custom Label (Max 40 Characters)								
A3:2-1	FA_Strobe	49VO-WRF	15cd	5TH FL- KING 523	X							ON
A3:2-2	FA_Strobe	49VO-WRF	110cd	5TH FL- KING 523		X						ON
A3:2-3	FA_HornStrobe	49AV-WRF	15cd	5TH FL- CORRIDOR 500	X	X						ON
A3:2-4	FA_HornStrobe	49AV-WRF	15cd	5TH FL- CORRIDOR 500			X					ON
A3:2-5	FA_HornStrobe	49AV-WRF	15cd	5TH FL- CORRIDOR 500	X		X					ON
A3:2-6	FA_Strobe	49VO-WRF	110cd	5TH FL- KING 502		X	X					ON
A3:2-7	FA_Strobe	49VO-WRF	15cd	5TH FL- KING 502	X	X	X					ON
A3:2-8	FA_Strobe	49VO-WRF	15cd	5TH FL- CORRIDOR 500			X					ON
A3:2-9	FA_HornStrobe	49AV-WRF	15cd	5TH FL- CORRIDOR 500	X		X					ON
A3:2-10	FA_Strobe	49VO-WRF	15cd	6TH FL- EXIT ACC, CORR, 600B		X		X				ON
A3:2-11	FA_HornStrobe	49AV-WRF	15cd	6TH FL- EXIT ACC, CORR, 600B	X	X		X				ON
A3:2-12	FA_Strobe	49VO-WRF	15cd	6TH FL- CORRIDOR 600			X	X				ON
A3:2-13	FA_Strobe	49VO-WRF	110cd	6TH FL- JUNIOR SUITE 614	X		X	X				ON
A3:2-14	FA_Strobe	49VO-WRF	15cd	6TH FL- CORRIDOR 600		X	X	X				ON
A3:2-15	FA_HornStrobe	49AV-WRF	15cd	6TH FL- CORRIDOR 600	X	X	X	X				ON
A3:2-16	FA_HornStrobe	49AV-WRF	15cd	6TH FL- CORRIDOR 600				X				ON
A3:2-17	FA_HornStrobe	49AV-WRF	15cd	6TH FL- CORRIDOR 600	X			X				ON
A3:2-18	FA_HornStrobe	49AV-WRF	15cd	6TH FL- CORRIDOR 600		X		X				ON
A3:2-19	FA_Strobe	49VO-WRF	110cd	6TH FL- KING SINGLE BEDROOM -ADA 601	X	X		X				ON
A3:2-20	FA_Strobe	49VO-WRF	110cd	6TH FL- KING SINGLE BEDROOM -ADA 601			X	X				ON
A3:2-21	FA_Strobe	49VO-WRF	15cd	6TH FL- KING SINGLE BEDROOM -ADA 601	X		X	X				ON
A3:2-22	FA_Strobe	49VO-WRF	15cd	6TH FL- KING SINGLE BEDROOM -ADA 601		X	X	X				ON
A3:2-23	FA_HornStrobe	49AV-WRF	15cd	5TH FL- KING 501	X	X	X	X				ON

A3: ENHANCED POWER SUPPLY - CHANNEL 3					SWITCH SETTINGS							
IDNac Number	Device Type			Custom Label (Max 40 Characters)								
A3:3-1	FA_HornStrobe	49AV-WRF	15cd	7TH FL- CORRIDOR 700	X							ON
A3:3-2	FA_HornStrobeWP	49AV-WRFO	15cd	7TH FL- EXTERIOR		X						ON
A3:3-3	FA_HornStrobe	49AV-WRF	15cd	7TH FL- CORRIDOR 700	X	X						ON
A3:3-4	FA_Strobe	49VO-WRF	15cd	7TH FL- KING 712			X					ON
A3:3-5	FA_Strobe	49VO-WRF	110cd	7TH FL- KING 712	X		X					ON
A3:3-6	FA_HornStrobe	49AV-WRF	15cd	7TH FL- CORRIDOR 700		X	X					ON
A3:3-7	FA_Strobe	49VO-WRF	15cd	7TH FL- CORRIDOR 700	X	X	X					ON
A3:3-8	FA_Strobe	49VO-WRF	110cd	7TH FL- KING SINGLE BEDROOM 701				X				ON
A3:3-9	FA_Strobe	49VO-WRF	110cd	7TH FL- KING SINGLE BEDROOM 701	X			X				ON
A3:3-10	FA_Strobe	49VO-WRF	15cd	7TH FL- KING SINGLE BEDROOM 701		X		X				ON
A3:3-11	FA_Strobe	49VO-WRF	110cd	7TH FL- KING SINGLE BEDROOM 701	X	X		X				ON
A3:3-12	FA_Strobe	49VO-WRF	15cd	7TH FL- KING SINGLE BEDROOM 701		X	X	X				ON
A3:3-13	FA_HornStrobe	49AV-WRF	15cd	7TH FL- CORRIDOR 700	X		X	X				ON

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 04/03/15

tyco Simplex
Safer. Smarter. Tyco.™
DISTRICT - 147
20 THOMAS DRIVE
WESTBROOK, ME 04092
SERVICE: 207-842-6440
PHONE: 20
FAX: 20

PRESS HOTEL

PRESS HOTEL
119 EXCHANGE ST
PORTLAND, ME

Revisions shown with △ symbol

ISSUE LOG:					
MARK	DATE	CAD	CHK	DESCRIPTION	
△	5-28-14	JD	IG	REVISED PER ENGINEERS COMMENTS & ADDED AOR SYSTEM	

DRAWN BY:	JD
CHECKED BY:	IG
ISSUE DATE:	4/24/14
JOB #:	977465501
PROJECT #:	147:PRE-BOOKED

SIMPLEXGRINNELL © 2013

SYSTEM:
FIRE ALARM SYSTEM

SHEET:
CALCULATIONS AND SCHEDULES

FA-602

IMPORTANT NOTICE TO USERS: By accepting or using this drawing you are agreeing to the following terms and conditions. The electronic information in the drawing may not be altered or transferred to any third party, used for other projects or additions to this project for which it was prepared, or used for completion of this project by any third party, SimplexGrinnell disclaims all liabilities by the user or any third party and such use will be a user's sole risk. User shall not be liable for any direct, indemnity, and hold SimplexGrinnell harmless from any and all claims for loss, damage or injury arising directly or indirectly therefrom.

LAST SAVED BY: JUDELACRUZ
LAST PRINTED: 5/29/2014 3:08:55 PM
24" x 36" - Arch D Size