



Jeff Levine, AICP, Director
Planning & Urban Development Department

Tammy Munson, Director
Inspections Division

Kitchen Exhaust System Checklist and Application

Dear Applicant,

The following is a checklist to assist you in filing for a permit for a Kitchen Exhaust system. Please complete this and submit job specific construction documents that demonstrate compliance.

1. Type of System:

Type I X Type II _____

Type I systems are systems that vent fryers, grills, broilers, ovens or woks.
Type II systems are systems that vent steamers and other non-grease producing appliances.

2. Type of Materials:

Is the hood Stainless steel or other type of steel? Provided by Owner

If other, what type? N/A

Is the duct work Stainless steel or other type of steel? Cold Rolled Steel 16 gauge welded

If other, what type? N/A

Thickness of the steel for the hood: 18 Ga. SS. Thickness of the duct for the hood: 16 gauge

Type of Hood and Duct Supports 1/2 Threaded Rod

Type of seams and Joints welded

Grease Gutters provided? Hood Clearance reduction to Combustibles design /specs:
Factory Stand off.

Duct Clearance reduction to Combustibles design /specs:
Per NFPA 96

Vibration Isolation System: N/A.