

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



# CITY OF PORTLAND BUILDING PERMIT



**This is to certify that**  
PRESS HOTEL LLC

**Located at**  
390 CONGRESS ST

**PERMIT ID:** 2015-00821    **ISSUE DATE:** 05/21/2015    **CBL:** 032 C001001

has permission to **For the installation of a Kitchen Exhaust System (Type 1) for the restaurant at the "Press Hotel".**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise cloed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

*/s/ David Petruccelli*

*/s/ Tammy Munson*

**Fire Official**

**Building Official**

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY  
THERE IS A PENALTY FOR REMOVING THIS CARD**

***Approved Property Use - Zoning***

Hotel with 110 rooms and ancillary hotel functions with separate restaurant

***Building Inspections***

***Fire Department***

**Classification:**

Hotel  
ENTIRE

BUILDING PERMIT INSPECTION PROCEDURES  
Please call 874-8703 (ONLY)  
or email: [buildinginspections@portlandmaine.gov](mailto:buildinginspections@portlandmaine.gov)

**Check the Status or Schedule an Inspection On-Line at  
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.**

## **REQUIRED INSPECTIONS:**

Final - Fire

Final Inspection

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

<b>City of Portland, Maine - Building or Use Permit</b>		<b>Permit No:</b> 2015-00821	<b>Date Applied For:</b> 04/21/2015	<b>CBL:</b> 032 C001001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
<b>Proposed Use:</b> Same: 110 Room Hotel with Ancillary Hotel Functions with Separate Restaurant		<b>Proposed Project Description:</b> For the installation of a Kitchen Exhaust System (Type 1) for the restaurant at the "Press Hotel".		
<b>Dept:</b> Historic	<b>Status:</b> Approved	<b>Reviewer:</b> Deborah Andrews	<b>Approval Date:</b> 05/21/2015	<b>Ok to Issue:</b> <input checked="" type="checkbox"/>
<b>Note:</b>				
<b>Conditions:</b>				
<b>Dept:</b> Zoning	<b>Status:</b> Approved	<b>Reviewer:</b> Ann Machado	<b>Approval Date:</b> 05/08/2015	<b>Ok to Issue:</b> <input checked="" type="checkbox"/>
<b>Note:</b>				
<b>Conditions:</b>				
<b>Dept:</b> Fire	<b>Status:</b> Approved w/Conditions	<b>Reviewer:</b> David Petrucci	<b>Approval Date:</b> 05/05/2015	<b>Ok to Issue:</b> <input checked="" type="checkbox"/>
<b>Note:</b>				
<b>Conditions:</b>				
<ol style="list-style-type: none"> <li>1) Fire extinguishers are required per NFPA 1.</li> <li>2) Any cutting and welding done will require a Hot Work Permit from Fire Department.</li> <li>3) Hood suppression system shall comply with NFPA 17A, 96, and UL 300. Activation of the suppression system shall activate the fire alarm system if available. A letter of compliance will be required at the time of final inspection stating: the date the system was tested for operation, fuel gas shut off, and fire alarm connection if applicable. The Class K fire extinguisher and proper signage should be located at the suppression system pull station.</li> <li>4) Construction or installation shall comply with City Code Chapter 10.</li> <li>5) Application requires State Fire Marshal approval.</li> <li>6) Street addresses shall be marked on the structure and shall be as approved by the City E-911 Addressing Officer.</li> <li>7) A separate Fire Alarm Permit is required for new systems; or for work effecting more than 5 fire alarm devices; or replacement of a fire alarm panel with a different model. This review does not include approval of fire alarm system design or installation.</li> <li>8) Compliance with NFPA 1, Fire Code, Annex O for In-building Public Safety Radio Enhancement Systems shall be verified by an RF Engineer.</li> <li>9) A separate Suppression System Permit is required for all new suppression systems, including standpipe systems, and sprinkler work effecting more than 20 heads. This review does not include approval of system design or installation.</li> <li>10) Installation shall comply with City Code Chapter 10 and NFPA 96, Standard for ventilation Control and Fire Protection of Commercial Cooking Operations, 2008 edition. A signed letter of certification is required.</li> <li>11) A firefighter Building Marking Sign is required.</li> <li>12) All means of egress to remain accessible at all times.</li> <li>13) Emergency lights and exit signs are required. Emergency lights and exit signs are required to be labeled in relation to the panel and circuit and on the same circuit as the lighting for the area they serve.</li> <li>14) Any cutting and welding done will require a Hot Work Permit from Fire Department.</li> <li>15) Fire walls, fire barriers, fire partitions, smoke barriers and smoke partitions or any other wall required to have protected openings or penetrations shall be effectively and permanently identified with signs or stenciling in accessible concealed floor, floor-ceiling or attic spaces at intervals not exceeding 30 feet with lettering not less than 0.5 inches in height.</li> <li>16) Notice: The first scheduled final inspection fee is at no charge. Additional inspections shall be billed at \$75 for each inspector.</li> </ol>				

**PERMIT ID:** 2015-00821

**Located at:** 390 CONGRESS ST

**CBL:** 032 C001001

- 17 Through-penetrations and membrane penetrations in fire walls, fire barrier walls, and fire resistance rated horizontal assemblies shall be protected by firestop systems or devices in conformance with NFPA 101:8.3.5 (ASTM E 814 or ANSI/UL 1479). Providing firestop labels at each firestop system or device and an onsite manual containing the detail for each firestop system or device used for the project will streamline final inspection approvals.
- 18 \*\*The fire alarm system design shall be evaluated for the renovated areas by an NICET IV certified interior fire alarm designer or a licensed engineer for compliance with the code. A compliance letter is required prior to the final inspection.\*\*  
\*\*A current inspection sticker from an approved fire alarm inspection company is required prior to the final inspection.\*\*
- 19 The approved plans with the Building Department Approved stamp shall be maintained on site for inspection.
- 20 Fire department connection type and location shall be approved in writing by Fire Prevention Bureau.