



29 April 2015

Captain David Petruccelli
PORTLAND FIRE DEPARTMENT
FIRE PREVENTION
380 Congress Street
Portland, ME 04101

SUBJECT: CERTIFICATION OF WELLS BLOOMFIELD FIRE SUPPRESSION SYSTEM

LOCATION: THE PRESS HOTEL
390 Congress Street
Portland, ME 04101

Captain Petruccelli,

This is to advise you that on 28 April 2015, Interstate Fire Protection has completed the installation of a Wet Chemical Kitchen Fire Suppression Systems in the kitchen facilities of the subject location. The system is installed in a Wells Bloomfield Model WVU-96 Universal Ventless Hood. The Ventless Hood is equipped with a Fire Suppression System designed by Wells Bloomfield using ANSUL R102 components. The exhaust hood canopies installed over cooking appliances in kitchen area located in the basement level. The system is designed to discharge into the hood canopy, the integral, self-contained exhaust system, and onto the kitchen appliances located under the hood simultaneously when activated.

The system was given a function test using the methods recommended by Wells Bloomfield. In addition to successfully causing system actuation, the following vital events occurred:

- The building life/safety system was notified. When this occurred, the Fire Alarm System notification devices activated and a signal was transmitted to the off-premise receiving station,
- The Hood Exhaust Fan and Cooking Appliances were immediately de-energized.

All testing was successful. After testing was completed, inspection tags were affixed to the Kitchen Fire Suppression System. The Fire System is installed in strict compliance with Wells Bloomfield UL Listed specifications, National, State and Local Fire Prevention Codes.

Please do not hesitate to contact me if you require additional information.

Respectfully Submitted,

Terence F. Mooney
INTERSTATE FIRE PROTECTION

TM:tm
Encl.