

Architectural Lighting Fixture Schedule

TYPE	MANUFACTURER AND CATALOG NUMBER	DESCRIPTIONS AND REMARKS	LAMP	TRIM
KE1	BK Lighting DE-LED-x21-SP-BLW-12 Remote Transformer: RM-D15INC-120 Contact: N: Gerry Trolio C: Enterprise Lighting Sales 20 West 36th Street New York, NY 10018 T: (212) 343-1336 E: gtrolio@enterels.com	Surface mounted 15W LED flag uplight with remote transformer dimmable via incandescent dimmers. Fixture is aluminum, nominally 7-3/16" H x 3" diameter, with 2-11/196" adjustable knuckle. Manufacturer to provide canopy mount for surface mounted j-box, soft focus lens, and 45° cap style. Architect to verify black finish. INSTALLATION NOTES: 1- Contractor to coordinate all accessories as required for proper mounting, wiring, and power feeds for a complete installation. 2- Contractor to coordinate fixture mounting with architectural detail drawings, manufacturer's installation requirements and field conditions. 3- Contractor to located transformer in remote, accessible, well ventilated location.	Lamping by Manufacturer: 15W, 2700K Color Temperature integral LED E.E. to verify 120 volts.	N/A
KE2	OMITTED FROM THE PROJECT			
KE3	USA Illumination 7875-FINISH-325NC-VOLTAGE-8177A-9157A Contact: N: Phil Thomas C: SDA T: (718) 361-9150 x213 E: phil@sdalighting.com	Recess mounted adjustable MR16 round downlight with integral electronic transformer. Housing is aluminum and steel, nominally 10-5/8"W x 4-1/8"H x 12-1/2" L. Aperture is nominally 1-7/8" diameter, with 3-3/4" diameter trim. Fixture manufacturer to provide black hexcell louver and solite lens. Architect to verify exact finish. INSTALLATION NOTES: 1- Contractor to coordinate all accessories as required for proper mounting, wiring, and power feeds for a complete installation. 2- Contractor to coordinate fixture mounting with architectural detail drawings, manufacturer's installation requirements and field conditions.	Lamping by GE Lighting: (1) Q35MR16/C/SP20 (120V 35W 20°) E.E. to verify 120 volts.	Overlap Flange

Architectural Lighting Fixture Schedule

TYPE	MANUFACTURER AND CATALOG NUMBER	DESCRIPTIONS AND REMARKS	LAMP	TRIM
KE5	Bega 2095LED Contact: Tony Delaurentis International Lights t: 212.414.2803 m: 646.430.3792 e: tony@internationallights.com	Recess mounted 2.2W LED (total system – 4.0W) with integral 0-10V dimmable electronic transformer. Housing is aluminum, nominally 3-3/16"W x 7-1/2" H x 4" D. Manufacturer to provide gel to bring color temperature of LED to 2700° color temperature or warmer, exact gel to be determined. Architect to specify finish. INSTALLATION NOTES: 1- Contractor to coordinate all accessories as required for proper mounting, wiring, and power feeds for a complete installation. 2- Contractor to coordinate fixture mounting with architectural detail drawings, manufacturer's installation requirements and field conditions.	Lamping by Manufacturer: 2.2W (4.0 total system watts), 3000K Color Temperature LED E.E. to verify 120 volts.	N/A
KE6	USA Illumination 7875-FINISH-325NC-VOLTAGE-8177A-9157A Contact: N: Phil Thomas C: SDA T: (718) 361-9150 x213 M: (917) 449-4570 E: phil@sdalighting.com	Recess mounted adjustable MR16 round downlight with integral electronic transformer. Housing is aluminum and steel, nominally 10-5/8"W x 4-1/8"H x 12-1/2" L. Aperture is nominally 1-7/8" diameter, with 3-3/4" diameter trim. Fixture manufacturer to provide black hexcell louver and solite lens. Architect to verify exact finish. INSTALLATION NOTES: 1- Contractor to coordinate all accessories as required for proper mounting, wiring, and power feeds for a complete installation. 2- Contractor to coordinate fixture mounting with architectural detail drawings, manufacturer's installation requirements and field conditions.	Lamping by GE Lighting: (1) Q35MR16/C/SP20 (120V 35W 20°) E.E. to verify 120 volts.	Overlap Flange

Architectural Lighting Fixture Schedule

TYPE	MANUFACTURER AND CATALOG NUMBER	DESCRIPTIONS AND REMARKS	LAMP	TRIM
KE7	<p>Custom Manufacturer / BK Lighting (2) DS-LED-e36-WFL-A9-FINISH-11-B-360SL (1) DECORATIVE SHROUD</p> <p>Accessories: Canopy Plate 360 SL – Horizontal Rotation Knuckle</p> <p>Remote Transformer: TR150-VOLTAGE</p> <p>Contact: N: Gerry Trolio C: Enterprise Lighting Sales 20 West 36th Street New York, NY 10018 T: (212) 343-1336 E: gtrolio@enterels.com</p>	<p>Surface mounted decorative shroud with (2) 8W directional LED bullets and remote magnetic transformer. LED bullets are aluminum, nominally 4-3/4" H x 2-1/4" diameter, with 2-1/4" adjustable knuckle. Manufacturer to provide canopy mount for recess mounted j-box, honeycomb louver, and 90° cap style. Architect to verify finish.</p> <p>MANUFACTURER OF DECORATIVE SHROUD TO PROVIDE SHOP DRAWING PRIOR TO FINAL FIXTURE APPROVAL.</p> <p>INSTALLATION NOTES: 1- Contractor to coordinate all accessories as required for proper mounting, wiring, and power feeds for a complete installation. 2- Contractor to coordinate fixture mounting with architectural detail drawings, manufacturer's installation requirements and field conditions. 3- Contractor to locate transformer in remote, accessible, and well ventilated location.</p>	<p>Lamping by Manufacturer: (2) 8W (16 Watt System Total), 2700K Color Temperature integral LEDs</p> <p>E.E. to verify 120 volts.</p>	N/A
KE8	<p>Vista Professional Outdoor Lighting GW-2172-SS-LAMP-HL</p> <p>Remote Transformer: ES-150</p> <p>Contact: N: Nathaniel Bliss C: Specification Lighting Sales, LLC T: (212) 736-3700 E: nathaniel@sistg.com</p>	<p>Recessed in-grade MR16 halogen uplight with remote magnetic transformer. Fixture is glass-reinforced Rytan R4 composite and stainless steel, nominally 4-3/4"H x 5" Diameter. Fixture manufacturer to provide 25° tilt and 360° rotation. Architect to verify stainless steel finish.</p> <p>INSTALLATION NOTES: 1- Contractor to coordinate all accessories as required for proper mounting, wiring, and power feeds for a complete installation. 2- Contractor to coordinate fixture mounting with architectural detail drawings, manufacturer's installation requirements and field conditions. 3- Contractor to locate transformer in basement, in remote, accessible, well ventilated location.</p>	<p>Lamping by GE Lighting: (1) Q35MR16/C/SP20 (120V 35W 20°)</p> <p>E.E. to verify 120 volts.</p>	N/A

Architectural Lighting Fixture Schedule

TYPE	MANUFACTURER AND CATALOG NUMBER	DESCRIPTIONS AND REMARKS	LAMP	TRIM
KE9	BK Lighting DS-LED-e36-WFL-A9-FINISH-11-A-360SL Accessories: Canopy Plate 360 SL – Horizontal Rotation Knuckle Remote Transformer: TR300-VOLTAGE Contact: N: Gerry Trolio C: Enterprise Lighting Sales 20 West 36th Street New York, NY 10018 T: (212) 343-1336 E: gtrolio@enterels.com	Surface mounted 8W directional LED bullet with dimmable remote magnetic transformer. LED bullets are aluminum, nominally 4-3/4" H x 2-1/4" diameter, with 2-1/4" adjustable knuckle. Manufacturer to provide canopy mount for recess mounted j-box, honeycomb louver, and 45° cap style. Architect to verify finish. INSTALLATION NOTES: 1- Contractor to coordinate replacement of existing fixtures and connection to power. Existing fixtures shall be removed and empty slots shall be covered with metal plate. New LED fixture shall be located per architectural drawings, contractor to coordinate exact mounting. 2- Contractor to coordinate all accessories as required for proper mounting, wiring, and power feeds for a complete installation. 3- Contractor to coordinate fixture mounting with architectural detail drawings, manufacturer's installation requirements and field conditions. 4- Contractor to locate transformer in remote, accessible, well ventilated location.	Lamping by Manufacturer: 8W, 2700K Color Temperature integral LEDs E.E. to verify 120 volts.	N/A
KE10	BK Lighting DE-LED-x21-SP-BLW-12 Remote Transformer: RM-D15INC-120 Contact: N: Gerry Trolio C: Enterprise Lighting Sales 20 West 36th Street New York, NY 10018 T: (212) 343-1336 E: gtrolio@enterels.com	Tree mounted 15W LED adjustable bullet with remote transformer dimmable via incandescent dimmers. Fixture is aluminum, nominally 7-3/16" H x 3" diameter, with 2-11/196" adjustable knuckle. Manufacturer to provide canopy mount for surface mounted j-box, soft focus lens, and 45° cap style. Architect to verify black finish. INSTALLATION NOTES: 1- Contractor to coordinate all accessories as required for proper mounting, wiring, and power feeds for a complete installation. 2- Contractor to coordinate fixture mounting with architectural detail drawings, manufacturer's installation requirements and field conditions. 3- Contractor to locate transformer in remote, accessible, well ventilated location.	Lamping by Manufacturer: 15W, 2700K Color Temperature integral LED E.E. to verify 120 volts.	N/A
KE11	OMITTED FROM PROJECT			
KE12	OMITTED FROM PROJECT			

Architectural Lighting Fixture Schedule

TYPE	MANUFACTURER AND CATALOG NUMBER	DESCRIPTIONS AND REMARKS	LAMP	TRIM
KE13	<p>Electrix L140W-05-Exact length by E.C- W2700K CUSTOM COLOR-60M (MODIFIED WITH FROSTED FILM BETWEEN LOUVER AND DIODES)-S</p> <p>Remote Transformers: (as required) PS96-W (non-dimmable)</p> <p>** Fixture mfg to allow for modified frosted lens**</p> <p>Contact: N: Nathaniel Bliss C: Specification Lighting Sales, LLC T: (212) 736-3700 E: nathaniel@slsltg.com</p>	<p>Surface mounted linear 2700K LED strip modified with continuous frosted film between LED diodes and louver with remote dimmable 0-10V power supply. Housing is extruded aluminum, nominally 1-1/4" W 1-1/2" H x Length. Contractor to verify exact run lengths and order quantity as required per architectural drawing. Contractor to verify mounting installation with architectural details.</p> <p>Location: Exchange Canopy</p> <p>NOTES: 1 - FIXTURE MANUFACTURER TO PROVIDE SHOP DRAWING WITH EXACT RUN LENGTHS FOR REVIEW AND APPROVAL. 2 - ARCHITECT TO PROVIDE ARCHITECTURAL SHOP DRAWING TO KNLD FOR REVIEW AND APPROVAL. 3 - Manufacturer to ensure that LEDs are color matched to highest level of accuracy (+/- 200K). 4 - Luminaries can be wired in series up to maximum 16 FT. 5 - Contractor to coordinate feed location(s) with driver(s) and connection to power. Drivers shall be installed in remote, well-ventilated, and accessible locations; contractor and architect to coordinate. Distance between driver, power supply, and fixture must not exceed manufacturers' recommendations (Maximum remote distance is 32 FT). Quantity and locations of feed(s) and driver(s) to be determined by contractor. 6 - Contractor to determine required wire size between fixture and driver; refer to manufacturer's instructions and to assure that voltage drop does not exceed 5%. 7 - Remote dimming driver is requires a 0-10V control interface, to be provided by contractor. 8 - Contractor to order all electrical and mounting hardware required for a complete installation. 9 - Owners to review working fixture samples for final approval.</p>	<p>Lamping by Manufacturer: 5W / ft, 2700K Custom Color Temperature LED</p> <p>E.E to verify 120 voltage</p>	N/A

Architectural Lighting Fixture Schedule

TYPE	MANUFACTURER AND CATALOG NUMBER	DESCRIPTIONS AND REMARKS	LAMP	TRIM
EX1	<p>RAB Lighting VX200/F22</p> <p>Globe: GL100W</p> <p>Guard: GD100CL</p> <p>Contact: N: Jordan Podwal C: RAB Lighting T: (888)722-1000 E: jordan@rabweb.com</p>	<p>Ceiling j-box mounted compact fluorescent fixture. Globe is clear glass and housing and guard is diecast aluminum, nominally 10-3/4"H x 5-3/8" diameter. Manufacturer to provide medium base socket, rounded metal guard, and clear glass globe. Architect to verify finish.</p> <p>INSTALLATION NOTES:</p> <ol style="list-style-type: none"> 1- Contractor to coordinate all accessories as required for proper mounting, wiring, and power feeds for a complete installation. 2- Contractor to coordinate fixture mounting with architectural detail drawings, manufacturer's installation requirements and field conditions. 	<p>Lamping by GE Lighting: (1) FLE20AG21/2/RVL/CD</p> <p>E.E. to verify 120 volts.</p>	N/A