

Lannie Dobson - Fwd: Press Hotel

From: Deb Andrews
To: Lannie Dobson
Date: 1/13/2015 3:38 PM
Subject: Fwd: Press Hotel
Attachments: 18472 REALES Press Hotel) Portland) Ext Signs) S1 S2 PRES 12-19-2014.pdf

>>> <rob@neokraft.com> 1/13/2015 3:06 PM >>>

Hi.

I have attached a revised drawing detailing the changes to the size of the cabinet thickness for the Press Hotel Signs. The wall sign letters are 8" thick. For the double-sided illuminated wall letters, we have scaled them back from 12" to 9". I hope this will suffice because anything less than this may result in the lights actually showing through.

Please contact me with any questions.

Regards,

Rob

Rob Mainville
Neokraft Signs Inc.
686 Main St.
Lewiston, ME 04240
207-782-9654 ext. 226
(M) 207-576-4204
rob@neokraft.com