Approved for Historic Preservation
Certificate of Appropriateness
Date: 06/23/14

31 EXCHANGE/46 MARKET ST FIRE ALARM INPUT/OUTPUT MATRIX

System Inputs	Activate Alarm LED on FACP & Remote Annunciator	Activate Local & Remote Alarm Audible Signal	Activate Supervisory LED on FACP & Remote Annunciator	Activate Local & Remote Supervisory Audible Signal	Activate Trouble LED on FACP & Remote Annunciator	Activate Local & Remote Trouble Audible Signal	Indicate System Status & Location on FACP & Remote Display	Activate Audible/Visual Evacuation Signals	Transmit Alarm Signal to Central Station Indicating Exchange St P	Transmit Alarm Signal to Central Station Indicating Market	Transmit Trouble Signal to Central Station	Transmit Supervisory Signal to Central Station	Transmit Alarm Signal Through Radio N	Transmit Alarm Signal Through P
Manual Pull Station (Exchange St & Market 3rd & 4th Floor)	X	X					X	X	X					X
Manual Pull Station (Market St. Basement & First Floor)	X	X					X	X		X				
Smoke Detector	X	X					X	X	X					X
Low Battery					X	X	X				X			
Loss of AC Power					X	X	X				X			
Open Circiut					X	X	X				X			
Short Circuit					X	X	X				X			
Ground Fault					X	X	X				X			
Sprinkler Flow	X	X					X	X	X				X	
Sprinkler Tamper			X	X			X					X		
Hood Suppression	X	X					X	X	X					X

Approved for Historic Preservation
Certificate of Appropriateness
Date: 06/23/14