

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



# CITY OF PORTLAND BUILDING PERMIT



**This is to certify that**

MARKET MILK PARTNERS LLC

**Located at**

46 MARKET ST

**PERMIT ID:** 2015-01642

**ISSUE DATE:** 08/26/2015

**CBL:** 032 E010001

has permission to **Change of use to barber shop - install non-load bearing walls & plumbing for a small barber shop.**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise cloed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

*/s/ Craig Messinger*

*/s/ Laurie Leader*

**Fire Official**

**Building Official**

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY  
THERE IS A PENALTY FOR REMOVING THIS CARD**

***Approved Property Use - Zoning***

Basement - personal service (barber shop)

***Building Inspections***

**Use Group:** B

**Type:** 3B

Business - Barber Shop

Occupant load = 16

Building is sprinkled NFPA 13

BASEMENT

MUBEC/IBC 2009

***Fire Department***

BUILDING PERMIT INSPECTION PROCEDURES  
Please call 874-8703 (ONLY)  
or email: [buildinginspections@portlandmaine.gov](mailto:buildinginspections@portlandmaine.gov)

**Check the Status or Schedule an Inspection On-Line at  
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.**

## **REQUIRED INSPECTIONS:**

Close-in Plumbing/Framing w/Fire & Draft Stopping

Electrical Close-in w/Fire & Draftstopping

Final - Electric

Final - Fire

Certificate of Occupancy/Final

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

<b>City of Portland, Maine - Building or Use Permit</b>		<b>Permit No:</b> 2015-01642	<b>Date Applied For:</b> 07/02/2015	<b>CBL:</b> 032 E010001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
<b>Proposed Use:</b> Barber Shop in basement	<b>Proposed Project Description:</b> Change of use to barber shop - install non-load bearing walls & plumbing for a small barber shop.			
<hr/>				
<b>Dept:</b> Historic	<b>Status:</b> Approved w/Conditions	<b>Reviewer:</b> Robert Wiener	<b>Approval Date:</b> 08/13/2015	<b>Ok to Issue:</b> <input checked="" type="checkbox"/>
<b>Note:</b>				
<b>Conditions:</b>				
1) HP staff understanding is that venting for dryers and bathroom on the basement level will be on the rear of the building and will not be visible from either Milk Street or Market Street.				
2) Restored basement window on Milk Street (following removal of ventilation louver) is to match the other windows in all respects.				
<hr/>				
<b>Dept:</b> Zoning	<b>Status:</b> Approved w/Conditions	<b>Reviewer:</b> Ann Machado	<b>Approval Date:</b> 08/03/2015	<b>Ok to Issue:</b> <input checked="" type="checkbox"/>
<b>Note:</b>				
<b>Conditions:</b>				
1) Separate permits shall be required for any new signage.				
2) This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work.				
3) ANY exterior work requires a separate review and approval thru Historic Preservation. This property is located within an Historic District.				
<hr/>				
<b>Dept:</b> Building Inspecti	<b>Status:</b> Approved w/Conditions	<b>Reviewer:</b> Laurie Leader	<b>Approval Date:</b> 08/26/2015	<b>Ok to Issue:</b> <input checked="" type="checkbox"/>
<b>Note:</b>				
<b>Conditions:</b>				
1) Penetrations through fire resistance rated assemblies shall be protected by an approved penetration firestop system installed as tested in accordance with ASTM E814 or UL 1479				
2) The continuity of the fire resistance rated wall or floor/ceiling assembly shall be installed and maintained as described in IBC Ch. 7 and all penetrations shall be treated with approved materials and methods.				
3) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems, fire suppression and fuel tanks. Separate plans may need to be submitted for approval as a part of this process.				
4) The addition of plumbing fixtures, including water lines, drainage and vent piping shall be installed in compliance with the UPC 2009 code.				
5) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.				
<hr/>				
<b>Dept:</b> Engineering DPS	<b>Status:</b> Not Applicable	<b>Reviewer:</b> Benjamin Pearson	<b>Approval Date:</b> 07/13/2015	<b>Ok to Issue:</b> <input checked="" type="checkbox"/>
<b>Note:</b>				
<b>Conditions:</b>				
<hr/>				
<b>Dept:</b> Fire	<b>Status:</b> Approved w/Conditions	<b>Reviewer:</b> Craig Messinger	<b>Approval Date:</b> 08/05/2015	<b>Ok to Issue:</b> <input checked="" type="checkbox"/>
<b>Note:</b>				
<b>Conditions:</b>				
1) Shall comply with NFPA 72, National Fire Alarm and signaling Code.				
2) All outstanding code violations shall be corrected prior to final inspection.				

**PERMIT ID:** 2015-01642

**Located at:** 46 MARKET ST

**CBL:** 032 E010001

3) Shall comply with NFPA 101, Chapter 38, New Business Occupancies.

4) All construction shall comply with City Code Chapter 10.