Signarama™
The way to grow your business.

CITY OF PORTLAND, MAINE · RESURGAM
Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 10/27/15

872 Portland Rd. Saco, ME 04072 | Ph: 207.494.8085 | Fx: 207.494.9011 | www.signarama-saco.com

Artwork Approval Form

Dimensions: 40" x 40" round
Materials: 3/4" MDO Primed & Painted with high performance vinyl applied to both sides. Installation and mounting: 50" Metal Triangle Ball Lighted Bracket. Mount sign bracket plate measuring 3" x 17" to brick building face using four 5/16 x 1-3/4 or 2" galvanized lag screw with ½" dia cement anchor sleeved. Additional fastener may be used depending on the condition of the bricks/building and weight of sign. Any wiring will be done separately by a licensed electrician.

Scope of Work:
1) Add new sign and lighted bracket to brick face of building at the same location of current sign bracket. Sign will be hung with sign clips bolted through the face, suspended by a stainless steel chain with stainless steel anchor slip attaching the chain to the sign clips and bracket.

Approved by:_____

A physical signature is not required for ema