

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT

This is to certify that

MARKET MILK PARTNERS LLC

Located at

46 MARKET ST

PERMIT ID: 2016-01400

ISSUE DATE: 06/17/2016

CBL: 032 E010001

has permission to **Sign for Petit Jacqueline**
48.05" Square = 16' sq.

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise cloed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

N/A

/s/ Tammy Munson

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning
restaurant

Building Inspections

Fire Department

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703 (ONLY)
or email: buildinginspections@portlandmaine.gov

**Check the Status or Schedule an Inspection On-Line at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.**

REQUIRED INSPECTIONS:

Final Inspection

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit		Permit No: 2016-01400	Date Applied For: 05/27/2016	CBL: 032 E010001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Restaurant - Petit Jacqueline/Portland Patisserie		Proposed Project Description: Sign for Petit Jacqueline 48.05" Square = 16' sq.		
Dept: Historic Status: Approved w/Conditions Reviewer: Deborah Andrews Approval Date: 06/16/2016 Note: Ok to Issue: <input checked="" type="checkbox"/> Conditions: 1) Facing Market Street entrance, sign to be installed to right side of recessed entrance, in the masonry. Sign panel to align vertically with sign at corner of Market/Milk. Lag bolts to be installed in mortar joints, not brick itself.				
Dept: Zoning Status: Approved w/Conditions Reviewer: Christina Stacey Approval Date: 06/16/2016 Note: B-3 zone, PAD on Milk St frontage Ok to Issue: <input checked="" type="checkbox"/> Multitenant, has frontage on two streets - allowed two signs. Milk St 32' frontage = 64 sf max sign allowed, has existing 16 sf "Portland Patisserie" sign - OK Market St 52' frontage = 104 sf max sign allowed, proposing 16 sf "Petit Jacqueline" sign - OK Conditions: 1) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems, fire suppression and fuel tanks. Separate plans may need to be submitted for approval as a part of this process. 2) This is being issued with the understanding that as a fast track, the owner is responsible for scheduling inspections for the work being done and the inspector may require modifications to the work that has been completed if it does not meet code. 3) This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work.				