City of Portland, Maine - Building or Use Permit Application 369 Congress Street, 04101, Tel: (207) 874-8703, FAX: 874-8716 Permit No Location of Construction: Owner: Phone: 774-1000 36 Market St. Inc. Lessee/Buver's Name: Owner Address: Phone: BusinessName: All w Murket St. 04101 Permit Issued: Contractor Name: Address: Phone: 831-8245 89 Montrose Ave Tin Neura PERMIT FEE: COST OF WORK: Proposed Use: Past Use: \$10,000 XXXXXXXXXXXXXXXXXXXXXXXXX FIRE DEPT. Approved INSPECTION: Day Spe / Wine Bar Commercial Use Group A Type: 3 P □ Denied Zone: CBL: BOCAGO 032-Y-902 Signature: Zoning Approval: Proposed Project Description: PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.) Interior assovations for Day spa/wine bar Action: Approved Special Zone or Reviews: Approved with Conditions: □Shoreland Denied □ Wetland □ Flood Zone ☐ Subdivision Date: Signature: ☐ Site Plan mai ☐minor ☐mm ☐ Permit Taken By: Date Applied For: 4-13-99 SP Zoning Appeal □ Variance This permit application does not preclude the Applicant(s) from meeting applicable State and Federal rules. □ Miscellaneous 2. Building permits do not include plumbing, septic or electrical work. ☐ Conditional Use 3. □ Interpretation Building permits are void if work is not started within six (6) months of the date of issuance. False informa-☐ Approved tion may invalidate a building permit and stop all work... ☐ Denied Historic Preservation □ Not in District or Landmark ☐ Does Not Require Review WITH REQUIREMENTS ☐ Requires Review Action: CERTIFICATION ☐ Appoved ☐ Approved with Conditions I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been □ Denied authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provisions of the code(s) applicable to such permit 4-13-99 SIGNATURE OF APPLICANT ADDRESS: DATE: PHONE:

White-Permit Desk Green-Assessor's Canary-D.P.W. Pink-Public File Ivory Card-Inspector

PHONE:

CEO DISTRICT

RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE

COMMENTS

		5/28 Final 60/14 8	5/5/99 Site West
Foundation: Framing: Plumbing: Final: Other:		howpour tuilding ok	null back for the last
Inspection Record Date		for CoPO (DO)	Chark brankering

THIS IS NOT A PERMIT/CONSTRUCTION CANNOT COMMENCE UNTIL THE PERMIT IS ISSUED

Building or Use Permit Pre-Application

Attached Single Family Dwellings/Two-Family Dwelling

Multi-Family or Commercial Structures and Additions Thereto

In the interest of processing your application in the quickest possible manner, please complete the Information below for a Building or Use Permit.

NOTE**If you or the property owner owes real estate or personal property taxes or user charges on ANY PROPERTY within the City, payment arrangements must be made before permits of any kind are accepted.

Location/Addressof Construction (include Portion of Buildi	ng): 36	MARKET ST. P	ORTLAND
Total Square Footage of Proposed Structure 3,900	Ft2	Square Footage of Lot 7	2447 5Q F+
Tax Assessor's Chart, Block & Lot Number Chart# 3 2 Block# F Lot# 2		Market Street Inc	Telephone#: 207
Owner's Address: 42 Market St POLTLAND ME 04101	Lessee/Buy	er's Name (If Applicable)	Cost Of Work: Fee S 10,000 S
Proposed Project Description: (Please be as specific as possion LNTERIOR RENO	ble) UNTION	FOR DAY SPA/ L Beauty Salon	Dosement (100)
Contractor's Name, Address & Telephone	89 Mc	INTROSE ANE PORT	1App 831-8245 M
Current Use: NONE Comercial		Proposed Use: DAY SPA	WINE BAR
•All Electrical Installation must comp •HVAC(Heating, Ventililation and Air C You must Include the following with you applied 1) ACopy 2) A Co Minor or Major site plan review will be require checklist outlines the minimum standards for a second accomplete set of construction drawings showing Cross Sections w/Framing details (in Floor Plans & Elevations Window and door schedules Foundation plans with required drains	oly with the 19 conditioning) is ation: of Your Deed py of your Co 3) A Ple d for the above site plan. 4) E struction document all of the foliculating porche	or Purchase and Sale Agreement or Purchase and Sale Agreement of Plan/Site Plan proposed projects. The attached suilding Plans ments must be designed by a registlowing elements of construction: s, decks w/ railings, and accessory structiong	ended by Section 6-Art III. 1993 BOCA Mechanical Code. BUILDING 1 3 1999 Stered design professional. ructures)
 Electrical and plumbing layout. Med 	hanical drawing	gs for any specialized equipment such	
equipment, HVAC equipment (air ha		er types of work that may require spe- Certification	cial review must be included.
I hereby certify that I am the Owner of record of the named owner to make this application as his/her authorized agent, application is issued, I certify that the Code Official's author	property, or that the	ne proposed work is authorized by the owner on to all applicable laws of this jurisdiction. In a	addition, if a permit for work described in the

Building Permit Fee: \$25.00 for the 1st \$1000,cost plus \$5.00 per \$1,000.00 construction cost thereafter.

Additional Sue review and related fees are attached on a separate addendum

Date:

enforce the provisions of the codes applicable to this permit.

Signature of applicant:

Joseph E.



Department of Urban Development Gray, Jr

Director

CITY OF PORTLAND

The Paradiso 36 Market Street Portland, Maine June 1, 1999

RE: The Paradiso Beauty Salon

CBL: 032-F-002

Dear Michelle;

A recent electrical inspection conducted at 36 Market Street revealed that the permit required electrical work for the beauty salon, known as "The Paradiso," which occupies the first and second floors, has been satisfactorily completed.

Sincerely,

Michael A. Collins Chief Electrical Inspector City of Portland Cc: David Caddell, CEO

ADDRI	ESS: 30 MAPLEST ST.
PERMI	TAPPLICATION FOR: Internal Vennalian.
	ING OWNER:TAPPLICANT:
REVIE'	
DATE	OF DECISION 4/20/99
	• /
ніѕто	RIC PRESERVATION REVIEW
review a applicat	Your property is an individually designated landmark structure or is located within a designated historic As such, alterations to the building exterior or site which are visible from a public way are subject to and approval under Article IX (Historic Preservation) of the Land Use Code. Your building or sign permit ion has been reviewed to determine whether the nature or scope of the project requires review, and if so, it meets the standards of the historic preservation ordinance.
ACTIO	N
	Does not Require Review (e.g. Interior work only)/ alteration is not readily visible from a public way)
*:	Note: this finding is based on the understanding that the application entails interior work only or that the proposed exterior alteration(s) will not be readily visible from a public way. If your project entails exterior or site alterations (including the installation of sign(s), awnings, or exterior lighting for such) these alterations must be reviewed and approved prior to commencing with the work. Contact 874-8726 for more information.
	Denied Reason for Denial:
	Approved as submitted
	Approved with conditions (see below)
	Conditions of Approval:
	Contact Historic Preservation Staff (874-8726 or 874-8728) prior to installation of sign(s) to confirm approved location.
	Your sign permit includes no reference to exterior lighting; if lighting is included, please submit information on fixtures and specifications on installation.
	Other conditions:
	1.
	2
	2.
	2

BUILDING PERMIT REPORT
DATE: 14 APR 99 ADDRESS: 36 MARKET STC CBL: \$32-F-\$02
REASON FOR PERMIT: InTerior renovations / Day Spot wine bar.
BUILDING OWNER: 36 MArketst. Inc.
PERMIT APPLICANT: TIM Myors.
USE GROUP B/A3 BOCA 1996 CONSTRUCTION TYPE 3-B
CONDITION(S) OF APPROVAL
This permit is being issued with the understanding that the following conditions are met:
Approved with the following conditions: $\frac{\times}{1}$, $\frac{\times}{12}$, $\frac{\times}{13}$, $\frac{\times}{14}$, $\frac{\times}{12}$, $\frac{\times}{13}$, $\frac{\times}{14}$, $\frac{\times}{12}$, \frac
 This permit does not excuse the applicant from meeting applicable State and Federal rules and laws. Before concrete for foundation is placed, approvals from the Development Review Coordinator and Inspection Services must be obtaine (A 24 hour notice is required prior to inspection)
Foundation drain shall be placed around the perimeter of a foundation that consists of gravel or crushed stone containing not more than 10 percent material that passes through a No. 4 sieve. The drain shall extend a minimum of 12 inches beyond the outside edge of the footing. The thickness shall be such that the bottom of the drain is not higher than the bottom of the base under the floor, and that the top of the drain is not less than 6 inches above the top of the footing. The top of the drain shall be covered with an approved filter membrane material. Where a drain tile or perforated pipe is used, the invert of the pipe or tile shall not be higher than the floor elevation. The top of joints or top of perforations shall be protected with an approved filter membrane material. The pipe or tile shall be placed on not less than 2" of gravel or crushed stone, and shall be covered with not less than 6" of the same material. Section 1813.5.2 4. Foundations anchors shall be a minimum of ½" in diameter, 7" into the foundation wall, minimum of 12" from corners of foundation and a maximum 6' o.c. between bolts. (Section 2305.17)
 Waterproofing and damp proofing shall be done in accordance with Section 1813.0 of the building code. Precaution must be taken to protect concrete from freezing. Section 1908.0
 It is strongly recommended that a registered land surveyor check all foundation forms before concrete is placed. This is done to verify that the proper setbacks are maintained.
 Private garages located beneath habitable rooms in occupancies in Use Group R-1, R-2, R-3 or I-1 shall be separated from adjacent interior spaces by fire partitions and floor/ceiling assembly which are constructed with not less than 1-hour fire resisting rating. Private garages attached side-by-side to rooms in the above occupancies shall be completely separated from the interior spaces and the attic area by means of ½ inch gypsum board or the equivalent applied to the garage means of ½ inch gypsum board or the equivalent applied to the garage side. (Chapter 4, Section 407.0 of the BOCA/1996) All chimneys and vents shall be installed and maintained as per Chapter 12 of the City's Mechanical Code. (The BOCA National
Mechanical Code/1993). Chapter 12 & NFPA 211 Sound transmission control in residential building shall be done in accordance with Chapter 12, Section 1214.0 of the City's Building Code.
Guardrails & Handrails: A guardrail system is a system of building components located near the open sides of elevated walking surfaces for the purpose of minimizing the possibility of an accidental fall from the walking surface to the lower level. Minimum height all Use Groups 42", except Use Group R which is 36". In occupancies in Use Group A, B, H-4, I-1, I-2, M and R and public garages and open parking structures, open guards shall have balusters or be of solid material such that a sphere with a diameter of 4" cannot pass through any opening. Guards shall not have an ornamental pattern that would provide a ladder effect. (Handrails shall be a minimum of 3e4" but not more than 38". Use Group R-3 shall not be less than 30", but not more than 38".) Handrail grip size shall have a circular cross section with an outside diameter of at least 1 ½" and not greater than 2". (Sections 1021 & 1022.0) - Handrails shall be on both sides of stairway. (Section 1014.7)
 Headroom in habitable space is a minimum of 7'6". (Section 1204.0) Stair construction in Use Group R-3 & R-4is a minimum of 10" tread and 7-3/" maximum rise. All other Use Group minimum 11"
tread, 7" maximum rise. (Section 1014.0) 4. The minimum headroom in all parts of a stairway shall not be less than 80 inches. (6'8") 1014.4
5. Every sleeping room below the fourth story in buildings of Use Groups R and I-1 shall have at least one operable window or exterior doo approved for emergency egress or rescue. The units must be operable from the inside without the use of special knowledge or separate tools. Where windows are provided as means of egress or rescue they shall have a sill height not more than 44 inches (1118mm) above the floor. All egress or rescue windows from sleeping rooms shall have a minimum net clear opening height dimension of 24 inches (610mm). The minimum net clear opening width dimension shall be 20 inches (508mm), and a minimum net clear opening of 5.7 sq. ft.
(Section 1018.6). (Section 1018.6). Each apartment shall have access to two (2) separate, remote and approved means of egress. A single exit is acceptable when it exits

directly from the apartment to the building exterior with no communications to other apartment units. (Section 1010.1)

All vertical openings shall be enclosed with construction having a fire rating of at least one (1) hour, including fire doors with self closer's. (Over 3 stories in height requirements for fire rating is two (2) hours.) (Section 710.0)

/16.

X17.

- 18. The boiler shall be protected by enclosing with (1)hour fire rated construction including fire doors and ceiling, or by providing automatic extinguishment. (Table 302.1.1)
- All single and multiple station smoke detectors shall be of an approved type and shall be installed in accordance with the provisions of 19. the City's Building Code Chapter 9, Section 920.3.2 (BOCA National Building Code/1996), and NFPA 101 Chapter 18 &19. (Smoke detectors shall be installed and maintained at the following locations):
 - In the immediate vicinity of bedrooms
 - In all bedrooms
 - In each story within a dwelling unit, including basements

In addition to the required AC primary power source, required smoke detectors in occupancies in Use Groups R-2, R-3 and I-1 shall receive power from a battery when the AC primary power source is interrupted. (Interconnection is required) Section 920.3.2.

- X20. A portable fire extinguisher shall be located as per NFPA #10. They shall bear the label of an approved agency and be of an approved type. (Section 921.0)
- X 21. The Fire Alarm System shall maintained to NFPA #72 Standard.
- **太22.** The Sprinkler System shall maintained to NFPA #13 Standard.
- All exit signs, lights and means of egress lighting shall be done in accordance with Chapter 10 Section & Subsections 1023.0 & 1024.0 X 23. of the City's Building Code. (The BOCA National Building Code/1996)
 - 24. Section 25-135 of the Municipal Code for the City of Portland states, "No person or utility shall be granted a permit to excavate or open any street or sidewalk from the time of November 15 of each year to April 15 of the following year".
 - 25. The builder of a facility to which Section 4594-C of the Maine State Human Rights Act Title 5 MRSA refers, shall obtain a certification from a design professional that the plans commencing construction of the facility, the builder shall submit the certification the Division of Inspection Services.
- 26. Ventilation shall meet the requirements of Chapter 12 Sections 1210.0 of the City's Building Code. (Crawl spaces & attics).
- X 27. All electrical, plumbing and HVAC permits must be obtained by a Master Licensed holders of their trade. No closing in of walls until all electrical (min. 72 hours notice) and plumbing inspections have been done.
 - 28. All requirements must be met before a final Certificate of Occupancy is issued.
- X 29. All building elements shall meet the fastening schedule as per Table 2305.2 of the City's Building Code (the BOCA National Building Code/1996).
 - Ventilation of spaces within a building shall be done in accordance with the City's Mechanical Code (The BOCA National Mechanical 30. Please read and implement the attached Land Use Zoning report requirements. > Sup. fermits Needed for New Sugary
 Boring, cutting and notching shall be done in accordance with Survey and notching shall be done in accordance with Survey and not ching shall be done in accordance with Survey and not ching shall be done in accordance with Survey and not ching shall be done in accordance with Survey and not ching shall be done in accordance with Survey and survey are survey and survey and survey and survey and survey and survey
 - Boring, cutting and notching shall be done in accordance with Sections 2305.4.4, 2305.5.1 and 2305.5.3 of the City's Building Code.
 - 33. Glass and glazing shall meet the requirements of Chapter 24 of the building code.
- This permit is being issued with the understanding That No bearing walls X 34. be removed for aftered. 35.

Hoffses, Building Inspector

H. McDougall, PFD

Marge Schmuckal, Zoning Administrator

MMIN PSH 12-14-98

36.

^{**}On the basis of plans submitted and conditions placed on these plans any deviations shall require a separate approval.



CIT OF PORTLAND, MAINE

Department of Building Inspection

Certificate of Occupancy

LOCATION 36 Market Street CBL#032-F-002

Issued to 36 Market Street Inch.

Date of Issue

— changed as to use under Building Permit No. 990356, has had final inspection, has been found to conform substantially to requirements of Zoning Ordinance and Building Code of the City, and is hereby approved for occupancy or use, limited or otherwise, as indicated below.

PORTION OF BUILDING OR PREMISES

Commercial

Limiting Conditions:

APPROVED OCCUPANCY

Day Spa/Wine Bar Type 3 B Use Group A 3/B BOCA 1996

This certificate supersedes certificate issued

Approved:

(Date)

Inspector

Inspector of Buildings

Notice: This certificate identifies lawful use of building or premises, and ought to be transferred from owner to owner when property changes hands. Copy will be furnished to owner or lessee for one dollar.