•	y <b>of Portland, Maine -</b> Congress Street, 04101	0			Pe	rmit No: 10-0098	Issue Date	e:	CBL: 032 F003	3001
Location of Construction: Owner Name:			Owner Address:				Phone:			
30 Market St ELC Inc				42 Market St						
		Contractor Nan Eastern Fire Pr	ame: Protection Co., Inc.		Contractor Address: 170 Kittyhawk Ave., PO Box0139 A			139 Aut	Phone           Aubu         2077841507	
Lessee/Buyer's Name Phone:				Permit Type: Fire Suppression System				Zone:		
Past	Use:	<b>Proposed Use:</b>			Pern	nit Fee:	Cost of Wo	rk:	CEO District:	]
Con	nmercial - Restaurant - "Pat	's Commercial /	Commercial / Restaurant - Fire			\$120.00	\$10,00	00.00	1	
Pizza - Old Port" (tenant fit up permit #10-0102)		Suppression S	Suppression System		Approved			SPECTION: e Group: Type		
Proposed Project Description: Fire Suppression System					Signature:		Signatu	ignature:		
					PEDESTRIAN ACTIVITIES DISTRIC Action Approved Approve Signature:					
Permit Taken By:Date Applied For:gg02/04/2010			Zoning Approval							
1.	This permit application do	bes not preclude the	Specia	al Zone or Revie	ews Zoning Appeal			<b>Historic Preservation</b>		
	Applicant(s) from meeting applicable State and Federal Rules.		Shoreland		U Variance			Not in District or Landma		
2.	Building permits do not include plumbing, septic or electrical work.		Wetland		Miscellaneous			Does Not Require Revie		
3.	Building permits are void within six (6) months of th		Flood Zon		Conditional Us			Requires Review		
False information may invalidate a building permit and stop all work			Subdivision			Interpretatio			Approved	
			☐ Site	e Plan		Approve	ed		Approved w/	Condition
			Maj 🗌	Mino 🗌 MM		Denied			Denied	
			Date:			Date:		Da	ate:	

## CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provision of the code(s) applicable to such permit.

SIGNATURE OF APPLICAN	ADDRESS	DATE	РНО
RESPONSIBLE PERSON IN CHARGE OF WORK, TIT		DATE	РНО

30 Market St       F.I. C. Inc.       42 Market St       Phone:         Busiaces Name:       Contractor Name:       Contractor Address:       Phone:         170 Kittyhawk Ave., PO Box0139 Aubu       2077841507         Lesser/Buyer's Name       Phone:       Permit Type:         Fire Suppression System       Zone:         Dept:       Historic       Status: Approved with Conditions       Reviewer:       Debonah Andrews       Approval Date:       02/10/2010         Note:       Or hybrid fire department hose connection may be installed on the front facade. All other exterior components associated with fire sprinkler system, including sprinkler going and main drain, to be located on rear clevation, outside of public view.       Dept:       Zon (s to Issue:       Image: Contractor Conte contractor Contractor Contractor Contractor Conte contractor C	Location of Construction:	Owner Name:		Owner Address:	Phone:		
Eastern Fire Protection Co., Inc.       170 Kittyhawk Ave., PO Box0139 Aubu       2077841507         Lesset/Buyer's Name       Phone:       Permit Type: Fire Suppression System       Zome:         Dept:       Historic       Status: Approved with Conditions       Reviewer:       Debrah Andrews       Approval Date:       02/10/2010         Note:       O'to Issue:       Ø'       O'to Issue:       Ø'         1)       * Only the fire department hose connection may be installed on the front facade. All other exterior components associated with fire sprinkler system, including sprinkler gong and main drain, to be located on rear clevation, outside of public view.       Ø'to Issue:       Ø'         Dept:       Zoning       Status: Approved with Conditions       Reviewer: Ann Machado       Approval Date:       02/05/2010         Note:       O'to to Issue:       Ø'       O'to to Issue:       Ø'         1)       ANY caterior work requires a separate review and approval thru Historic Preservation. This property is located within an Historic       D'to Issue:       Ø'         2)       This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval Date:       02/12/2010         Note:       Ok to Issue:       Ø'       Ø'to Issue:       Ø'         1)       Sprinkler systems to be designed and installed per IBC 2003 standards Sec. 903.3.1       Ok to Issue: </td <td>30 Market St</td> <td colspan="2">E L C Inc</td> <td>42 Market St</td> <td></td> <td></td>	30 Market St	E L C Inc		42 Market St			
Lessee/Buyer's Name       Phone:       Permit Type: Fire Suppression System       Zone:         Dept:       Historic       Status: Approved with Conditions       Reviewer: Deborah Andrews       Approval Date:       02/10/2010         Note:       Ok to Issue:       Ø       Ok to Issue:       Ø         1)       * Only the fire department hose connection may be installed on the front facade. All other exterior components associated with fire sprinkler system, including sprinkler gong and main drain, to be located on rear elevation, outside of public view.         Dept:       Zonei;       Matual Status: Approved with Conditions       Reviewer: Ann Machado       Approval Date:       02/05/2010         Note:       Ox to Issue:       Ø       0.8 to Issue:       Ø         1) ANY esterior work requires a separate review and approval thru Historic Preservation. This property is located within an Historic District.       1.1 his permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval Date:       02/12/2010         Note:       Ok to Issue:       Ø       0/12/2010       Ok to Issue:       Ø         1) Sprinkler systems to be designed and installed per IBC 2003 standards Sec. 903.3.1       Ok to Issue:       Ø       10/11/2010         Note:       Ok to Issue:       Ø       11/2010       Ok to Issue:       Ø         1) Fire Department connection shall be 5" storz.	Business Name:						
Fire Suppression System         Dept:       Historic       Status: Approved with Conditions       Reviewer:       Deborah Andrews       Approval Date:       02/10/2010         Note:       Only the fire department hose connection may be installed on the front facade. All other exterior components associated with fire sprinkler system, including sprinkler gong and main drain, to be located on rear elevation, outside of public view.         Dept:       Zoning       Status: Approved with Conditions       Reviewer:       Ann Machado       Approval Date:       02/05/2010         Note:       Out to Issue:       Image: Contract Contenem Content Contract Contract Contract Contract Contra		Eastern Fire Protection	Co., Inc.	170 Kittyhawk Ave., PO E	lox0139 Aubu	207784150	7
Dept:       Historic       Status:       Approved with Conditions       Reviewer:       Deborah Andrews       Approval Date:       02/10/2010 Ok to Issue:         1) * Only the fire department hose connection may be installed on the front facade. All other exterior components associated with fire sprinkler system, including sprinkler gong and main drain, to be located on rear elevation, outside of public view.       Dept:       Zoning       Status: Approved with Conditions       Reviewer:       Ann Machado       Approval Date:       02/05/2010         Note:       0       Ok to Issue:       0       0k to Issue:       0         1) ANY exterior work requires a separate review and approval thru Historic Preservation. This property is located within an Historic District.       2)       This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval Date:       02/02/2010         Note:       0       Note:       0       0k to Issue:       0         1)       Sprinkler systems to be designed and installed per IBC 2003 standards Sec. 903.3.1       0k to Issue:       02/01/2010         Note:       0       Not to Issue:       0       0k to Issue:       0         1)       Sprinkler systems to be designed and installed per IBC 2003 standards Sec. 903.3.1       0k to Issue:       0         Dept:       Fire       Status: Approved with Conditions       Reviewer:       Capt K	Lessee/Buyer's Name	Phone:					Zone:
Note:       Ok to Issue:       Ok         1) * Only the fire department hose connection may be installed on the front facade. All other exterior components associated with fire spinkler system, including sprinkler gong and main drain, to be located on rear elevation, outside of public view.         Dept:       Zoning       Status: Approved with Conditions       Reviewer: Ann Machado       Approval Date:       0205/2010         Note:       OAN exterior work requires a separate review and approval thru Historic Preservation. This property is located within an Historic District.       District.       District.       District.       OI has been submitted. Any deviations shall require a separate approval Date:       02/12/2010         Note:       Or to Issue:       Image: Control of the plant here is the proval date:       02/12/2010         Note:       OB to Issue:       Image: Control of the plant here is the designed and installed per IBC 2003 standards Sec. 903.3.1       Dept:       Fire       Status: Approved with Conditions       Reviewer:       Capt Keith Gautreau       Approval Date:       02/11/2010         Note:       Ok to Issue:       Image: Control of the system shall be installed per IBC 2003 standards Sec. 903.3.1       Dept:       Fire Department connection shall be 5" storz.       Image: Control of the system shall be installed in accordance with NFPA 13.         4)       Application requires State Fire Marshal approval.       Sin the sprinkler system shall be installed in accordance with NFPA 13.				Fire Suppression System	1		
Note:       Ok to Issue:       Ok         1) * Only the fire department hose connection may be installed on the front facade. All other exterior components associated with fire spinkler system, including sprinkler gong and main drain, to be located on rear elevation, outside of public view.         Dept:       Zoning       Status: Approved with Conditions       Reviewer: Ann Machado       Approval Date:       0205/2010         Note:       OAN exterior work requires a separate review and approval thru Historic Preservation. This property is located within an Historic District.       District.       District.       District.       OI has been submitted. Any deviations shall require a separate approval Date:       02/12/2010         Note:       Or to Issue:       Image: Control of the plant here is the proval date:       02/12/2010         Note:       OB to Issue:       Image: Control of the plant here is the designed and installed per IBC 2003 standards Sec. 903.3.1       Dept:       Fire       Status: Approved with Conditions       Reviewer:       Capt Keith Gautreau       Approval Date:       02/11/2010         Note:       Ok to Issue:       Image: Control of the system shall be installed per IBC 2003 standards Sec. 903.3.1       Dept:       Fire Department connection shall be 5" storz.       Image: Control of the system shall be installed in accordance with NFPA 13.         4)       Application requires State Fire Marshal approval.       Sin the sprinkler system shall be installed in accordance with NFPA 13.				D1 14 1		00/	0/2010
<ol> <li>* Only the fire department hose connection may be installed on the front facade. All other exterior components associated with fire sprinkler system, including sprinkler gong and main drain, to be located on rear elevation, outside of public view.</li> <li>Dept: Zoning Status: Approved with Conditions Reviewer: Ann Machado Approval Date: 02/05/2010 Note: Ok to Issue: </li> <li>ANY exterior work requires a separate review and approval thru Historic Preservation. This property is located within an Historic District.</li> <li>This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work.</li> <li>Dept: Building Status: Approved with Conditions Reviewer: Jeanine Bourke Approval Date: 02/12/2010 Note: Ok to Issue: </li> <li>J sprinkler systems to be designed and installed per IBC 2003 standards Sec. 903.3.1</li> <li>Dept: Fire Status: Approved with Conditions Reviewer: Capt Keith Gautreau Approval Date: 02/11/2010 Note: Ok to Issue: </li> <li>Pire Department connection shall be 5" storz.</li> <li>The Fire alarm and Sprinkler systems shall be reviewed by a licensed contractor[s] for code compliance. Compliance letters are required.</li> <li>The sprinkler system shall be installed in accordance with NFPA 13.</li> <li>Application requires State Fire Marshal approval.</li> <li>Fire department connection type and location shall be approved in writing by fire prevention bureau.</li> <li>The Fire Approxement will require knox locking caps on all Fire Department Connections on the exterior of the building.</li> <li>System acceptance and commissioning must be co-ordinated with alarm and suppression system contractors and the Fire Department. Call 874-8703 to schedule.</li> <li>Comments:</li> <li>24/2010-amachado: Spoke to Jesse at Eastern Fire Protection. He said that Pat's Pizza is occupying the whole building. He also said that he woils send a PDF of the plan. He told me that</li></ol>	-	pproved with Condition	ns <b>Reviewer</b> :	: Deborah Andrews			
fire sprinkler system, including sprinkler gong and main drain, to be located on rear elevation, outside of public view.         Dept:       Zoning       Status: Approved with Conditions       Reviewer: Ann Machado       Approval Date:       02/05/2010         Note:       Ok to Issue:       Image: Control of the issue:       Image: Contro of the issue:       Image: Control of the iss							
Note:       Ok to Issue:       ✓         1) ANY exterior work requires a separate review and approval thru Historic Preservation. This property is located within an Historic District.       2)         2) This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work.         Dept:       Building       Status: Approved with Conditions       Reviewer: Jeanine Bourke       Approval Date:       02/12/2010         Note:       Ok to Issue:       ✓         1) Sprinkler systems to be designed and installed per IBC 2003 standards Sec. 903.3.1         Dept:       Fire       Status: Approved with Conditions       Reviewer: Capt Keith Gautreau       Approval Date:       02/11/2010         Note:       Ok to Issue:       ✓         1)       Fire Department connection shall be 5" storz.       Ok to Issue:       ✓         1)       Fire alarm and Sprinkler systems shall be reviewed by a licensed contractor[s] for code compliance. Compliance letters are required.       O         3)       The sprinkler system shall be installed in accordance with NFPA 13.       Application requires State Fire Marshal approval.         5)       Fire department connection type and location shall be approved in writing by fire prevention bureau.         6)       The Fire Department will require knox locking caps on all Fire Department Connections on the exterior of the building.         <							ith
<ol> <li>ANY exterior work requires a separate review and approval thru Historic Preservation. This property is located within an Historic District.</li> <li>This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work.</li> <li>Dept: Building Status: Approved with Conditions Reviewer: Jeanine Bourke Approval Date: 02/12/2010 Note: 0k to Issue: ✓</li> <li>Sprinkler systems to be designed and installed per IBC 2003 standards Sec. 903.3.1</li> <li>Dept: Fire Status: Approved with Conditions Reviewer: Capt Keith Gautreau Approval Date: 02/11/2010 Note: 0k to Issue: ✓</li> <li>Fire Department connection shall be 5" storz.</li> <li>The sprinkler systems shall be neviewed by a licensed contractor[s] for code compliance. Compliance letters are required.</li> <li>The sprinkler system shall be installed in accordance with NFPA 13.</li> <li>Application requires State Fire Marshal approval.</li> <li>Fire Department connection type and location shall be approved in writing by fire prevention bureau.</li> <li>The Fire Department will require knox locking caps on all Fire Department Connections on the exterior of the building.</li> <li>System acceptance and commissioning must be co-ordinated with alarm and suppression system contractors and the Fire Department. Call 874-8703 to schedule.</li> <li>Comments:</li> <li>2/4/2010-amachado: Spoke to Jesse at Eastern Fire Protection. He said that Pat's Pizza is occupying the whole building. He also said that the would send a PDF of the plan. He told me that his contact at ELC Corporation was Chris Tyll (776-3831). I left a vociemail for Chris Tyll. We need atenant fit up permit for Pat's Pizza. Permits</li> </ol>	Dept: Zoning Status: A	pproved with Condition	ns Reviewer:	: Ann Machado	Approval Dat	e: 02/0	)5/2010
<ul> <li>District.</li> <li>2) This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work.</li> <li>Dept: Building Status: Approved with Conditions Reviewer: Jeanine Bourke Approval Date: 02/12/2010 Note: Ok to Issue: <ul> <li>Ok to Issue: </li> <li>I) Sprinkler systems to be designed and installed per IBC 2003 standards Sec. 903.3.1</li> </ul> </li> <li>Dept: Fire Status: Approved with Conditions Reviewer: Capt Keith Gautreau Approval Date: 02/11/2010 Note: Ok to Issue: <ul> <li>I) Sprinkler systems to be designed and installed per IBC 2003 standards Sec. 903.3.1</li> <li>Dept: Fire Status: Approved with Conditions Reviewer: Capt Keith Gautreau Approval Date: 02/11/2010 Ok to Issue: <ul> <li>I) Fire Department connection shall be 5" storz.</li> <li>2) The Fire alarm and Sprinkler systems shall be reviewed by a licensed contractor[s] for code compliance. Compliance letters are required.</li> <li>3) The sprinkler system shall be installed in accordance with NFPA 13.</li> <li>4) Application requires State Fire Marshal approval.</li> <li>5) Fire department connection type and location shall be approved in writing by fire prevention bureau.</li> <li>6) The Fire Department will require knox locking caps on all Fire Department Connections on the exterior of the building.</li> <li>7) System acceptance and commissioning must be co-ordinated with alarm and suppression system contractors and the Fire Department. Call 874-8703 to schedule.</li> </ul> Comments: 2/4/2010-amachado: Spoke to Jesse at Eastern Fire Protection. He said that Pat's Pizza is occupying the whole building. He also said that he would send a PDF of the plan. He told me that his contact at ELC Corporation was Chris Tyll (776-3831). I left a vociemail for Chris Tyll. We need atenant fit up permit for Pat's Pizza. Permits</li></ul></li></ul>	Note:					Ok to Issue	: 🗸
work.       Image: Status: Approved with Conditions Reviewer: Jeanine Bourke       Approval Date:       02/12/2010         Note:       Ok to Issue:       Image: Status: Approved with Conditions Reviewer: Capt Keith Gautreau       Approval Date:       02/11/2010         Note:       Ok to Issue:       Image: Status: Approved with Conditions Reviewer: Capt Keith Gautreau       Approval Date:       02/11/2010         Note:       Ok to Issue:       Image: Status: Approved with Conditions Reviewer: Capt Keith Gautreau       Approval Date:       02/11/2010         Note:       Ok to Issue:       Image: Status:       Image: Status: Approved with Conditions Reviewer: Capt Keith Gautreau       Approval Date:       02/11/2010         Note:       Ok to Issue:       Image: Status:		arate review and approv	al thru Historic	Preservation. This property	is located with	in an Histor	ric
Note:       Ok to Issue:       ✓         1) Sprinkler systems to be designed and installed per IBC 2003 standards Sec. 903.3.1       Ok to Issue:       ✓         1) Sprinkler systems to be designed and installed per IBC 2003 standards Sec. 903.3.1       Ok to Issue:       02/11/2010         Note:       Ok to Issue:       ✓         1) Fire Department connection shall be 5" storz.       Ok to Issue:       ✓         2) The Fire alarm and Sprinkler systems shall be reviewed by a licensed contractor[s] for code compliance. Compliance letters are required.       Ok to Issue:       ✓         3) The sprinkler system shall be installed in accordance with NFPA 13.       4       Application requires State Fire Marshal approval.       5         5) Fire department connection type and location shall be approved in writing by fire prevention bureau.       6       The Fire Department will require knox locking caps on all Fire Department Connections on the exterior of the building.         7) System acceptance and commissioning must be co-ordinated with alarm and suppression system contractors and the Fire Department. Call 874-8703 to schedule.          Comments:         2/4/2010-amachado: Spoke to Jesse at Eastern Fire Proetction. He said that Pat's Pizza is occupying the whole building. He also said that he would send a PDF of the plan. He told me that his contact at ELC Corporation was Chris Tyll (776-3831). I left a vociemail for Chris Tyll. We need atenant fit up permit for Pat's Pizza. Permits		the basis of plans subm	itted. Any devi	ations shall require a separ	ate approval be	efore startin	g that
<ol> <li>Sprinkler systems to be designed and installed per IBC 2003 standards Sec. 903.3.1</li> <li>Dept: Fire Status: Approved with Conditions Reviewer: Capt Keith Gautreau Approval Date: 02/11/2010 Note: Ok to Issue: ☑</li> <li>Fire Department connection shall be 5" storz.</li> <li>The Fire alarm and Sprinkler systems shall be reviewed by a licensed contractor[s] for code compliance. Compliance letters are required.</li> <li>The sprinkler system shall be installed in accordance with NFPA 13.</li> <li>Application requires State Fire Marshal approval.</li> <li>Fire department connection type and location shall be approved in writing by fire prevention bureau.</li> <li>The Fire Department will require knox locking caps on all Fire Department Connections on the exterior of the building.</li> <li>System acceptance and commissioning must be co-ordinated with alarm and suppression system contractors and the Fire Department. Call 874-8703 to schedule.</li> <li>Comments:</li> <li>2/4/2010-amachado: Spoke to Jesse at Eastern Fire Protection. He said that Pat's Pizza is occupying the whole building. He also said that he would send a PDF of the plan. He told me that his contact at ELC Corporation was Chris Tyll (776-3831). I left a vociemail for Chris Tyll. We need atenant fit up permit for Pat's Pizza. Permits</li> </ol>	Dept: Building Status: A	pproved with Condition	ns <b>Reviewer</b> :	Jeanine Bourke	Approval Dat	e: 02/	12/2010
<ol> <li>Sprinkler systems to be designed and installed per IBC 2003 standards Sec. 903.3.1</li> <li>Dept: Fire Status: Approved with Conditions Reviewer: Capt Keith Gautreau Approval Date: 02/11/2010 Note: Ok to Issue: ☑</li> <li>Fire Department connection shall be 5" storz.</li> <li>The Fire alarm and Sprinkler systems shall be reviewed by a licensed contractor[s] for code compliance. Compliance letters are required.</li> <li>The sprinkler system shall be installed in accordance with NFPA 13.</li> <li>Application requires State Fire Marshal approval.</li> <li>Fire department connection type and location shall be approved in writing by fire prevention bureau.</li> <li>The Fire Department will require knox locking caps on all Fire Department Connections on the exterior of the building.</li> <li>System acceptance and commissioning must be co-ordinated with alarm and suppression system contractors and the Fire Department. Call 874-8703 to schedule.</li> <li>Comments:</li> <li>2/4/2010-amachado: Spoke to Jesse at Eastern Fire Protection. He said that Pat's Pizza is occupying the whole building. He also said that he would send a PDF of the plan. He told me that his contact at ELC Corporation was Chris Tyll (776-3831). I left a vociemail for Chris Tyll. We need atenant fit up permit for Pat's Pizza. Permits</li> </ol>	Note:					Ok to Issue	: 🗸
Dept:       Fire       Status: Approved with Conditions       Reviewer:       Capt Keith Gautreau       Approval Date:       02/11/2010         Note:       Ok to Issue:       Image: Capt Keith Gautreau       Approval Date:       02/11/2010         1)       Fire Department connection shall be 5" storz.       Ok to Issue:       Image: Capt Keith Gautreau       Approval Date:       02/11/2010         2)       The Fire alarm and Sprinkler systems shall be reviewed by a licensed contractor[s] for code compliance. Compliance letters are required.       Ok       to Issue:       Image: Capt Keith Gautreau         3)       The sprinkler system shall be installed in accordance with NFPA 13.       Application requires State Fire Marshal approval.       Site department connection type and location shall be approved in writing by fire prevention bureau.       Generation of the building.         5)       Fire department will require knox locking caps on all Fire Department Connections on the exterior of the building.       Sister Comments:         2/4/2010-amachado:       Spoke to Jesse at Eastern Fire Proetction. He said that Pat's Pizza is occupying the whole building. He also said that he would send a PDF of the plan. He told me that his contact at ELC Corporation was Chris Tyll (776-3831). I left a vociemail for Chris Tyll. We need atenant fit up permit for Pat's Pizza. Permits		nd installed per IBC 200	)3 standards Sec	903 3 1			
Note:       Ok to Issue:       ✓         1) Fire Department connection shall be 5" storz.       2)       The Fire alarm and Sprinkler systems shall be reviewed by a licensed contractor[s] for code compliance. Compliance letters are required.       3)         3) The sprinkler system shall be installed in accordance with NFPA 13.       4)       Application requires State Fire Marshal approval.       5)         5) Fire department connection type and location shall be approved in writing by fire prevention bureau.       6)       The Fire Department will require knox locking caps on all Fire Department Connections on the exterior of the building.         7) System acceptance and commissioning must be co-ordinated with alarm and suppression system contractors and the Fire Department. Call 874-8703 to schedule.       Comments:         2/4/2010-amachado: Spoke to Jesse at Eastern Fire Proetction. He said that Pat's Pizza is occupying the whole building. He also said that he would send a PDF of the plan. He told me that his contact at ELC Corporation was Chris Tyll (776-3831). I left a vociemail for Chris Tyll. We need atenant fit up permit for Pat's Pizza. Permits	i) spinnier systems to be designed a	na motanea per 120 200					
<ol> <li>Fire Department connection shall be 5" storz.</li> <li>The Fire alarm and Sprinkler systems shall be reviewed by a licensed contractor[s] for code compliance. Compliance letters are required.</li> <li>The sprinkler system shall be installed in accordance with NFPA 13.</li> <li>Application requires State Fire Marshal approval.</li> <li>Fire department connection type and location shall be approved in writing by fire prevention bureau.</li> <li>The Fire Department will require knox locking caps on all Fire Department Connections on the exterior of the building.</li> <li>System acceptance and commissioning must be co-ordinated with alarm and suppression system contractors and the Fire Department. Call 874-8703 to schedule.</li> <li>Comments:</li> <li>2/4/2010-amachado: Spoke to Jesse at Eastern Fire Protection. He said that Pat's Pizza is occupying the whole building. He also said that he would send a PDF of the plan. He told me that his contact at ELC Corporation was Chris Tyll (776-3831). I left a vociemail for Chris Tyll. We need atenant fit up permit for Pat's Pizza. Permits</li> </ol>	Dept: Fire Status: A	pproved with Condition	ns <b>Reviewer</b> :	: Capt Keith Gautreau	Approval Dat	e: 02/	1/2010
<ol> <li>2) The Fire alarm and Sprinkler systems shall be reviewed by a licensed contractor[s] for code compliance. Compliance letters are required.</li> <li>3) The sprinkler system shall be installed in accordance with NFPA 13.</li> <li>4) Application requires State Fire Marshal approval.</li> <li>5) Fire department connection type and location shall be approved in writing by fire prevention bureau.</li> <li>6) The Fire Department will require knox locking caps on all Fire Department Connections on the exterior of the building.</li> <li>7) System acceptance and commissioning must be co-ordinated with alarm and suppression system contractors and the Fire Department. Call 874-8703 to schedule.</li> <li>Comments:</li> <li>2/4/2010-amachado: Spoke to Jesse at Eastern Fire Proetction. He said that Pat's Pizza is occupying the whole building. He also said that he would send a PDF of the plan. He told me that his contact at ELC Corporation was Chris Tyll (776-3831). I left a vociemail for Chris Tyll. We need atenant fit up permit for Pat's Pizza. Permits</li> </ol>	Note:					Ok to Issue	: 🗸
<ul> <li>Compliance letters are required.</li> <li>3) The sprinkler system shall be installed in accordance with NFPA 13.</li> <li>4) Application requires State Fire Marshal approval.</li> <li>5) Fire department connection type and location shall be approved in writing by fire prevention bureau.</li> <li>6) The Fire Department will require knox locking caps on all Fire Department Connections on the exterior of the building.</li> <li>7) System acceptance and commissioning must be co-ordinated with alarm and suppression system contractors and the Fire Department. Call 874-8703 to schedule.</li> <li>Comments:</li> <li>2/4/2010-amachado: Spoke to Jesse at Eastern Fire Protection. He said that Pat's Pizza is occupying the whole building. He also said that he would send a PDF of the plan. He told me that his contact at ELC Corporation was Chris Tyll (776-3831). I left a vociemail for Chris Tyll. We need atenant fit up permit for Pat's Pizza. Permits</li> </ul>	1) Fire Department connection shall b	be 5" storz.					
<ul> <li>4) Application requires State Fire Marshal approval.</li> <li>5) Fire department connection type and location shall be approved in writing by fire prevention bureau.</li> <li>6) The Fire Department will require knox locking caps on all Fire Department Connections on the exterior of the building.</li> <li>7) System acceptance and commissioning must be co-ordinated with alarm and suppression system contractors and the Fire Department. Call 874-8703 to schedule.</li> <li>Comments:</li> <li>2/4/2010-amachado: Spoke to Jesse at Eastern Fire Protection. He said that Pat's Pizza is occupying the whole building. He also said that he would send a PDF of the plan. He told me that his contact at ELC Corporation was Chris Tyll (776-3831). I left a vociemail for Chris Tyll. We need atenant fit up permit for Pat's Pizza. Permits</li> </ul>							
<ul> <li>5) Fire department connection type and location shall be approved in writing by fire prevention bureau.</li> <li>6) The Fire Department will require knox locking caps on all Fire Department Connections on the exterior of the building.</li> <li>7) System acceptance and commissioning must be co-ordinated with alarm and suppression system contractors and the Fire Department. Call 874-8703 to schedule.</li> <li>Comments:</li> <li>2/4/2010-amachado: Spoke to Jesse at Eastern Fire Proetction. He said that Pat's Pizza is occupying the whole building. He also said that he would send a PDF of the plan. He told me that his contact at ELC Corporation was Chris Tyll (776-3831). I left a vociemail for Chris Tyll. We need atenant fit up permit for Pat's Pizza. Permits</li> </ul>	3) The sprinkler system shall be installed in accordance with NFPA 13.						
<ul> <li>6) The Fire Department will require knox locking caps on all Fire Department Connections on the exterior of the building.</li> <li>7) System acceptance and commissioning must be co-ordinated with alarm and suppression system contractors and the Fire Department. Call 874-8703 to schedule.</li> <li>Comments:</li> <li>2/4/2010-amachado: Spoke to Jesse at Eastern Fire Proetction. He said that Pat's Pizza is occupying the whole building. He also said that he would send a PDF of the plan. He told me that his contact at ELC Corporation was Chris Tyll (776-3831). I left a vociemail for Chris Tyll. We need atenant fit up permit for Pat's Pizza. Permits</li> </ul>	4) Application requires State Fire Marshal approval.						
<ul> <li>7) System acceptance and commissioning must be co-ordinated with alarm and suppression system contractors and the Fire Department. Call 874-8703 to schedule.</li> <li>Comments:</li> <li>2/4/2010-amachado: Spoke to Jesse at Eastern Fire Proetction. He said that Pat's Pizza is occupying the whole building. He also said that he would send a PDF of the plan. He told me that his contact at ELC Corporation was Chris Tyll (776-3831). I left a vociemail for Chris Tyll. We need atenant fit up permit for Pat's Pizza. Permits</li> </ul>	5) Fire department connection type and location shall be approved in writing by fire prevention bureau.						
Department. Call 874-8703 to schedule.  Comments: 2/4/2010-amachado: Spoke to Jesse at Eastern Fire Proetction. He said that Pat's Pizza is occupying the whole building. He also said that he would send a PDF of the plan. He told me that his contact at ELC Corporation was Chris Tyll (776-3831). I left a vociemail for Chris Tyll. We need atenant fit up permit for Pat's Pizza. Permits	6) The Fire Department will require knox locking caps on all Fire Department Connections on the exterior of the building.						
2/4/2010-amachado: Spoke to Jesse at Eastern Fire Proetction. He said that Pat's Pizza is occupying the whole building. He also said that he would send a PDF of the plan. He told me that his contact at ELC Corporation was Chris Tyll (776-3831). I left a vociemail for Chris Tyll. We need atenant fit up permit for Pat's Pizza. Permits							
that he would send a PDF of the plan. He told me that his contact at ELC Corporation was Chris Tyll (776-3831). I left a vociemail for Chris Tyll. We need atenant fit up permit for Pat's Pizza. Permits	Comments:						
2/10/2010-gg: received from historic as of 02/10/10. /gg	that he would send a PDF of the plan. He told me that his contact at ELC Corporation was Chris Tyll (776-3831). I left a vociemail for						

## CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provision of the code(s) applicable to such permit.

SIGNATURE OF APPLICAN	ADDRESS	DATE	РНО